



Converse Consultants

Geotechnical Engineering, Environmental & Groundwater Science, Inspection & Testing Services

August 23, 2023

Washoe County Health District
Air Quality Management Division
1001 E. Ninth Street, Suite B171
Reno, Nevada 89512

AIR QUALITY MGMT.

AUG 24 2023

WASHOE COUNTY
HEALTH DIST.

Attn: Ms. Genine Rosa (Grosa@washoecounty.gov)
Environmental Engineer II

Subject: POTENTIAL TO EMIT EVALUATION – RENOWN HOSPITAL MILL STREET FACILITY
1155 Mill Street, Reno, NV
Converse Project No: 23-23187-01

Ms. Rosa,

On behalf of Renown Health, Converse Consultants (Converse) is submitting the results of a Potential to Emit (PTE) evaluation conducted at the above-referenced site (Site). This PTE evaluation was conducted at the request of the Washoe County Health District Air Quality Management Division (AQMD). Two PTE evaluations were conducted – one for the facility as it currently exists and the other for the facility as it will exist following the construction of the new central utility plant (CUP) and demolition of the existing CUP. In accordance with the AQMD's request, the emissions from fuel burning equipment on the adjacent properties that support the Site are included in the PTE evaluations. The PTE evaluations include actual emissions for the Site based on annual throughput/consumption data for the site for 2022.

The PTE calculations indicate that the potential emissions of nitrogen oxides (NO_x) will exceed the Title V permit threshold of 100 ton/year. The potential emissions for the other pollutants of concern included in the PTE evaluation were well below the Title V threshold. Although the potential NO_x emissions exceed the Title V threshold, the actual NO_x emissions for the Site are below 20 tons/year. As such, it is our opinion that a Synthetic Minor Source Permit (SMSP) limiting NO_x emissions to below the Title V threshold is appropriate for this Site.

The following documents are included in this submittal:

- SMSP application
- PTE calculations
- Stationary Source Permit applications (new boilers and generators)

- Check in the amount of \$4,154 for AQMD application review fees.

Should you have any questions, please contact the undersigned at (775) 225-7655.

Respectfully submitted,

CONVERSE CONSULTANTS,



Tracy Johnston, PE, CEM
Senior Engineer

Enclosures: SMSP Application
Stationary Source Permit Applications
Check in the amount of \$4,154

Distribution: Addressee (hand-delivered)
Chris Baker (Chris.Baker@renown.org)
Jason Dondero (jdondero@cumming-group.com)

Attachment 1

Synthetic Minor Source Permit Application

**SYNTHETIC MINOR SOURCE PERMIT
APPLICATION**
Renown Health | Mill Street Facility

**Washoe County Health District,
Air Quality Management Division**

TRINITY CONSULTANTS

1575 Delucchi Lane
Suite 203
Reno, NV 89502
(775) 242-3200

August 2023

Project 232901.0031



TABLE OF CONTENTS

1. EXECUTIVE SUMMARY	1-1
2. PROPOSED PERMIT REVISIONS	2-1
3. EMISSION CALCULATIONS	3-1
3.1 Facility Emissions Summary.....	3-1
3.2 Boiler Emission Calculations	3-2
3.3 Emergency Generator	3-2
3.4 Adjacent Ancillary Equipment.....	3-3
4. REGULATORY APPLICABILITY	4-1
4.1 Federal Regulations	4-1
4.1.1 Non-Attainment New Source Review	4-1
4.1.2 Prevention of Significant Deterioration.....	4-1
4.1.3 Class I Operating Permit.....	4-1
4.1.4 New Source Performance Standards.....	4-1
4.1.5 National Emission Standards for Hazardous Air Pollutants	4-2
4.2 WCAQMD Source Specific Requirements	4-3
4.2.1 Requested Synthetic Minor Limitations	4-3
4.3 WCAQMD Application Requirements	4-4
APPENDIX A. DETAILED EMISSION CALCULATIONS	
APPENDIX B. WCAQMD PERMIT APPLICATIONS FOR NEW EQUIPMENT	
APPENDIX C. SUBMITTALS FOR NEW EQUIPMENT	

1. EXECUTIVE SUMMARY

Renown Regional Medical Center (Renown) currently owns and operates a healthcare facility located at and around 1155 Mill Street, Reno, Nevada (the Mill Street Facility). The Facility was issued a Permit to Operate No. AAIR16-0714 (the Permit) by the Washoe County Health District, Air Quality Management Division (WCAQMD). The facility operates various boilers and emergency engines with associated generators to provide power during emergencies. Renown submitted an application to install four (4) new boilers and three (3) new emergency generators in June 2023. This application narrative has been prepared upon request by the WCAQMD to supplement the information contained in the initial June 2023 application.

Pursuant to the requirements of Washoe County District Board of Health (WCDBOH) Regulations Governing Air Quality Management (AQM), Renown is submitting this permit revision application to the Washoe County Air Quality Management Division to request a synthetic minor source permit to operate. Based on the control equipment and type of operations at the Renown, the facility will be classified as a synthetic minor source of emissions of NO_x. All other pollutants will have a potential to emit below major source thresholds.

With the submittal of this permit revision application pursuant to WCDBOH Regulations Governing AQM – 030.920 (the Application), Renown is proposing the following updates to the Facility and the Permit. Please see Section 2 for a detailed discussion of the requested updates:

- Removal of all three (3) existing boilers:
 - ◆ (1) 1,000 hp Babcock & Wilcox Boiler
 - ◆ (1) 1,000 hp Cleaver Brooks Boiler
 - ◆ (1) 800 hp Cleaver Brooks Fire Tube Boiler (m/n CBL-200-800-200)
- Removal of eight (8) existing generators:
 - ◆ (3) 350 kW Cummins (mfg. 1970)
 - ◆ (4) 1,000 kW Cummins (mfg. 1983)
 - ◆ (1) 2,000 kW CAT (mfg. 2003)
- Installation of three (3) new Cleaver Brooks CBEX-2W-200-900-150ST boilers each rated at 36.741 MMBtu/hr
- Installation of three (3) new Model Year 2023 EPA Tier 2 Caterpillar 3516C engines with associated generators each rated at 2,000 kW
- Addition of a cumulative 8.0955 MMBtu/hr of Natural Gas fired ancillary equipment associated with the Mill Street Campus but located at various addresses (901 & 1095 E 2nd, 75, 85, 225, & 309 Kirman, 975, 980, & 1000 Ryland) associated with the Facility
- Incorporation of a 99 ton per year (tpy) emission limit for Nitrogen Oxides (NO_x) to maintain the source as a Synthetic Minor facility.

Appendix A contains detailed facility-wide emission calculations for the existing emission units, the proposed emission units, and Calendar Year 2022's Actual Emissions. As such, this Application and associated appendix contain all the required information for a Synthetic Minor Source Operating Permit Revision application in addition to the previously submitted WCAQMD Forms. Additionally, enclosed with this application is a check in the amount of \$3,796 for Synthetic Minor Source Operating Permit Revision with <100 tons of pollutants per year.¹

¹ Per WCAQMD Air Quality Management Fees found at <https://www.washoecounty.gov/health/resources/fees/air-quality-management-fees.php>.

2. PROPOSED PERMIT REVISIONS

As part of this Revision Application, Renown is proposing to make the following changes to the Permit:

- Removal of all three (3) existing boilers:
 - ◆ (1) 1,000 hp Babcock & Wilcox Boiler
 - ◆ (1) 1,000 hp Cleaver Brooks Boiler
 - ◆ (1) 800 hp Cleaver Brooks Fire Tube Boiler (m/n CBL-200-800-200)
- Removal of eight (8) existing generators:
 - ◆ (3) 350 kW Cummins (mfg. 1970)
 - ◆ (4) 1,000 kW Cummins (mfg. 1983)
 - ◆ (1) 2,000 kW CAT (mfg. 2003)
- Installation of three (3) new Cleaver Brooks CBEX-2W-200-900-150ST boilers each rated at 36.741 MMBtu/hr
- Installation of three (3) new Model Year 2023 EPA Tier 2 Caterpillar 3516C engines with associated generators each rated at 2,000 kW
- Addition of a cumulative 8.0955 MMBtu/hr of Natural Gas fired ancillary equipment associated with the Mill Street Campus but located at various addresses (901 & 1095 E 2nd, 75, 85, 225, & 309 Kirman, 975, 980, & 1000 Ryland) associated with the Facility
- Incorporation of a 99 ton per year (tpy) emission limit for Nitrogen Oxides (NO_x) to maintain the source as a Synthetic Minor facility.

3. EMISSION CALCULATIONS

3.1 Facility Emissions Summary

This section includes the emissions calculation methodology for the existing facility and for the proposed project at the facility. Table 3-1 below provides the existing equipment's potential-to-emit (PTE) as well as the CY2022 actual emissions for the Mill Street Facility. This table demonstrates that, although the facility has a PTE of greater than 100 tons per year (tpy) for Nitrogen Oxides (NO_x), due to the hours of operation of the existing equipment, the facility did not exceed the Title V threshold of 100 tpy for NO_x. Therefore, the Mill Street Facility did not and will not require a Title V Operating permit existing or proposed operations. Table 3-2 below provides a comprehensive Facility-wide emissions summary with post-project. Detailed emission calculations are included in Appendix A.

Table 3-1. Current Emissions Summary

Pollutants	Existing Boilers	Existing Engines	Facility-wide Potential Emissions (tpy)	Existing Actual Emissions (tpy)	Title V Thresholds	Actual Emissions Exceeds?
NO _x	59.3	112.21	171.5	18.03	100	No
CO	47.1	25.57	72.7	13.52	100	No
VOC	3.1	3.59	6.7	0.95	100	No
PM	4.6	3.73	8.3	1.28	100	No
PM ₁₀	4.4	3.73	8.1	1.27	100	No
PM _{2.5}	4.3	3.73	8.1	1.27	100	No
SO ₂	32.4	0.77	33.2	0.56	100	No
CO _{2e}	71,138	5,300.87	76,439	18,756	--	N/A
Single HAP (hexane)	0.99	--	1.0	0.21	10	No
Total HAP	1.08	2.54	3.6	0.26	25	No

Table 3-2. Project Emissions Summary

Pollutants	Proposed Boilers	Proposed Engines	Facility-wide Potential Emissions (tpy)
NO _x	52.04	73.30	125.34
CO	41.39	13.36	54.75
VOC	2.71	1.95	4.66
PM	4.05	1.68	5.73
PM ₁₀	3.87	1.68	5.55
PM _{2.5}	3.82	1.68	5.50
SO ₂	28.24	0.05	28.29
CO _{2e}	62,116.21	4914.70	67,031
Single HAP (hexane)	1.11	--	1.11
Total HAP	1.35	2.60	3.96

3.2 Boiler Emission Emissions

Boiler emissions are comprised of natural gas and diesel fired external combustion equipment. Emission factors were obtained from U.S. EPA AP-42 Section 1.4, *Natural Gas Combustion*, July 1998, as well as 40 CFR Part 98 Subpart C for GHG emissions. Emissions were calculated based on maximum input capacity, maximum annual hours of operation, and established emission factors. As the boilers have the capacity to fire diesel fuel in emergency situations, such as curtailment, 500 hours of operation of the boilers while firing Diesel Fuel #2 was included. Emission factors were obtained from U.S. EPA AP-42 Section 1.3, *Fuel Oil Combustion*, September 1999, as well as 40 CFR Part 98 Subpart C for GHG emissions.

3.3 Ancillary Equipment Emissions

Ancillary equipment emissions are comprised of natural gas fired external combustion equipment. Emission factors were obtained from U.S. EPA AP-42 Section 1.4, *Natural Gas Combustion*, July 1998, as well as 40 CFR Part 98 Subpart C for GHG emissions. Emissions were calculated -based on maximum input capacity, maximum annual hours of operation, and established emission factors. For convenience, the sum total of all Renown's Mill Street Campus was identified as 8.0955 MMBtu/hr from all HVAC or similar units.

3.4 Emergency Generator Emissions

Emissions from the existing stationary diesel-fired internal combustion equipment were calculated based on the maximum input rates, a maximum of 500 annual hours of operation, and emission factors. The emission factors are based on the applicable standards as contained in New Source Performance Standards (NSPS) Subpart IIII "*Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.*" Emission factors for pollutants not addressed by NSPS Subpart IIII are pursuant to U.S. EPA AP-42, Section 3.3 and 3.4, *Gasoline and Diesel Industrial Engines & Large Stationary Diesel And All Stationary Dual-fuel Engines*, August 2000 & October 1996, respectively as well as 40 CFR Part 98 for greenhouse gas (GHG) emissions.

Emissions from the proposed stationary diesel-fired internal combustion equipment were calculated based on the maximum input rates, a maximum of 500 annual hours of operation, and applicable emission factors. The emission factors are based on the applicable standards as contained in NSPS Subpart IIII and vendor guaranteed emission rates at 100% load.

3.5 Adjacent Ancillary Equipment

Emissions generated by fuel burning devices from adjacent supporting properties are inclusive of the facility's PTE. Emissions generated from adjacent fuel burning sources were calculated based on maximum heat input rates, a maximum of 8,760 annual hours of operation (natural gas-fired), and natural gas emission factors. The emission factors are based on the applicable standards as contained in AP-42 Chapter 1.4, Table 1.4-1 and Table 1.4-2, respectively as well as per 40 CFR 98 Subpart A. The emission factors are based on the applicable standards as contained in NSPS Subpart IIII. Emissions derived from diesel-gas firing are non-existent as all equipment isn't configured to operate on diesel fuel at any time.

4. REGULATORY APPLICABILITY

Renown is subject to federal, state, and local air regulations. This section summarizes the air permitting requirements and the key air quality regulations that apply to the proposed updates at the Facility. Specifically addressed are Federal New Source Review (NSR), Prevention of Significant Deterioration (PSD), Class I permitting (i.e., Title V of the 1990 Clean Air Act Amendments), New Source Performance Standards (NSPS), National Emission Standards for Hazardous Air Pollutants (NESHAP), and state and local-specific requirements. Applicability to certain general provisions is not detailed in this narrative summary.

4.1 Federal Regulations

4.1.1 Non-Attainment New Source Review

The Facility is located in Washoe County, which is classified as attainment or unclassifiable for all criteria pollutants. As such Non-Attainment New Source Review does not apply.

4.1.2 Prevention of Significant Deterioration

The Facility is located in Washoe County, which is classified as attainment or unclassifiable for all criteria pollutants. As such, the Facility would potentially be subject to PSD requirements. WCAQMD has the authority to issue PSD permits under WCDBOH Regulations Governing AQM – 030.600 which incorporates by reference the federal PSD requirements. The Facility is not a major stationary source as defined in WCDBOH Regulations Governing AQM – 010.090. None of the changes proposed in this Application constitute a major stationary source in and of itself. As such, PSD requirements are not triggered.

4.1.3 Class I Operating Permit

40 CFR Part 70 establishes the major source operating permit program. The major source (i.e., Class I) thresholds for sources in attainment areas are 10 tons per year of a single HAP, 25 tpy of any combination of HAP, or 100 tpy of a criteria pollutant. Per WCDBOH Regulations Governing AQM – 010.090, fugitive emissions are to be considered in determining whether a source is a major source if the source category belongs to the "List of 28" (40 CFR 52.21(b)(1)(iii)). The Facility is not on the "List of 28" and as such, fugitive emissions need not be considered. As demonstrated in Section 3, the Facility's potential emissions are greater than the Class I thresholds defined in WCDBOH Regulations Governing AQM – 010.090 but as part of this permit application is requesting a federally enforceable facility-wide emission limit of 99 tpy NO_x. As such, the Facility is not subject to Class I permitting requirements.

4.1.4 New Source Performance Standards

NSPS apply to certain types of equipment that are newly constructed, modified, or reconstructed after a given applicability date. The proposed new boilers included in this application are covered by an NSPS.

40 CFR 60 Subpart Dc– Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

NSPS Subpart Dc is applicable to steam generating units that commenced construction, modification, or reconstruction after June 9, 1989, and which have a maximum design heat input capacity of 100 MMBtu/hr or less, but greater than or equal to 10 MMBtu/hr. All four (4) of the boilers Renown is requesting to construct and operate have a maximum heat input capacity of 36.74 MMBtu/hr, fire both natural gas and

diesel fuel #2, and will be constructed after June 9, 1989. Therefore, all four (4) boilers included in this application are subject to Subpart Dc.

The boilers will comply with NSPS Subpart Dc standards by combusting only natural gas or diesel fuel during an emergency (i.e., curtailment). Subpart Dc does not include any emission limits or standards for firing natural gas but does have emissions standards include a 0.50 lb/MMBtu SO₂ limit per 40 CFR 60.42c(d) and a 20% opacity limit excluding one – 6-minute period per hour of not more than 27 percent opacity per 40 CFR 60.43c(c) during periods of oil combustion. Both of these limits are applicable upon completion of initial performance testing. Renown plans to comply with the oil-fired SO₂ emission limit by obtaining a certification from the fuel oil supplier denoting the sulfur content of the provided oil is less than 0.5 % by weight sulfur. This sulfur content will be obtained with each shipment of fuel oil to the Facility and retained for demonstrating compliance. Particulate matter compliance is to be demonstrated by conducting a performance test while firing fuel oil.

Per 40 CFR 60.48c, the Facility will comply with the reporting requirements for a new source including dates of construction and actual startup, provide performance test data, as well as recordkeeping requirements for a facility firing diesel fuel and complying with the fuel supplier certification, and all other required records.

40 CFR 60 Subpart IIII – Compression Ignition Internal Combustion Engines

NSPS Subpart IIII applies to manufacturers, owners, and operators of stationary compression-ignition (CI) internal combustion engines (ICE) as specified in 40 CFR 60.4200(a) through (e). NSPS Subpart IIII sets emission standards for NO_x, CO, PM and hydrocarbons (HC) for certain types of CI ICE. Pursuant to 40 CFR 60.4200(a), Subpart IIII applies to stationary CI ICE with the model year being 2006 or later.

Renown plans to install three (3) diesel fuel-fired emergency generators (CI ICE) at the facility. The generators will likely be ordered by Renown in 2023, thus requiring purchase of NSPS IIII compliant engines. The three (3) generators are rated at 2,680 hp. Pursuant to 40 CFR 60.4205(b), the generators (engines) purchased by Renown must be certified by the manufacturer to meet the emissions standards in 40 CFR 1039, and the engines must be installed and configured according to the manufacturer's emission-related specifications.²

Owners and operators of emergency engines must comply with the emissions limitations of NSPS Subpart IIII by purchasing a certified engine with a non-resettable hour meter, performing maintenance on the engine according to the manufacturer's written instructions, and keeping records of maintenance and engine certifications on-site. Additionally, pursuant to 60.4211(f)(3), emergency engines cannot operate for more than 50 hours for non-emergency use and 100 total hours for non-emergency use, maintenance, and testing. Renown will comply with all the requirements of NSPS Subpart IIII upon the installation and operation of the proposed engines.

4.1.5 National Emission Standards for Hazardous Air Pollutants

NESHAP are emission standards for HAP and are applicable to major and area sources of HAP. A HAP major source is defined as having potential emissions in excess of 25 tpy for total HAP and/or potential emissions in excess of 10 tpy for any individual HAP. An area source is a stationary source that is not a major source. Part 63 NESHAP allowable emission limits are established on the basis of a Maximum Achievable Control Technology (MACT) determination for a particular source category. NESHAP apply to sources in specifically regulated industrial source categories (CAA Section 112(d)) or on a case-by-case basis (Section 112(g)) for

² 40 CFR 60.4202(a)(2)

facilities not regulated as a specific industrial source type. Potential emissions at the Facility will be below 25 tpy for total HAP and 10 tpy for all individual HAP. Therefore, the facility is an area source of HAP emissions.

40 CFR 63 Subpart ZZZZ – Stationary Reciprocating Internal Combustion Engines

Pursuant to the requirements of 40 CFR 63.6585, NESHAP Subpart ZZZZ applies to the three (3) generators that are proposed to be installed at Renown. However, pursuant to 40 CFR 63.6590(c), the requirements listed under NESHAP Subpart ZZZZ are met if the requirements of NSPS Subpart IIII or NSPS Subpart JJJJ are met. As the emergency generator engines are subject to the requirements of NSPS Subpart IIII, no further requirements apply for said engines under this part.

40 CFR 63 Subpart JJJJJ - Industrial, Commercial, and Institutional Boilers Area Sources

NESHAP Subpart JJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources, regulates industrial, commercial, and institutional boilers located at area sources of HAP. The facility is an area source and thus the boilers are potentially subject to Subpart JJJJJ. In the scope of this application, the boilers will be constructed after June 4, 2010 (new source), are considered a gas-fired boiler, and are rated greater than 10 MMBtu/hr, the boilers are not subject to NESHAP Subpart JJJJJ.

A gas-fired boiler is defined by the Subpart as, "Gas-fired boiler includes any boiler that burns gaseous fuels not combined with any solid fuels and burns liquid fuel only during periods of gas curtailment, gas supply interruption, startups, or for periodic testing, maintenance, or operator training on liquid fuel. Periodic testing, maintenance, or operator training on liquid fuel shall not exceed a combined total of 48 hours during any calendar year."

Although the boilers have a dual-fuel capacity (both natural gas and diesel fuel), the boilers are expected to only operate on diesel gas during periods of gas curtailment, gas supply interruption, startups, or for periodic testing, maintenance, or operator training. In CY2022, the existing boilers each operated for 8 hours, demonstrating that Renown has the capability to not exceed a total of 48 hours on liquid fuel during any calendar year. Therefore, as stated above, the proposed boilers are not subject to the regulation.

4.2 WCAQMD Source Specific Requirements

In addition to federal air regulations, the WCDBOH Regulations Governing AQM – 030 provide additional state requirements at the source-level.

4.2.1 Requested Synthetic Minor Limitations

Per the WCDBOH Regulations Governing AQM – 030.905 Part B(6), a source may limit the facility emissions to levels below the major source threshold and become a synthetic minor source. Renown is requesting a federally enforceable synthetic minor limit on NO_x such that the Renown Facility will not be considered a major source with respect to the Title V Operating Permit. Renown is requesting a 99 tpy NO_x permit limit that will be controlled by limiting the generators' hours of operation and the boilers actual operation on diesel. As demonstrated in Table 3.1, actual emissions do not exceed 95 tpy for all regulated pollutants, including 70 tpy of PM₁₀, 9 tpy of any single HAP, 23 tpy of any combination of HAP, and 90% of any less threshold for a single HAP. Renown will maintain an operating log detailing the hours of operation for each generator that will be made available to WCAQMD upon request per the requirements in WCDBOH Regulations Governing AQM – 010.090 Part E.

4.3 WCAQMD Application Requirements

As stated previously in this Application, Renown is submitting this revision application pursuant to the requirements of WCAQMD. The following is a summary of the WCAQMD requirements in *italic, bold* text as well as Renown's action to meet each requirement in standard text.

1. Each application must contain, as a minimum:

- (a) Name and physical address of business and other identifying information;**
- (b) Nature of business, including products produced and processes to be used, including any applicable SIC and NAICS codes;**
- (c) Name and phone number of agent, manager or contact person;**

Please refer to previously submitted WCAQMD forms.

- (d) Site information, including flow diagrams, description of site, description of all insignificant activities for Part 70 permits, and all emission points in sufficient detail to determine applicability and fees;**
- (e) Nature and quantity of emissions for all regulated pollutants on an hourly, daily or annual basis, expressed in units as necessary to determine compliance, including notation as to if the proposed modification will be a major source or modification and which pollutants the source will be major for;**
- (f) Facilities or process equipment to be permitted or have their permit revised, including the control equipment, control measures or work practices to be utilized in emission reduction;**
- (g) Operating times, temperatures, fuels used, raw materials consumption, production rates, or other pertinent information;**

The information shall be sufficient in scope to enable the Control Officer to make any determination pursuant to the requirements of Section 030.010 of these regulations.

Please refer to Sections 2, 3, and 4, and Appendix A of this Application for information satisfying the requirements of (d) through (g).

- (h) Such other information or documentation requested by the Control Officer as necessary to determine compliance with all requirements and standards;**

Additional information and documentation will be supplied as requested.

- (i) Signature of a responsible person of the firm or business;**

Please refer to previously submitted WCAQMD forms.

- (j) A plan review fee and any other fees as set by the District Board of Health;**
- (k) Calculations and methods used to estimate emissions.**

Please refer to Sections 3 and Appendix A of this Application.

APPENDIX A. DETAILED EMISSION CALCULATIONS

**Renown
Mill Street - Reno, Nevada**

Table B-1. Facility Potential Emissions Summary (tpy)

Pollutants	Existing		Facility-wide Potential		Proposed		Facility-wide Potential		Existing Actual Emissions (tpy)	Title V Thresholds	Actual Emissions Exceeds?
	Boilers	Engines	Engines	Emissions (tpy)	Boilers	Engines	Engines	Emissions (tpy)			
NO _x	59.3	112.21	171.5		52.04	73.30		125.34	18.03	100	No
CO	47.1	25.57	72.7		41.39	13.36		54.75	13.52	100	No
VOC	3.1	3.59	6.7		2.71	1.95		4.66	0.95	100	No
PM	4.6	3.73	8.3		4.05	1.68		5.73	1.28	100	No
PM ₁₀	4.4	3.73	8.1		3.87	1.68		5.55	1.27	100	No
PM _{2.5}	4.3	3.73	8.1		3.82	1.68		5.50	1.27	100	No
SO ₂	32.4	0.77	33.2		28.24	0.05		28.29	0.56	100	No
CO ₂ e	71,138	5,300.87	76,439		62,116.21	4914.70		67,031	18,756	--	N/A
Single HAP (hexane)	0.99	--	1.0		1.11	--		1.11	0.21	10	No
Total HAP	1.08	2.54	3.6		1.35	2.60		3.96	0.26	25	No

Table B-2. Boilers Criteria Pollutant Emissions

Boilers				
Equipment Info	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
Maximum Heat Input Rate	33,475 MMBtu/hr	38.8 MMBtu/hr	54.32 MMBtu/hr	8,095 MMBtu/hr
Diesel Fuel Consumption	239,107,142.9 Gal/hr	277,142,857.1 Gal/hr	388 Gal/hr	0 Gal/hr
Maximum Hours of Operation	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr
Hours of Operation on NG	8,260 hr/yr	8,260 hr/yr	8,260 hr/yr	8,760 hr/yr
Hours of Operation on Diesel	500 hr/yr	500 hr/yr	500 hr/yr	0 hr/yr

Emission Factors (Natural Gas) ¹	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf
CO	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf
VOC	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf
PM	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM ₁₀	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM _{2.5}	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
SO ₂	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf
CO ₂	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf
N ₂ O	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf
CH ₄	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf
CO _{2e} ²	120,713 lb/MMscf	120,713 lb/MMscf	120,713 lb/MMscf	120,713 lb/MMscf

Emission Factors (Diesel) ³	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal
CO	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal
VOC	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal
PM	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal
PM ₁₀	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal
PM _{2.5}	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal
SO ₂	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal
CO ₂	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal
N ₂ O	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal
CH ₄	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal
CO _{2e} ²	22,409 lb/1000 gal	22,409 lb/1000 gal	22,409 lb/1000 gal	22,409 lb/1000 gal

Potential Emissions ⁴	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	14.75 tpy	17.10 tpy	23.93 tpy	3.48 tpy
CO	11.68 tpy	13.54 tpy	18.96 tpy	2.92 tpy
VOC	0.77 tpy	0.89 tpy	1.24 tpy	0.19 tpy
PM	1.15 tpy	1.33 tpy	1.87 tpy	0.26 tpy
PM ₁₀	1.09 tpy	1.27 tpy	1.78 tpy	0.26 tpy
PM _{2.5}	1.08 tpy	1.25 tpy	1.75 tpy	0.26 tpy
SO ₂	8.57 tpy	9.93 tpy	13.91 tpy	0.02 tpy
CO ₂	17,597.93 tpy	20,397.31 tpy	28,556.23 tpy	4,171.56 tpy
N ₂ O	0.31 tpy	0.36 tpy	0.51 tpy	0.08 tpy
CH ₄	0.39 tpy	0.45 tpy	0.63 tpy	0.08 tpy
CO _{2e} ²	17,701.10 tpy	20,516.89 tpy	28,723.64 tpy	4,196.35 tpy

Notes:

1. AP-42 Chapter 1.4, Table 1.4-1 and Table 1.4-2. Uncontrolled emission factor for NO_x assumed for U201 and Low-NO_x burner emission factor for NO_x assumed for U202.
2. GWP%: CO₂ = 1, N₂O = 298, CH₄ = 25, per 40 CFR 98 Subpart A (rule effective January 1, 2014).
3. AP-42 Chapter 1.3 Table 1.3-1 (CO, SO₂, NO_x, and PM), Table 1.3-3 (VOC), Table 1.3-8 (N₂O), and Table 1.3-12 (CO₂); for #2 Diesel Fuel
4. Annual emissions per pollutant based on maximum of natural gas combustion and diesel combustion.

Table B-3. Boilers HAP Emissions

Pollutant	HAP?	Emission Factors (Diesel) ¹		Emission Factors (Natural Gas) ²		Diesel Emissions (tpy)			Natural Gas Emissions (tpy)			Combined HAP Emissions (tpy)		
		lb/Mgal	lb/Mscf	lb/Mscf	lb/Mscf	CB1	BW	CB2	CB1	BW	CB2	CB1	BW	CB2
Benzene	Yes	2.14E-04	lb/Mgal	2.10E-03	lb/MMscf	1.28E-05	1.49E-05	2.08E-05	2.85E-04	3.30E-04	4.62E-04	2.97E-04	3.45E-04	4.83E-04
Ethylbenzene	Yes	6.36E-05	lb/Mgal	--	lb/MMscf	3.80E-06	4.41E-06	6.17E-06	--	--	--	3.80E-06	4.41E-06	6.17E-06
Formaldehyde	Yes	3.30E-02	lb/Mgal	7.50E-02	lb/MMscf	1.97E-03	2.29E-03	3.20E-03	1.02E-02	1.18E-02	1.65E-02	1.21E-02	1.41E-02	1.97E-02
Naphthalene	Yes	1.13E-03	lb/Mgal	6.10E-04	lb/MMscf	6.75E-05	7.83E-05	1.10E-04	8.27E-05	9.58E-05	1.34E-04	1.50E-04	1.74E-04	2.44E-04
1,1,1-Trichloroethane	Yes	2.36E-04	lb/Mgal	--	lb/MMscf	1.41E-05	1.64E-05	2.29E-05	--	--	--	1.41E-05	1.64E-05	2.29E-05
Toluene	Yes	6.20E-03	lb/Mgal	3.40E-03	lb/MMscf	3.71E-04	4.30E-04	6.01E-04	4.61E-04	5.34E-04	7.49E-04	8.31E-04	9.64E-04	1.35E-03
o-Xylene	Yes	1.09E-04	lb/Mgal	--	lb/MMscf	1.26E-06	1.46E-06	2.05E-06	2.44E-07	2.83E-07	3.96E-07	6.52E-06	7.55E-06	1.06E-05
Acenaphthene	Yes	2.11E-05	lb/Mgal	1.80E-06	lb/MMscf	1.51E-08	1.75E-08	2.45E-08	2.44E-07	2.83E-07	3.96E-07	1.51E-06	1.74E-06	2.44E-06
Acenaphthylene	Yes	2.53E-07	lb/Mgal	1.80E-06	lb/MMscf	7.29E-08	8.45E-08	1.18E-07	3.25E-07	3.77E-07	5.28E-07	2.59E-07	3.00E-07	4.20E-07
Anthracene	Yes	1.22E-06	lb/Mgal	2.40E-06	lb/MMscf	2.40E-07	2.78E-07	3.89E-07	2.44E-07	2.83E-07	3.96E-07	3.98E-07	4.62E-07	6.46E-07
Benz(a)anthracene	Yes	4.01E-06	lb/Mgal	1.80E-06	lb/MMscf	8.85E-08	1.03E-07	1.44E-07	2.44E-07	2.83E-07	3.96E-07	4.84E-07	5.61E-07	7.85E-07
Benzo(b,k)fluoranthene	Yes	1.48E-06	lb/Mgal	1.80E-06	lb/MMscf	1.35E-07	1.57E-07	2.19E-07	3.36E-09	3.90E-09	5.45E-09	3.32E-07	3.85E-07	5.39E-07
Benzo(g,h,i)perylene	Yes	2.26E-06	lb/Mgal	1.80E-06	lb/MMscf	1.42E-07	1.65E-07	2.31E-07	3.36E-09	3.90E-09	5.45E-09	1.38E-07	1.60E-07	2.25E-07
Chrysene	Yes	2.38E-06	lb/Mgal	1.80E-06	lb/MMscf	9.98E-08	1.16E-07	1.62E-07	2.44E-07	2.83E-07	3.96E-07	3.86E-07	4.48E-07	6.27E-07
Dibenz(a,h)anthracene	Yes	1.67E-06	lb/Mgal	--	lb/MMscf	2.89E-07	3.35E-07	4.69E-07	4.89E-08	5.67E-08	7.94E-08	1.49E-07	1.72E-07	2.41E-07
Fluoranthene	Yes	4.84E-06	lb/Mgal	3.61E-07	lb/MMscf	2.67E-07	3.10E-07	4.34E-07	--	--	--	2.89E-07	3.35E-07	4.69E-07
Fluorene	Yes	4.47E-06	lb/Mgal	1.69E-06	lb/MMscf	2.67E-07	3.10E-07	4.34E-07	2.29E-07	2.66E-07	3.72E-07	4.96E-07	5.75E-07	8.05E-07
Indeno(1,2,3-cd)pyrene	Yes	2.14E-06	lb/Mgal	1.80E-06	lb/MMscf	1.28E-07	1.48E-07	2.08E-07	2.44E-07	2.83E-07	3.96E-07	3.72E-07	4.31E-07	6.03E-07
Phenanthrene	Yes	1.05E-05	lb/Mgal	1.70E-05	lb/MMscf	6.28E-07	7.28E-07	1.02E-06	2.30E-06	2.67E-06	3.74E-06	3.72E-06	4.31E-06	6.03E-06
Pyrene	Yes	4.25E-06	lb/Mgal	5.00E-06	lb/MMscf	2.54E-07	2.94E-07	4.12E-07	6.78E-07	7.86E-07	1.10E-06	9.32E-07	1.08E-06	1.51E-06
OCDD	No	3.10E-09	lb/Mgal	--	lb/MMscf	1.85E-10	2.15E-10	3.01E-10	--	--	--	1.85E-10	2.15E-10	3.01E-10
Antimony	Yes	5.25E-03	lb/Mgal	--	lb/MMscf	3.14E-04	3.64E-04	5.09E-04	--	--	--	3.14E-04	3.64E-04	5.09E-04
Arsenic	Yes	1.32E-03	lb/Mgal	2.00E-04	lb/MMscf	7.89E-05	9.15E-05	1.28E-04	2.71E-05	3.14E-05	4.40E-05	1.06E-04	1.23E-04	1.72E-04
Barium	No	2.57E-03	lb/Mgal	--	lb/MMscf	1.54E-04	1.78E-04	2.49E-04	--	--	--	1.54E-04	1.78E-04	2.49E-04
Beryllium	Yes	2.78E-05	lb/Mgal	1.20E-05	lb/MMscf	1.66E-06	1.93E-06	2.70E-06	1.63E-06	1.89E-06	2.64E-06	3.29E-06	3.81E-06	5.34E-06
Cadmium	Yes	3.98E-04	lb/Mgal	1.10E-03	lb/MMscf	2.38E-05	2.76E-05	3.86E-05	1.49E-04	1.73E-04	2.42E-04	1.73E-04	2.00E-04	2.81E-04
Chloride	No	3.47E-01	lb/Mgal	--	lb/MMscf	2.07E-02	2.40E-02	3.37E-02	--	--	--	2.07E-02	2.40E-02	3.37E-02
Chromium	Yes	8.45E-04	lb/Mgal	1.40E-03	lb/MMscf	5.05E-05	5.85E-05	8.20E-05	1.90E-04	2.20E-04	3.08E-04	2.40E-04	2.78E-04	3.90E-04
Chromium VI	Yes	2.48E-04	lb/Mgal	8.40E-05	lb/MMscf	1.48E-05	1.72E-05	2.41E-05	1.90E-04	2.20E-04	3.08E-04	2.40E-04	2.78E-04	3.90E-04
Cobalt	Yes	6.02E-03	lb/Mgal	--	lb/MMscf	3.60E-04	4.17E-04	5.84E-04	1.14E-05	1.32E-05	1.85E-05	1.48E-05	1.72E-05	2.41E-05
Copper	No	1.76E-03	lb/Mgal	--	lb/MMscf	1.05E-04	1.22E-04	1.71E-04	--	--	--	1.05E-04	1.22E-04	1.71E-04
Fluoride	No	3.73E-02	lb/Mgal	--	lb/MMscf	2.23E-03	2.58E-03	3.62E-03	--	--	--	2.23E-03	2.58E-03	3.62E-03
Lead	Yes	1.51E-03	lb/Mgal	--	lb/MMscf	9.03E-05	1.05E-04	1.46E-04	--	--	--	9.03E-05	1.05E-04	1.46E-04
Manganese	Yes	3.00E-03	lb/Mgal	3.80E-04	lb/MMscf	1.79E-04	2.08E-04	2.91E-04	5.15E-05	5.97E-05	8.36E-05	2.31E-04	2.68E-04	3.75E-04
Mercury	Yes	1.13E-04	lb/Mgal	2.60E-04	lb/MMscf	6.75E-06	7.83E-06	1.10E-05	3.52E-05	4.08E-05	5.72E-05	4.20E-05	4.87E-05	6.81E-05
Molybdenum	No	7.87E-04	lb/Mgal	--	lb/MMscf	4.70E-05	5.45E-05	7.63E-05	--	--	--	4.70E-05	5.45E-05	7.63E-05
Nickel	Yes	8.45E-02	lb/Mgal	2.10E-03	lb/MMscf	5.05E-03	5.85E-03	8.20E-03	2.85E-04	3.30E-04	4.62E-04	5.34E-03	6.18E-03	8.66E-03
Phosphorous	No	9.45E-03	lb/Mgal	--	lb/MMscf	5.65E-04	6.55E-04	9.17E-04	--	--	--	5.65E-04	6.55E-04	9.17E-04
Selenium	Yes	6.83E-04	lb/Mgal	2.40E-05	lb/MMscf	4.08E-05	4.73E-05	6.63E-05	3.25E-06	3.77E-06	5.28E-06	4.41E-05	5.11E-05	7.15E-05
Vanadium	Yes	3.18E-02	lb/Mgal	--	lb/MMscf	1.90E-03	2.20E-03	3.08E-03	--	--	--	1.90E-03	2.20E-03	3.08E-03
Zinc	Yes	2.91E-02	lb/Mgal	--	lb/MMscf	1.74E-03	2.02E-03	2.82E-03	--	--	--	1.74E-03	2.02E-03	2.82E-03
2-Methylnaphthalene	Yes	--	lb/Mgal	2.40E-05	lb/MMscf	--	--	--	3.25E-06	3.77E-06	5.28E-06	3.25E-06	3.77E-06	5.28E-06
3-Methylchloranthrene	Yes	--	lb/Mgal	1.80E-06	lb/MMscf	--	--	--	2.44E-07	2.83E-07	3.96E-07	2.44E-07	2.83E-07	3.96E-07
7,12-Dimethylbenz(a)anthracene	Yes	--	lb/Mgal	1.60E-05	lb/MMscf	--	--	--	2.17E-06	2.51E-06	3.52E-06	2.17E-06	2.51E-06	3.52E-06
Benzo(a)pyrene	Yes	--	lb/Mgal	1.20E-06	lb/MMscf	--	--	--	1.63E-07	1.89E-07	2.64E-07	1.63E-07	1.89E-07	2.64E-07
Dichlorobenzene	Yes	--	lb/Mgal	1.20E-03	lb/MMscf	--	--	--	1.63E-04	1.89E-04	2.64E-04	1.63E-04	1.89E-04	2.64E-04
Hexane	Yes	--	lb/Mgal	1.80E+00	lb/MMscf	--	--	--	2.44E-01	2.83E-01	3.96E-01	2.44E-01	2.83E-01	3.96E-01
Total HAP (tpy)														
Single Maximum HAP (tpy)												0.27	0.31	0.44
												0.24	0.28	0.40

Notes:
 1. AP-42 Chapter 1.3, Table 1.3-9 and 1.3-11 for Fuel Oil Combustion
 2. AP-42 Chapter 1.4, Table 1.4-3 and 1.4-4 for Natural Gas Combustion.

Table B-4. Ancillary NG Unit HAP Emissions

Pollutant	HAP?	Emission Factors (Natural Gas) ¹		Natural Gas Emissions (tpy)
				Misc Equipment
Benzene	Yes	2.10E-03	lb/MMscf	7.30E-05
Ethylbenzene	Yes	--	lb/MMscf	-
Formaldehyde	Yes	7.50E-02	lb/MMscf	2.61E-03
Naphthalene	Yes	6.10E-04	lb/MMscf	2.12E-05
1,1,1-Trichloroethane	Yes	--	lb/MMscf	-
Toluene	Yes	3.40E-03	lb/MMscf	1.18E-04
o-Xylene	Yes	--	lb/MMscf	-
Acenaphthene	Yes	1.80E-06	lb/MMscf	6.26E-08
Acenaphthylene	Yes	1.80E-06	lb/MMscf	6.26E-08
Anthracene	Yes	2.40E-06	lb/MMscf	8.34E-08
Benz(a)anthracene	Yes	1.80E-06	lb/MMscf	6.26E-08
Benzo(b,k)fluoranthene	Yes	1.80E-06	lb/MMscf	6.26E-08
Benzo(g,h,i)perylene	Yes	2.48E-08	lb/MMscf	8.62E-10
Chrysene	Yes	1.80E-06	lb/MMscf	6.26E-08
Dibenzo(a,h)anthracene	Yes	--	lb/MMscf	-
Fluoranthene	Yes	3.61E-07	lb/MMscf	1.25E-08
Fluorocne	Yes	1.69E-06	lb/MMscf	5.87E-08
Indeno(1,2,3-cd)pyrene	Yes	1.80E-06	lb/MMscf	6.26E-08
Phenanthrene	Yes	1.70E-05	lb/MMscf	5.91E-07
Pyrene	Yes	5.00E-06	lb/MMscf	1.74E-07
OCDD	No	--	lb/MMscf	-
Antimony	Yes	--	lb/MMscf	-
Arsenic	Yes	2.00E-04	lb/MMscf	6.95E-06
Barium	No	--	lb/MMscf	-
Beryllium	Yes	1.20E-05	lb/MMscf	4.17E-07
Cadmium	Yes	1.10E-03	lb/MMscf	3.82E-05
Chloride	No	--	lb/MMscf	-
Chromium	Yes	1.40E-03	lb/MMscf	4.87E-05
Chromium VI	Yes	--	lb/MMscf	-
Cobalt	Yes	8.40E-05	lb/MMscf	2.92E-06
Copper	No	--	lb/MMscf	-
Fluoride	No	--	lb/MMscf	-
Lead	Yes	--	lb/MMscf	-
Manganese	Yes	3.80E-04	lb/MMscf	1.32E-05
Mercury	Yes	2.60E-04	lb/MMscf	9.04E-06
Molybdenum	No	--	lb/MMscf	-
Nickel	Yes	2.10E-03	lb/MMscf	7.30E-05
Phosphorous	No	--	lb/MMscf	-
Selenium	Yes	2.40E-05	lb/MMscf	8.34E-07
Vanadium	Yes	--	lb/MMscf	-
Zinc	Yes	--	lb/MMscf	-
2-Methylnaphthalene	Yes	2.40E-05	lb/MMscf	8.34E-07
3-Methylchloranthrene	Yes	1.80E-06	lb/MMscf	6.26E-08
7,12-Dimethylbenz(a)anthracene	Yes	1.60E-05	lb/MMscf	5.56E-07
Benzo(a)pyrene	Yes	1.20E-06	lb/MMscf	4.17E-08
Dichlorobenzene	Yes	1.20E-03	lb/MMscf	4.17E-05
Hexane	Yes	1.80E+00	lb/MMscf	6.26E-02
Total HAP (tpy)				6.56E-02
Single Maximum HAP (tpy)				6.26E-02

Notes:

1. AP-42 Chapter 1.4, Table 1.4-3 and 1.4-4 for Natural Gas Combustion.

Table B-5. Engines Criteria Pollutant Emissions

Equipment Info	Gen 1		Gen 2		Gen 3		Gen 4		Gen 5		Gen 6	
	Ref.	469 hp	Ref.	469 hp	Ref.	469 hp	Ref.	1340 hp	Ref.	1340 hp	Ref.	1340 hp
Engine Rating	1	500 hr/yr										
Maximum Hours of Operation ¹												
Emission Factors (Diesel Fuel)												
NO _x	Ref.	3.10E-02 lb/hp-hr	Ref.	3.10E-02 lb/hp-hr	Ref.	3.10E-02 lb/hp-hr	Ref.	2.40E-02 lb/hp-hr	Ref.	2.40E-02 lb/hp-hr	Ref.	2.40E-02 lb/hp-hr
CO	2	6.68E-03 lb/hp-hr	2	6.68E-03 lb/hp-hr	2	6.68E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr
VOC	2	2.51E-03 lb/hp-hr	2	2.51E-03 lb/hp-hr	2	2.51E-03 lb/hp-hr	7	2.02E-03 lb/hp-hr	7	2.02E-03 lb/hp-hr	7	2.02E-03 lb/hp-hr
PM ₁₀	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	8	1.70E-03 lb/hp-hr	8	1.70E-03 lb/hp-hr	8	1.70E-03 lb/hp-hr
PM _{2.5}	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	7	1.70E-03 lb/hp-hr	7	1.70E-03 lb/hp-hr	7	1.70E-03 lb/hp-hr
SO ₂	3	2.20E-03 lb/hp-hr										
CO ₂	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	3	2.05E-03 lb/hp-hr	3	2.05E-03 lb/hp-hr	3	2.05E-03 lb/hp-hr
CH ₄	2	1.15 lb/hp-hr	2	1.15 lb/hp-hr	2	1.15 lb/hp-hr	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr
N ₂ O	4	4.63E-05 lb/hp-hr	4	4.63E-05 lb/hp-hr	4	4.63E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr
CO ₂ e	5	9.26E-06 lb/hp-hr										
	6	1.15 lb/hp-hr	6	1.15 lb/hp-hr	6	1.15 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr
Potential Emissions												
NO _x	Gen 1	3.63 tpy	Gen 2	3.63 tpy	Gen 3	3.63 tpy	Gen 4	8.04 tpy	Gen 5	8.04 tpy	Gen 6	8.04 tpy
CO		0.78 tpy		0.78 tpy		0.78 tpy		1.84 tpy		1.84 tpy		1.84 tpy
VOC		0.29 tpy		0.29 tpy		0.29 tpy		0.21 tpy		0.21 tpy		0.21 tpy
PM ₁₀		0.26 tpy		0.26 tpy		0.26 tpy		0.23 tpy		0.23 tpy		0.23 tpy
PM _{2.5}		0.26 tpy		0.26 tpy		0.26 tpy		0.23 tpy		0.23 tpy		0.23 tpy
SO ₂		0.24 tpy		0.24 tpy		0.24 tpy		0.23 tpy		0.23 tpy		0.23 tpy
CO ₂		134.84 tpy		134.84 tpy		134.84 tpy		388.60 tpy		388.60 tpy		388.60 tpy
CO ₂ e		135.30 tpy		135.30 tpy		135.30 tpy		390.06 tpy		390.06 tpy		390.06 tpy

Notes:

1. Annual operational limitation conservatively assumed 500 hours of emergency operation.
2. AP-42 Chapter 3.3, Table 3.3-1 (10/96). VOC emission factor based on the sum of TOC from Exhaust and Crankcase.
3. PM₁₀ and PM_{2.5} conservatively assumed to equal total PM.
4. Methane emission factor based on 40 CFR Part 98, Table C-2 for diesel fuel (3.0E-3 kg/MMBtu CH₄ converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
5. N₂O emission factor based on 40 CFR Part 98, Table C-2 for diesel fuel (6.0E-04 kg/MMBtu N₂O converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
6. CO₂e potential emissions were calculated using the global warming potentials (GWP) for each GHG pollutant emitted from 40 CFR 98, Subpart A, Table A-1 (rule effective January 1, 2014):
CO₂ 1
CH₄ 25
N₂O 298
7. AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large stationary diesel engines (greater than 600 hp).
8. AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. VOC emission factor is calculated as the total organic carbon (TOC) emission factor multiplied by 91%. It is conservatively assumed that all non-methane TOC is VOC.
9. It is assumed that all SO₂ is SO₂. The SO₂ emission factor was calculated conservatively assuming a maximum allowable sulfur content per 40 CFR 60.4207(c).
10. AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. The CH₄ emission factor is calculated as the total organic carbon (TOC) emission factor multiplied by 9%. It is conservatively assumed that all non-methane TOC is VOC.
11. EPA Tier 4 emission standards for engines of size (75 ≤ hp < 175).

Renown
Mill Street - Reno, Nevada

Ref.	Gen 7 1340 hp 500 hr/yr	Ref.	Gen 8 2680 hp 500 hr/yr	Ref.	Gen 9 804 hp 500 hr/yr	Ref.	Gen 10 2680 hp 500 hr/yr	Ref.	Gen 11 2680 hp 500 hr/yr	Ref.	Gen 12 2680 hp 500 hr/yr
1		1		1		1		1		1	
7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr
7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr
8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr
7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr
2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr
3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr
2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr
2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr
10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr
5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr
6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr
	8.04 tpy		16.08 tpy		4.82 tpy		16.08 tpy		16.08 tpy		16.08 tpy
	1.84 tpy		3.69 tpy		1.11 tpy		3.69 tpy		3.69 tpy		3.69 tpy
	0.21 tpy		0.43 tpy		0.13 tpy		0.43 tpy		0.43 tpy		0.43 tpy
	0.23 tpy		0.47 tpy		0.14 tpy		0.47 tpy		0.47 tpy		0.47 tpy
	0.23 tpy		0.47 tpy		0.14 tpy		0.47 tpy		0.47 tpy		0.47 tpy
	0.00 tpy		0.01 tpy		0.00 tpy		0.01 tpy		0.01 tpy		0.01 tpy
	388.60 tpy		777.20 tpy		233.16 tpy		777.20 tpy		777.20 tpy		777.20 tpy
	390.06 tpy		780.11 tpy		234.03 tpy		780.11 tpy		780.11 tpy		780.11 tpy

Table B-6. HAP Emissions for Engines > 600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu) ¹	Emission Factor (lb/hp-hr) ²	Emissions (tpy)
Benzene	1	7.76E-04	5.43E-06	0.40
Toluene	1	2.81E-04	1.97E-06	0.15
Xylenes	1	1.93E-04	1.35E-06	0.10
Propylene	1	2.79E-03	1.95E-05	1.44
Formaldehyde	1	7.89E-05	5.52E-07	0.04
Acetaldehyde	1	2.52E-05	1.76E-07	0.01
Acrolein	1	7.88E-06	5.52E-08	0.01
Total PAH	1	2.12E-04	1.48E-06	4.08E-03 0.11

Notes:

1. Per U.S. EPA's AP-42, Section 3.4, Large Stationary Diesel and All Stationary Dual-Fuel Engines; Tables 3.4-3 and 3.4-4 (Oct. 1996) for diesel fuel combustion.
2. Converted from lb/MMBtu to lb/hp-hr using an average brake-specific fuel consumption (BSFC) value of 7,000 Btu/hp-hr, per AP-42 Table 3.4-1, footnote e.

Table B-7. HAP Emissions for Engines <600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu)	Emission Factor (lb/hp-hr)	Emissions (tpy)
Benzene	1	9.33E-04	6.53E-06	4.02E-02
Toluene	1	4.09E-04	2.86E-06	1.76E-02
Xylenes	1	2.85E-04	2.00E-06	1.23E-02
Propylene	1	2.58E-03	1.81E-05	1.11E-01
1,3-Butadiene	1	3.91E-05	2.74E-07	1.69E-03
Formaldehyde	1	1.18E-03	8.26E-06	5.09E-02
Acetaldehyde	1	7.67E-04	5.37E-06	3.31E-02
Acrolein	1	9.25E-05	6.48E-07	3.99E-03
Naphthalene	1	8.48E-05	5.94E-07	3.66E-03
Acenaphthylene	1	5.06E-06	3.54E-08	2.18E-04
Acenaphthene	1	1.42E-06	9.94E-09	6.13E-05
Fluorene	1	2.92E-05	2.04E-07	1.26E-03
Phenanthrene	1	2.94E-05	2.06E-07	1.27E-03
Anthracene	1	1.87E-06	1.31E-08	8.07E-05
Fluoranthene	1	7.61E-06	5.33E-08	3.28E-04
Pyrene	1	4.78E-06	3.35E-08	2.06E-04
Benzo(a)anthracene	1	1.68E-06	1.18E-08	7.25E-05
Chrysene	1	3.53E-07	2.47E-09	1.52E-05
Benzo(b)fluoranthene	1	9.91E-08	6.94E-10	4.28E-06
Benzo(k)fluoranthene	1	1.55E-07	1.09E-09	6.69E-06
Benzo(a)pyrene	1	1.88E-07	1.32E-09	8.11E-06
Indeno(1,2,3-cd)pyrene	1	3.75E-07	2.63E-09	1.62E-05
Dibenz(a,h)anthracene	1	5.83E-07	4.08E-09	2.51E-05
Benzo(e,h)perylene	1	4.89E-07	3.42E-09	2.11E-05

Notes:

1. HAP emission factors based on AP-42 Table 3.3-2 for organic compound emissions from diesel-fired engines. Emission factors converted from lb/MMBtu to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr.

This Page was Intentionally Left Blank

Table B-8 Proposed Boilers Criteria Pollutant Emissions

Boilers				
Equipment Info	1061-0-B-01	1061-0-B-02	1061-0-B-03	Misc Ancillary Equipment
Maximum Heat Input Rate	36,741 MMBtu/hr	36,741 MMBtu/hr	36,741 MMBtu/hr	8,0955 MMBtu/hr
Diesel Fuel Consumption	262,435,7143 Gal/hr	262,435,7143 Gal/hr	262,435,7143 Gal/hr	0 Gal/hr
Maximum Hours of Operation	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr
Hours of Operation on NG	8,260 hr/yr	8,260 hr/yr	8,260 hr/yr	8,760 hr/yr
Hours of Operation on Diesel	500 hr/yr	500 hr/yr	500 hr/yr	0 hr/yr

Emission Factors (Natural Gas) ¹				
	1061-0-B-01	1061-0-B-02	1061-0-B-03	Misc Ancillary Equipment
NO _x	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf
CO	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf
VOC	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf
PM	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM ₁₀ ²	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM _{2.5} ²	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
SO ₂	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf
CO ₂	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf
N ₂ O	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf
CH ₄	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf
CO _{2e} ³	120,713 lb/MMscf	120,713 lb/MMscf	120,713 lb/MMscf	120,713 lb/MMscf

Emission Factors (Diesel) ⁴				
	1061-0-B-01	1061-0-B-02	1061-0-B-03	Misc Ancillary Equipment
NO _x	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal
CO	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal
VOC	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal
PM	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal
PM ₁₀ ²	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal
PM _{2.5} ²	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal
SO ₂	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal
CO ₂	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal
N ₂ O	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal
CH ₄	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal
CO _{2e} ³	22,409 lb/1000 gal	22,409 lb/1000 gal	22,409 lb/1000 gal	22,409 lb/1000 gal

Potential Emissions ⁵				
	1061-0-B-01	1061-0-B-02	1061-0-B-03	Misc Ancillary Equipment
NO _x	16.19 tpy	16.19 tpy	16.19 tpy	3.48 tpy
CO	12.82 tpy	12.82 tpy	12.82 tpy	2.92 tpy
VOC	0.84 tpy	0.84 tpy	0.84 tpy	0.19 tpy
PM	1.26 tpy	1.26 tpy	1.26 tpy	0.26 tpy
PM ₁₀ ²	1.20 tpy	1.20 tpy	1.20 tpy	0.26 tpy
PM _{2.5} ²	1.19 tpy	1.19 tpy	1.19 tpy	0.26 tpy
SO ₂	9.41 tpy	9.41 tpy	9.41 tpy	0.02 tpy
CO ₂	19,314.88 tpy	19,314.88 tpy	19,314.88 tpy	4,171.56 tpy
N ₂ O	0.34 tpy	0.34 tpy	0.34 tpy	0.08 tpy
CH ₄	0.42 tpy	0.42 tpy	0.42 tpy	0.08 tpy
CO _{2e} ³	19,428.12 tpy	19,428.12 tpy	19,428.12 tpy	4,196.35 tpy

Notes:

- AP-42 Chapter 1.4, Table 1.4-1 and Table 1.4-2. Uncontrolled emission factor for NG assumed for U201 and Low NG burner emission factor for NG assumed for U202.
- PM₁₀ and PM_{2.5} conservatively assumed to be equal to total PM emissions.
- GWFs: CO₂ = 1, N₂O = 290, CH₄ = 25, per 40 CFR 90 Subpart A (rule effective January 1, 2014).
- AP-42 Chapter 1.3 Table 1.3-1 (CO, SO₂, NO_x, and PM), Table 1.3-3 (VOC), Table 1.3-8 (N₂O), and Table 1.3-12 (CO₂); assumes Gridfiled emission factors are equal to No. 6 Fuel emission factors.
- Annual emissions per pollutant based on maximum of natural gas combustion and diesel combustion.

Table B-11. Ancillary NG Unit HAP Emissions

Pollutant	HAP?	Emission Factors (Natural Gas) ¹		Natural Gas Emissions (tpy)
				Misc Equipment
Benzene	Yes	2.10E-03	lb/MMscf	7.30E-05
Ethylbenzene	Yes	--	lb/MMscf	-
Formaldehyde	Yes	7.50E-02	lb/MMscf	2.61E-03
Naphthalene	Yes	6.10E-04	lb/MMscf	2.12E-05
1,1,1-Trichloroethane	Yes	--	lb/MMscf	-
Toluene	Yes	3.40E-03	lb/MMscf	1.18E-04
o-Xylene	Yes	--	lb/MMscf	-
Acenaphthene	Yes	1.80E-06	lb/MMscf	6.26E-08
Acenaphthylene	Yes	1.80E-06	lb/MMscf	6.26E-08
Anthracene	Yes	2.40E-06	lb/MMscf	8.34E-08
Benz(a)anthracene	Yes	1.80E-06	lb/MMscf	6.26E-08
Benzo(b,k)fluoranthene	Yes	1.80E-06	lb/MMscf	6.26E-08
Benzo(g,h,i)perylene	Yes	2.48E-08	lb/MMscf	8.62E-10
Chrysene	Yes	1.80E-06	lb/MMscf	6.26E-08
Dibenzo(a,h)anthracene	Yes	--	lb/MMscf	-
Fluoranthene	Yes	3.61E-07	lb/MMscf	1.25E-08
Fluorene	Yes	1.69E-06	lb/MMscf	5.87E-08
Indeno(1,2,3-cd)pyrene	Yes	1.80E-06	lb/MMscf	6.26E-08
Phenanthrene	Yes	1.70E-05	lb/MMscf	5.91E-07
Pyrene	Yes	5.00E-06	lb/MMscf	1.74E-07
OCDD	No	--	lb/MMscf	-
Antimony	Yes	--	lb/MMscf	-
Arsenic	Yes	2.00E-04	lb/MMscf	6.95E-06
Barium	No	--	lb/MMscf	-
Beryllium	Yes	1.20E-05	lb/MMscf	4.17E-07
Cadmium	Yes	1.10E-03	lb/MMscf	3.82E-05
Chloride	No	--	lb/MMscf	-
Chromium	Yes	1.40E-03	lb/MMscf	4.87E-05
Chromium VI	Yes	--	lb/MMscf	-
Cobalt	Yes	8.40E-05	lb/MMscf	2.92E-06
Copper	No	--	lb/MMscf	-
Fluoride	No	--	lb/MMscf	-
Lead	Yes	--	lb/MMscf	-
Manganese	Yes	3.80E-04	lb/MMscf	1.32E-05
Mercury	Yes	2.60E-04	lb/MMscf	9.04E-06
Molybdenum	No	--	lb/MMscf	-
Nickel	Yes	2.10E-03	lb/MMscf	7.30E-05
Phosphorous	No	--	lb/MMscf	-
Selenium	Yes	2.40E-05	lb/MMscf	8.34E-07
Vanadium	Yes	--	lb/MMscf	-
Zinc	Yes	2.40E-05	lb/MMscf	8.34E-07
2-Methylnaphthalene	Yes	1.80E-06	lb/MMscf	6.26E-08
3-Methylchloranthrene	Yes	1.60E-05	lb/MMscf	5.56E-07
7,12-Dimethylbenz(a)anthracene	Yes	1.20E-06	lb/MMscf	4.17E-08
Benzo(a)pyrene	Yes	1.20E-03	lb/MMscf	4.17E-05
Dichlorobenzene	Yes	1.80E+00	lb/MMscf	6.26E-02
Hexane	Yes			
Total HAP (tpy)				6.56E-02
Single Maximum HAP (tpy)				6.26E-02

Notes:

1. AP-42 Chapter 1.4, Table 1.4-3 and 1.4-4 for Natural Gas Combustion.

Table B-9. Proposed Boilers HAP Emissions

Pollutant	HAP?	Emission Factors (Diesel) ¹		Emission Factors (Natural Gas) ²		Diesel Emissions (tpy)			Natural Gas Emissions (tpy)			Combined HAP Emissions (tpy)		
						1061-0-B-01	1061-0-B-02	1061-0-B-03	1061-0-D-01	1061-0-B-02	1061-0-B-03	1061-0-B-01	1061-0-B-02	1061-0-B-03
Benzene	Yes	2.14E-04	lb/Mgal	2.10E-03	lb/MMscf	1.40E-05	1.40E-05	1.40E-05	3.12E-04	3.12E-04	3.12E-04	3.26E-04	3.26E-04	3.26E-04
Ethylbenzene	Yes	6.36E-05	lb/Mgal	--	lb/MMscf	4.17E-06	4.17E-06	4.17E-06	--	--	--	4.17E-06	4.17E-06	4.17E-06
Formaldehyde	Yes	3.30E-02	lb/Mgal	--	lb/MMscf	2.17E-03	2.17E-03	2.17E-03	--	--	--	2.17E-03	2.17E-03	2.17E-03
Naphthalene	Yes	1.13E-03	lb/Mgal	7.50E-02	lb/MMscf	7.41E-05	7.41E-05	7.41E-05	1.12E-02	1.12E-02	1.12E-02	4.17E-06	4.17E-06	4.17E-06
1,1,1-Trichloroethane	Yes	2.36E-04	lb/Mgal	6.10E-04	lb/MMscf	1.55E-05	1.55E-05	1.55E-05	9.07E-05	9.07E-05	9.07E-05	1.33E-02	1.33E-02	1.33E-02
Toluene	Yes	6.20E-03	lb/Mgal	3.40E-03	lb/MMscf	4.07E-04	4.07E-04	4.07E-04	--	--	--	1.65E-04	1.65E-04	1.65E-04
o-Xylene	Yes	1.09E-04	lb/Mgal	--	lb/MMscf	7.15E-06	7.15E-06	7.15E-06	5.06E-04	5.06E-04	5.06E-04	1.55E-05	1.55E-05	1.55E-05
Acenaphthene	Yes	2.11E-05	lb/Mgal	1.80E-06	lb/MMscf	1.38E-06	1.38E-06	1.38E-06	--	--	--	1.55E-05	1.55E-05	1.55E-05
Acenaphthylene	Yes	2.53E-07	lb/Mgal	1.80E-06	lb/MMscf	1.38E-06	1.38E-06	1.38E-06	--	--	--	1.55E-05	1.55E-05	1.55E-05
Anthracene	Yes	4.01E-06	lb/Mgal	2.40E-06	lb/MMscf	8.00E-08	8.00E-08	8.00E-08	2.68E-07	2.68E-07	2.68E-07	9.13E-04	9.13E-04	9.13E-04
Benzo(a)anthracene	Yes	1.48E-06	lb/Mgal	1.80E-06	lb/MMscf	2.63E-07	2.63E-07	2.63E-07	2.68E-07	2.68E-07	2.68E-07	7.15E-06	7.15E-06	7.15E-06
Benzo(b)fluoranthene	Yes	2.26E-06	lb/Mgal	2.49E-08	lb/MMscf	1.48E-07	1.48E-07	1.48E-07	2.68E-07	2.68E-07	2.68E-07	1.65E-06	1.65E-06	1.65E-06
Benzo(k)fluoranthene	Yes	2.38E-06	lb/Mgal	1.80E-06	lb/MMscf	1.56E-07	1.56E-07	1.56E-07	2.68E-07	2.68E-07	2.68E-07	1.65E-06	1.65E-06	1.65E-06
Chrysene	Yes	1.67E-06	lb/Mgal	--	lb/MMscf	1.10E-07	1.10E-07	1.10E-07	2.68E-07	2.68E-07	2.68E-07	1.52E-07	1.52E-07	1.52E-07
Dibenz(a,h)anthracene	Yes	4.84E-06	lb/Mgal	3.61E-07	lb/MMscf	3.18E-07	3.18E-07	3.18E-07	2.68E-07	2.68E-07	2.68E-07	4.24E-07	4.24E-07	4.24E-07
Fluorene	Yes	4.47E-06	lb/Mgal	1.69E-06	lb/MMscf	2.93E-07	2.93E-07	2.93E-07	5.37E-08	5.37E-08	5.37E-08	1.10E-07	1.10E-07	1.10E-07
Indeno(1,2,3-cd)pyrene	Yes	2.14E-06	lb/Mgal	1.70E-05	lb/MMscf	1.40E-07	1.40E-07	1.40E-07	2.51E-07	2.51E-07	2.51E-07	3.71E-07	3.71E-07	3.71E-07
Phenanthrene	Yes	1.05E-05	lb/Mgal	1.80E-06	lb/MMscf	6.89E-07	6.89E-07	6.89E-07	2.68E-07	2.68E-07	2.68E-07	5.45E-07	5.45E-07	5.45E-07
Pyrene	Yes	4.25E-06	lb/Mgal	5.00E-06	lb/MMscf	2.79E-07	2.79E-07	2.79E-07	2.53E-06	2.53E-06	2.53E-06	4.08E-07	4.08E-07	4.08E-07
OCDD	No	3.10E-09	lb/Mgal	--	lb/MMscf	2.03E-10	2.03E-10	2.03E-10	7.44E-07	7.44E-07	7.44E-07	3.22E-06	3.22E-06	3.22E-06
Antimony	Yes	1.32E-03	lb/Mgal	--	lb/MMscf	3.44E-04	3.44E-04	3.44E-04	--	--	--	1.02E-06	1.02E-06	1.02E-06
Arsenic	Yes	5.25E-03	lb/Mgal	--	lb/MMscf	8.66E-05	8.66E-05	8.66E-05	--	--	--	2.03E-10	2.03E-10	2.03E-10
Barium	Yes	2.57E-03	lb/Mgal	2.00E-04	lb/MMscf	1.69E-04	1.69E-04	1.69E-04	2.98E-05	2.98E-05	2.98E-05	3.44E-04	3.44E-04	3.44E-04
Beryllium	No	2.70E-05	lb/Mgal	--	lb/MMscf	1.82E-06	1.82E-06	1.82E-06	--	--	--	1.16E-04	1.16E-04	1.16E-04
Cadmium	Yes	3.98E-04	lb/Mgal	1.20E-05	lb/MMscf	1.82E-06	1.82E-06	1.82E-06	1.79E-06	1.79E-06	1.79E-06	1.69E-04	1.69E-04	1.69E-04
Chloride	No	3.47E-01	lb/Mgal	1.10E-03	lb/MMscf	2.61E-05	2.61E-05	2.61E-05	1.64E-04	1.64E-04	1.64E-04	3.61E-06	3.61E-06	3.61E-06
Chromium	Yes	8.45E-04	lb/Mgal	--	lb/MMscf	2.28E-02	2.28E-02	2.28E-02	1.64E-04	1.64E-04	1.64E-04	1.90E-04	1.90E-04	1.90E-04
Chromium VI	Yes	2.48E-04	lb/Mgal	1.40E-03	lb/MMscf	5.54E-05	5.54E-05	5.54E-05	2.08E-04	2.08E-04	2.08E-04	2.28E-02	2.28E-02	2.28E-02
Cobalt	Yes	6.02E-03	lb/Mgal	8.40E-05	lb/MMscf	3.95E-04	3.95E-04	3.95E-04	2.08E-04	2.08E-04	2.08E-04	2.64E-04	2.64E-04	2.64E-04
Copper	Yes	1.76E-03	lb/Mgal	--	lb/MMscf	1.15E-04	1.15E-04	1.15E-04	1.25E-05	1.25E-05	1.25E-05	1.63E-05	1.63E-05	1.63E-05
Fluoride	No	3.73E-02	lb/Mgal	--	lb/MMscf	2.45E-03	2.45E-03	2.45E-03	--	--	--	4.07E-04	4.07E-04	4.07E-04
Lead	Yes	1.51E-03	lb/Mgal	--	lb/MMscf	9.91E-05	9.91E-05	9.91E-05	--	--	--	1.15E-04	1.15E-04	1.15E-04
Manganese	Yes	3.00E-03	lb/Mgal	--	lb/MMscf	9.91E-05	9.91E-05	9.91E-05	5.65E-05	5.65E-05	5.65E-05	2.45E-03	2.45E-03	2.45E-03
Mercury	Yes	1.13E-04	lb/Mgal	3.80E-04	lb/MMscf	1.97E-04	1.97E-04	1.97E-04	3.87E-05	3.87E-05	3.87E-05	9.91E-05	9.91E-05	9.91E-05
Molybdenum	No	7.87E-04	lb/Mgal	2.60E-04	lb/MMscf	7.41E-06	7.41E-06	7.41E-06	5.65E-05	5.65E-05	5.65E-05	2.53E-04	2.53E-04	2.53E-04
Nickel	Yes	8.45E-02	lb/Mgal	2.10E-03	lb/MMscf	5.16E-05	5.16E-05	5.16E-05	3.87E-05	3.87E-05	3.87E-05	4.61E-05	4.61E-05	4.61E-05
Phosphorous	Yes	9.46E-03	lb/Mgal	--	lb/MMscf	5.54E-03	5.54E-03	5.54E-03	--	--	--	5.66E-03	5.66E-03	5.66E-03
Selenium	No	6.93E-04	lb/Mgal	2.40E-05	lb/MMscf	6.21E-04	6.21E-04	6.21E-04	3.12E-04	3.12E-04	3.12E-04	5.16E-05	5.16E-05	5.16E-05
Vanadium	Yes	3.19E-04	lb/Mgal	--	lb/MMscf	4.48E-05	4.48E-05	4.48E-05	3.57E-06	3.57E-06	3.57E-06	6.21E-04	6.21E-04	6.21E-04
Zinc	Yes	2.91E-02	lb/Mgal	--	lb/MMscf	1.91E-03	1.91E-03	1.91E-03	--	--	--	2.09E-03	2.09E-03	2.09E-03
2-Methylnaphthalene	Yes	--	lb/Mgal	2.40E-05	lb/MMscf	--	--	--	3.57E-06	3.57E-06	3.57E-06	1.91E-03	1.91E-03	1.91E-03
3-Methylfluoranthene	Yes	--	lb/Mgal	1.80E-06	lb/MMscf	--	--	--	2.68E-07	2.68E-07	2.68E-07	2.09E-03	2.09E-03	2.09E-03
7,12-Dimethylbenz(a)anthracene	Yes	--	lb/Mgal	1.60E-05	lb/MMscf	--	--	--	2.38E-06	2.38E-06	2.38E-06	2.68E-07	2.68E-07	2.68E-07
Benzo(a)pyrene	Yes	--	lb/Mgal	1.20E-06	lb/MMscf	--	--	--	1.79E-07	1.79E-07	1.79E-07	2.38E-06	2.38E-06	2.38E-06
Dichlorobenzene	Yes	--	lb/Mgal	1.20E-03	lb/MMscf	--	--	--	1.79E-04	1.79E-04	1.79E-04	1.79E-04	1.79E-04	1.79E-04
Hexane	Yes	--	lb/Mgal	1.80E+00	lb/MMscf	--	--	--	2.68E-01	2.68E-01	2.68E-01	2.68E-01	2.68E-01	2.68E-01
Total HAP (tpy)												0.29	0.29	0.29
Single Maximum HAP (tpy)												0.27	0.27	0.27

Notes:
1. AP-42 Chapter 1.3, Table 1.3-9 and 1.3-11 for Distillate Fuel Oil Combustion
2. AP-42 Chapter 1.4, Table 1.4-3 and 1.4-4 for Natural Gas Combustion.

Table B-10. Proposed and Existing Engines Criteria Pollutant Emissions

Equipment Info	Ref.	Gen 1		Gen 2		Gen 3		Existing Gen 1		Existing Gen 2		Existing Gen 3		Existing Gen 4	
		2680 hp	500 hr/yr	2680 hp	500 hr/yr	2680 hp	500 hr/yr	2680 hp	500 hr/yr						
Engine Rating															
Maximum Hours of Operation ¹	1	500 hr/yr	500 hr/yr	500 hr/yr	500 hr/yr	500 hr/yr	500 hr/yr	500 hr/yr	500 hr/yr						
Emission Factors (Diesel Fuel)															
NO _x	7	1.01E-02 lb/hp-hr	7	1.01E-02 lb/hp-hr	7	1.01E-02 lb/hp-hr	7	1.01E-02 lb/hp-hr	8	2.40E-02 lb/hp-hr	8	2.40E-02 lb/hp-hr	8	2.40E-02 lb/hp-hr	8
CO	7	5.95E-04 lb/hp-hr	7	5.95E-04 lb/hp-hr	7	5.95E-04 lb/hp-hr	7	5.95E-04 lb/hp-hr	8	5.50E-03 lb/hp-hr	8	5.50E-03 lb/hp-hr	8	5.50E-03 lb/hp-hr	8
VOC	7	2.64E-05 lb/hp-hr	7	2.64E-05 lb/hp-hr	7	2.64E-05 lb/hp-hr	7	2.64E-05 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8
PM	7	6.61E-05 lb/hp-hr	7	6.61E-05 lb/hp-hr	7	6.61E-05 lb/hp-hr	7	6.61E-05 lb/hp-hr	8	7.00E-04 lb/hp-hr	8	7.00E-04 lb/hp-hr	8	7.00E-04 lb/hp-hr	8
PM ₁₀	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2
PM _{2.5}	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	3	6.61E-05 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	2
SO ₂	9	1.21E-05 lb/hp-hr	9	1.21E-05 lb/hp-hr	9	1.21E-05 lb/hp-hr	9	1.21E-05 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3
CH ₄	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2	1.21E-05 lb/hp-hr	2
N ₂ O	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	2
CO ₂ e	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10
CO ₂ e	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5	9.26E-06 lb/hp-hr	5
Potential Emissions															
NO _x		6.75 tpy		6.75 tpy		6.75 tpy		6.75 tpy	16.08 tpy	16.08 tpy	16.08 tpy	16.08 tpy	16.08 tpy	16.08 tpy	16.08 tpy
CO		0.40 tpy		0.40 tpy		0.40 tpy		0.40 tpy	3.69 tpy	3.69 tpy	3.69 tpy	3.69 tpy	3.69 tpy	3.69 tpy	3.69 tpy
VOC		0.18 tpy		0.18 tpy		0.18 tpy		0.18 tpy	0.43 tpy	0.43 tpy	0.43 tpy	0.43 tpy	0.43 tpy	0.43 tpy	0.43 tpy
PM		0.04 tpy		0.04 tpy		0.04 tpy		0.04 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy
PM ₁₀		0.04 tpy		0.04 tpy		0.04 tpy		0.04 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy
PM _{2.5}		0.01 tpy		0.01 tpy		0.01 tpy		0.01 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy	0.47 tpy
SO ₂		777.20 tpy		777.20 tpy		777.20 tpy		777.20 tpy	0.01 tpy	0.01 tpy	0.01 tpy	0.01 tpy	0.01 tpy	0.01 tpy	0.01 tpy
CO ₂ e		780.11 tpy		780.11 tpy		780.11 tpy		780.11 tpy	777.20 tpy	777.20 tpy	777.20 tpy	777.20 tpy	777.20 tpy	777.20 tpy	777.20 tpy

Notes:

- Annual operational limitation conservatively assumed 500 hours of emergency operation.
- AP-42 Chapter 3.3, Table 3.3-1 (10/96), VOC emission factor based on the sum of TOC from Exhaust and Crankcase.
- PM₁₀ and PM_{2.5} conservatively assumed to equal total PM.
- Methane emission factor based on 40 CFR Part 99, Table C-2 for diesel fuel (3.0E-3 kg/MMBtu CH₄ converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
- N₂O emission factor based on 40 CFR Part 99, Table C-2 for diesel fuel (6.0E-04 kg/MMBtu N₂O converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
- CO₂e potential emissions were calculated using the global warming potentials (GWP) for each CRIC pollutant emitted from 40 CFR 99, Subpart A, Table A-1 (rule effective January 1, 2014):
CO₂ 1
CH₄ 25
N₂O 298
- Based on Manufacturer Specifications
- AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. VOC emission factor is calculated as the total organic carbon (TOC) emission factor multiplied by 91%, per footnote f of AP-42 Table 3.4-1. It is conservatively assumed that all non-methane TOC is VOC.
- It is assumed that all SO₂ is SO₂. The SO₂ emission factor was calculated conservatively assuming a maximum diesel sulfur content of 15 ppm, the maximum allowable sulfur content per 40 CFR 60.4207(g).
- AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. The CH₄ emission factor is calculated as the total organic carbon (TOC) emission factor multiplied by 9%, per footnote f of AP-42 Table 3.4-1.
- EPA Tier 4 emission standards for engines of size (75 < hp < 175).

Table B-5. HAP Emissions for Engines > 600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu) ¹ (lb/hp-hr) ²	Emissions (tpy)
Benzene	1	7.76E-04	5.43E-06
Toluene	1	2.81E-04	1.97E-06
Xylenes	1	1.93E-04	1.35E-06
Propylene	1	2.79E-03	1.95E-05
Formaldehyde	1	7.89E-05	5.52E-07
Acetaldehyde	1	2.52E-05	1.76E-07
Acrolein	1	7.88E-06	5.52E-08
Total PAH	1	2.12E-04	1.48E-06

Notes:

1. Per U.S. EPA's AP-42, Section 3.4, Large Stationary Diesel and All Stationary Dual-fuel Engines, Tables 3.4-3 and 3.4-4 (Oct. 1995) for diesel fuel combustion.
2. Converted from lb/MMBtu to lb/hp-hr using an average brake-specific fuel consumption (BSFC) value of 7,000 Btu/hp-hr, per AP-42 Table 3.4-1, footnote c.

Table B-6. HAP Emissions for Engines <600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu)	Emission Factor (lb/hp-hr)	Emissions (tpy)
Benzene	1	9.33E-04	6.53E-06	1.55E-01
Toluene	1	4.09E-04	2.66E-06	6.72E-02
Xylenes	1	2.85E-04	2.00E-06	4.66E-02
Propylene	1	2.58E-03	1.81E-05	4.24E-01
1,3-Butadiene	1	3.91E-05	2.74E-07	6.43E-03
Formaldehyde	1	1.18E-03	8.26E-06	1.94E-01
Acetaldehyde	1	7.67E-04	5.37E-06	1.26E-01
Acrolein	1	9.25E-05	6.48E-07	1.52E-02
Aethylalene	1	8.46E-05	5.94E-07	1.39E-02
Acenaphthylene	1	5.06E-06	3.54E-08	8.32E-04
Acenaphthene	1	1.42E-06	9.94E-09	2.33E-04
Fluorene	1	2.92E-05	2.04E-07	4.80E-03
Phenanthrene	1	2.94E-05	2.06E-07	4.83E-03
Anthracene	1	1.87E-06	1.31E-08	3.07E-04
Pyrene	1	7.61E-06	5.33E-08	1.25E-03
Benzo(a)anthracene	1	4.76E-06	3.35E-08	7.86E-04
Chrysene	1	1.68E-06	1.18E-08	2.76E-04
Benzo(b)fluoranthene	1	3.53E-07	2.47E-09	5.80E-05
Benzo(k)fluoranthene	1	9.91E-08	6.94E-10	1.63E-05
Benzo(a)pyrene	1	1.55E-07	1.09E-09	2.55E-05
Indeno(1,2,3-cd)pyrene	1	1.88E-07	1.32E-09	3.09E-05
Dibenz(a,h)anthracene	1	3.75E-07	2.63E-09	6.16E-05
Benzo(e)perylene	1	5.63E-07	4.08E-09	9.58E-05
		4.89E-07	3.42E-09	8.04E-05

Notes:

1. HAP emission factors based on AP-42 Table 3.3-2 for organic compound emissions from diesel-fired engines. Emission factors converted from lb/MMBtu to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr.

Table B-12. CY2022 Actual Boilers Criteria Pollutant Emissions

Boilers				
Equipment Info	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
Actual Heat Input Rate	64204.46562 MMBtu/yr	74417.72266 MMBtu/yr	104184.8117 MMBtu/yr	8,0955 MMBtu/yr
Diesel Fuel Consumption	239.1071429 Gal/hr	277.1428571 Gal/hr	239.1071429 Gal/hr	0 Gal/hr
Maximum Hours of Operation	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr	8,760 hr/yr
Hours of Operation on NG	8,752 hr/yr	8,752 hr/yr	8,752 hr/yr	8,760 hr/yr
Hours of Operation on Diesel	8 hr/yr	8 hr/yr	8 hr/yr	0 hr/yr

Emission Factors (Natural Gas)	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf	100 lb/MMscf
CO	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf	84 lb/MMscf
VOC	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf	5.5 lb/MMscf
PM	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM ₁₀ ²	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
PM _{2.5} ²	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf	7.6 lb/MMscf
SO ₂	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf	0.6 lb/MMscf
CO ₂	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf	120,000 lb/MMscf
N ₂ O	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf	2.2 lb/MMscf
CH ₄	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf	2.3 lb/MMscf
CO _{2e} ³	120,740 lb/MMscf	120,740 lb/MMscf	120,740 lb/MMscf	120,740 lb/MMscf

Emission Factors (Diesel)	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal	20 lb/1000 gal
CO	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal	5 lb/1000 gal
VOC	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal	0.34 lb/1000 gal
PM	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal	2.00 lb/1000 gal
PM ₁₀ ²	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal	1.08 lb/1000 gal
PM _{2.5} ²	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal	0.83 lb/1000 gal
SO ₂	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal	142 lb/1000 gal
CO ₂	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal	22,300 lb/1000 gal
N ₂ O	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal	0.26 lb/1000 gal
CH ₄	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal	1.26 lb/1000 gal
CO _{2e} ³	22,682 lb/1000 gal	22,682 lb/1000 gal	22,682 lb/1000 gal	22,682 lb/1000 gal

Potential Emissions ⁵	Cleaver Brooks 1	Babcock & Wilcox 1	Cleaver Brooks 2	Misc Ancillary Equipment
NO _x	3.17 tpy	3.67 tpy	5.13 tpy	3.48 tpy
CO	2.65 tpy	3.07 tpy	4.29 tpy	2.92 tpy
VOC	0.17 tpy	0.20 tpy	0.28 tpy	0.19 tpy
PM	0.24 tpy	0.28 tpy	0.39 tpy	0.26 tpy
PM ₁₀ ²	0.24 tpy	0.28 tpy	0.39 tpy	0.26 tpy
PM _{2.5} ²	0.24 tpy	0.28 tpy	0.39 tpy	0.26 tpy
SO ₂	0.15 tpy	0.18 tpy	0.17 tpy	0.02 tpy
CO ₂	3,798.06 tpy	4,402.23 tpy	6,149.85 tpy	4,171.56 tpy
N ₂ O	0.07 tpy	0.08 tpy	0.12 tpy	0.08 tpy
CH ₄	0.07 tpy	0.09 tpy	0.11 tpy	0.08 tpy
CO _{2e} ³	3,821.73 tpy	4,429.67 tpy	6,188.02 tpy	4,197.30 tpy

- Notes:
1. AP-42 Chapter 1.4, Table 1.4-1 and Table 1.4-2. Uncontrolled emission factor for NO_x assumed for U201 and Low-NO_x burner emission factor for NO_x assumed for U202.
 2. PM₁₀ and PM_{2.5} conservatively assumed to be equal to total PM emissions.
 3. GWP: CO₂ = 1, N₂O = 298, CH₄ = 25, per 40 CFR 98 Subpart A (rule effective January 1, 2014).
 4. AP-42 Chapter 1.3 Table 1.3-1 (CO, SO₂, NO_x, and PM), Table 1.3-3 (VOC), Table 1.3-8 (SO) and Table 1.3-12 (CO); assumes Gridfield emission factors are equal to No. 6 Fuel emission factors.
 5. Annual emissions per pollutant based on maximum of natural gas combustion and diesel combustion.

Table B-13. CY2022 Actual Boilers HAP Emissions

Pollutant	HAP?	Emission Factors (Diesel) ¹		Emission Factors (Natural Gas) ²		Diesel Emissions (tpy)			Natural Gas Emissions (tpy)			Combined HAP Emissions (tpy)			
		HAP?	lb/Mgal	lb/Mgal	lb/MMscf	lb/MMscf	CB1	BW	CB2	CB1	BW	CB2	CB1	BW	CB2
Benzene	Yes	2.14E-04	lb/Mgal	2.10E-03	lb/MMscf	1.28E-05	1.49E-05	1.28E-05	6.61E-05	7.66E-05	1.07E-04	7.89E-05	9.14E-05	1.20E-04	
Ethylbenzene	Yes	6.36E-05	lb/Mgal	--	lb/MMscf	3.80E-06	4.41E-06	3.80E-06	--	--	--	3.80E-06	4.41E-06	3.80E-06	
Formaldehyde	Yes	3.30E-02	lb/Mgal	7.50E-02	lb/MMscf	1.97E-03	2.29E-03	1.97E-03	2.29E-03	2.23E-05	3.12E-05	4.33E-03	5.02E-03	5.80E-03	
Naphthalene	Yes	1.13E-03	lb/Mgal	6.10E-04	lb/MMscf	6.75E-05	7.83E-05	6.75E-05	1.92E-05	2.23E-05	3.12E-05	8.67E-05	1.01E-04	5.80E-03	
1,1,1-Trichloroethane	Yes	2.36E-04	lb/Mgal	--	lb/MMscf	1.41E-05	1.64E-05	1.41E-05	--	--	--	1.41E-05	1.64E-05	9.87E-05	
Toluene	Yes	6.20E-03	lb/Mgal	3.40E-03	lb/MMscf	3.71E-04	4.30E-04	3.71E-04	1.07E-04	1.24E-04	1.74E-04	4.78E-04	5.54E-04	1.41E-05	
o-Xylene	Yes	2.11E-05	lb/Mgal	--	lb/MMscf	6.52E-06	7.55E-06	6.52E-06	--	--	--	6.52E-06	7.55E-06	5.44E-04	
Acenaphthene	Yes	1.09E-04	lb/Mgal	--	lb/MMscf	1.26E-06	1.46E-06	1.26E-06	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Acenaphthylene	Yes	2.53E-07	lb/Mgal	1.80E-06	lb/MMscf	1.51E-08	1.75E-08	1.51E-08	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Anthracene	Yes	1.22E-06	lb/Mgal	1.80E-06	lb/MMscf	2.40E-07	2.79E-07	2.40E-07	7.55E-08	8.76E-08	1.23E-07	1.49E-07	1.72E-07	1.95E-07	
Benz(a)anthracene	Yes	4.01E-06	lb/Mgal	1.80E-06	lb/MMscf	7.29E-08	8.45E-08	7.29E-08	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Benzo(b,k)fluoranthene	Yes	1.48E-06	lb/Mgal	1.80E-06	lb/MMscf	2.40E-07	2.79E-07	2.40E-07	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Benzo(g,h,i)perylene	Yes	2.26E-06	lb/Mgal	1.80E-06	lb/MMscf	8.85E-08	1.03E-07	8.85E-08	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Chrysene	Yes	2.39E-06	lb/Mgal	2.48E-08	lb/MMscf	1.35E-07	1.57E-07	1.35E-07	7.81E-10	9.05E-10	1.27E-09	1.45E-07	1.68E-07	1.80E-07	
Dibenz(a,h)anthracene	Yes	1.67E-06	lb/Mgal	1.80E-06	lb/MMscf	1.42E-07	1.65E-07	1.42E-07	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Fluoranthene	Yes	4.84E-06	lb/Mgal	--	lb/MMscf	9.98E-08	1.16E-07	9.98E-08	--	--	--	9.98E-08	1.16E-07	1.36E-07	
Fluorene	Yes	4.47E-06	lb/Mgal	3.61E-07	lb/MMscf	2.89E-07	3.35E-07	2.89E-07	1.14E-08	1.32E-08	1.84E-08	1.99E-07	2.31E-07	2.34E-07	
Indeno(1,2,3-cd)pyrene	Yes	2.14E-06	lb/Mgal	1.69E-06	lb/MMscf	2.67E-07	3.10E-07	2.67E-07	5.32E-08	6.16E-08	8.63E-08	3.01E-07	3.49E-07	3.09E-07	
Phenanthrene	Yes	1.05E-05	lb/Mgal	1.80E-06	lb/MMscf	1.28E-07	1.48E-07	1.28E-07	5.67E-08	6.57E-08	9.19E-08	1.32E-06	1.53E-06	6.52E-06	
Pyrene	Yes	4.25E-06	lb/Mgal	1.70E-05	lb/MMscf	6.28E-07	7.28E-07	6.28E-07	5.35E-07	6.20E-07	8.68E-07	1.85E-07	2.14E-07	2.20E-07	
OCDD	No	3.10E-09	lb/Mgal	5.00E-06	lb/MMscf	1.85E-10	2.15E-10	1.85E-10	1.57E-07	1.82E-07	2.55E-07	1.16E-06	1.35E-06	1.50E-06	
Antimony	No	5.25E-03	lb/Mgal	--	lb/MMscf	3.14E-04	3.64E-04	3.14E-04	--	--	--	4.11E-07	4.77E-07	5.09E-07	
Arsenic	Yes	1.32E-03	lb/Mgal	2.00E-04	lb/MMscf	1.54E-04	1.78E-04	1.54E-04	6.29E-06	7.30E-06	1.02E-05	1.85E-10	2.15E-10	1.85E-10	
Barium	No	2.57E-03	lb/Mgal	--	lb/MMscf	7.99E-05	9.15E-05	7.99E-05	--	--	--	3.14E-04	3.64E-04	3.14E-04	
Beryllium	Yes	2.78E-05	lb/Mgal	1.20E-05	lb/MMscf	1.66E-06	1.93E-06	1.66E-06	3.78E-07	4.38E-07	6.13E-07	8.52E-05	9.88E-05	3.14E-04	
Cadmium	No	3.47E-01	lb/Mgal	1.10E-03	lb/MMscf	2.38E-05	2.76E-05	2.38E-05	3.46E-05	4.01E-05	5.62E-05	1.54E-04	1.78E-04	1.54E-04	
Chloride	Yes	3.98E-04	lb/Mgal	1.20E-05	lb/MMscf	1.66E-06	1.93E-06	1.66E-06	3.78E-07	4.38E-07	6.13E-07	2.04E-06	2.36E-06	2.27E-06	
Chromium	No	8.45E-04	lb/Mgal	1.40E-03	lb/MMscf	2.07E-02	2.40E-02	2.07E-02	4.01E-05	4.61E-05	6.46E-05	5.84E-05	6.77E-05	8.00E-05	
Chromium VI	Yes	2.48E-04	lb/Mgal	1.40E-03	lb/MMscf	5.05E-05	5.85E-05	5.05E-05	4.41E-05	5.11E-05	7.15E-05	2.07E-02	2.40E-02	2.07E-02	
Cobalt	Yes	6.02E-03	lb/Mgal	8.40E-05	lb/MMscf	1.48E-05	1.72E-05	1.48E-05	4.41E-05	5.11E-05	7.15E-05	9.46E-05	1.10E-04	1.22E-04	
Copper	No	1.76E-03	lb/Mgal	--	lb/MMscf	3.60E-04	4.17E-04	3.60E-04	2.64E-06	3.06E-06	4.29E-06	3.62E-04	1.72E-05	1.48E-05	
Fluoride	No	3.73E-02	lb/Mgal	--	lb/MMscf	1.05E-04	1.22E-04	1.05E-04	--	--	--	1.49E-05	1.72E-05	1.48E-05	
Lead	Yes	1.51E-03	lb/Mgal	--	lb/MMscf	2.23E-03	2.58E-03	2.23E-03	--	--	--	1.05E-04	1.22E-04	1.05E-04	
Manganese	Yes	3.00E-03	lb/Mgal	3.80E-04	lb/MMscf	9.03E-05	1.05E-04	9.03E-05	--	--	--	2.23E-03	2.58E-03	2.23E-03	
Mercury	Yes	1.13E-04	lb/Mgal	2.60E-04	lb/MMscf	1.79E-04	2.08E-04	1.79E-04	1.20E-05	1.39E-05	1.94E-05	9.03E-05	1.05E-04	9.03E-05	
Molybdenum	No	7.87E-04	lb/Mgal	--	lb/MMscf	6.75E-06	7.83E-06	6.75E-06	8.18E-06	9.48E-06	1.33E-05	1.91E-04	2.22E-04	1.99E-04	
Nickel	Yes	8.45E-02	lb/Mgal	2.10E-03	lb/MMscf	4.70E-05	5.45E-05	4.70E-05	6.61E-05	7.66E-05	1.07E-04	1.49E-05	1.73E-05	2.00E-05	
Phosphorous	No	9.45E-03	lb/Mgal	--	lb/MMscf	5.05E-03	5.85E-03	5.05E-03	--	--	--	4.70E-05	5.45E-05	4.70E-05	
Selenium	Yes	6.83E-04	lb/Mgal	2.40E-05	lb/MMscf	6.56E-04	7.56E-04	6.56E-04	6.61E-05	7.66E-05	1.07E-04	5.12E-03	5.93E-03	5.16E-03	
Vanadium	Yes	3.18E-02	lb/Mgal	--	lb/MMscf	4.08E-05	4.73E-05	4.08E-05	7.55E-07	8.76E-07	1.23E-06	4.16E-05	4.82E-05	5.65E-04	
Zinc	Yes	2.91E-02	lb/Mgal	--	lb/MMscf	1.90E-03	2.20E-03	1.90E-03	--	--	--	1.90E-03	2.20E-03	1.90E-03	
2-Methylnaphthalene	Yes	--	lb/Mgal	2.40E-05	lb/MMscf	--	--	--	7.55E-07	8.76E-07	1.23E-06	1.74E-03	2.02E-03	1.74E-03	
3-Methylchloranthrene	Yes	--	lb/Mgal	1.80E-06	lb/MMscf	--	--	--	5.67E-08	6.57E-08	9.19E-08	7.55E-07	8.76E-07	1.23E-06	
7,12-Dimethylbenz(a)anthracene	Yes	--	lb/Mgal	1.60E-05	lb/MMscf	--	--	--	5.04E-07	5.84E-07	8.17E-07	5.67E-08	6.57E-08	9.19E-08	
Benzo(a)pyrene	Yes	--	lb/Mgal	1.20E-06	lb/MMscf	--	--	--	3.78E-08	4.38E-08	6.13E-08	3.78E-08	4.38E-08	6.13E-08	
Dichlorobenzene	Yes	--	lb/Mgal	1.20E-03	lb/MMscf	--	--	--	3.78E-05	4.38E-05	6.13E-05	3.78E-05	4.38E-05	6.13E-05	
Hexane	Yes	--	lb/Mgal	1.80E+00	lb/MMscf	--	--	--	5.67E-02	6.57E-02	9.19E-02	5.67E-02	6.57E-02	9.19E-02	
Total HAP (tpy)												0.07	0.08	0.11	
Single Maximum HAP (tpy)												0.06	0.07	0.09	

Notes:
1. AP-42 Chapter 1.3, Table 1.3-9 and 1.3-11 for Fuel Oil Combustion
2. AP-42 Chapter 1.4, Table 1.4-3 and 1.4-4 for Natural Gas Combustion.

Table B-14. CY2022 Actual Engines Criteria Pollutant Emissions

Equipment Info Engine Rating Actual Hours of Operation ¹	Gen 1 469 hp 28 hr/yr		Gen 2 469 hp 28 hr/yr		Gen 3 469 hp 28 hr/yr		Gen 4 1340 hp 2 hr/yr		Gen 5 1340 hp 2 hr/yr		Gen 6 1340 hp 2 hr/yr		Gen 7 1340 hp 2 hr/yr	
	Ref.	Gen 1	Ref.	Gen 2	Ref.	Gen 3	Ref.	Gen 4	Ref.	Gen 5	Ref.	Gen 6	Ref.	Gen 7
NO _x	1	3.10E-02 lb/hp-hr	2	3.10E-02 lb/hp-hr	2	3.10E-02 lb/hp-hr	2	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr
CO	2	6.68E-03 lb/hp-hr	2	6.68E-03 lb/hp-hr	2	6.68E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr						
VOC	2	2.51E-03 lb/hp-hr	2	2.51E-03 lb/hp-hr	2	2.51E-03 lb/hp-hr	8	6.42E-04 lb/hp-hr						
PM ₁₀	2	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	7	7.00E-04 lb/hp-hr						
PM _{2.5}	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	3	2.20E-03 lb/hp-hr	3	7.00E-04 lb/hp-hr						
SO ₂	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	3	7.00E-04 lb/hp-hr						
CO ₂	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	2	2.05E-03 lb/hp-hr	9	1.21E-05 lb/hp-hr						
CH ₄	4	1.15 lb/hp-hr	2	1.15 lb/hp-hr	2	1.15 lb/hp-hr	7	1.16 lb/hp-hr						
N ₂ O	4	4.63E-05 lb/hp-hr	4	4.63E-05 lb/hp-hr	4	4.63E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr						
CO _{2e}	5	9.26E-06 lb/hp-hr												
	6	1.15 lb/hp-hr	6	1.15 lb/hp-hr	6	1.15 lb/hp-hr	6	1.16 lb/hp-hr						
Potential Emissions		Gen 1		Gen 2		Gen 3		Gen 4		Gen 5		Gen 6		Gen 7
NO _x		0.20 tpy		0.20 tpy		0.20 tpy		0.03 tpy		0.03 tpy		0.03 tpy		0.03 tpy
CO		0.04 tpy		0.04 tpy		0.04 tpy		0.01 tpy		0.01 tpy		0.01 tpy		0.01 tpy
VOC		0.02 tpy		0.02 tpy		0.02 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
PM		0.01 tpy		0.01 tpy		0.01 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
PM ₁₀		0.01 tpy		0.01 tpy		0.01 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
PM _{2.5}		0.01 tpy		0.01 tpy		0.01 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
SO ₂		0.01 tpy		0.01 tpy		0.01 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
CO ₂		7.55 tpy		7.55 tpy		7.55 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.00 tpy
CO _{2e}		7.58 tpy		7.58 tpy		7.58 tpy		1.55 tpy		1.55 tpy		1.55 tpy		1.55 tpy

Notes:

- Annual operation per 2022 Emission Inventory
- AP-42 Chapter 3.3, Table 3.3-1 (10/96). VOC emission factor based on the sum of TOC from Exhaust and Crankcase.
- PM₁₀ and PM_{2.5} conservatively assumed to equal total PM.
- Methane emission factor - see on 40 CFR Part 98, Table C-2 for diesel fuel (3.0E-3 kg/MMBtu CH₄ converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
- N₂O emission factor - see on 40 CFR Part 98, Table C-2 for diesel fuel (6.0E-04 kg/MMBtu N₂O converted to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr).
- CO_{2e} potential emissions were calculated using the global warming potentials (GWP) for each GHG pollutant emitted from 40 CFR 98, Subpart A, Table A-1 (rule effective January 1, 2014):
 CO₂: 1
 CH₄: 25
 N₂O: 298
- AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large stationary diesel engines (greater than 600 hp).
- AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. VOC emission factor is calculated as the total organic carbon (TOC) emission factor multiplied by 91%, per footnote c of AP-42 Table 3.4-1. It is conservatively assumed that all non-methane TOC is VOC.
- AP-42 Chapter 3.4, Table 3.4-1 (10/96) for large engines. The SO₂ emission factor was calculated conservatively assuming a maximum allowable sulfur content of 15 ppm, the maximum allowable sulfur content per 40 CFR 60.4207(g).
- EPA Tier 4 emission standards for engines of size (75 ≤ hp < 175).

Renown
 Mill Street - Reno, Nevada

Ref.	Gen 8 2680 hp 18 hr/yr	Ref.	Gen 9 804 hp 12 hr/yr	Ref.	Gen 10 2680 hp 12 hr/yr	Ref.	Gen 11 2680 hp 12 hr/yr	Ref.	Gen 12 2680 hp 12 hr/yr
1		1		1		1		1	
7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr	7	2.40E-02 lb/hp-hr
8	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr	7	5.50E-03 lb/hp-hr
7	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr	8	6.42E-04 lb/hp-hr
2	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr	7	7.00E-04 lb/hp-hr
3	7.00E-04 lb/hp-hr	2	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr	3	7.00E-04 lb/hp-hr
2	1.21E-05 lb/hp-hr	3	1.21E-05 lb/hp-hr	3	1.21E-05 lb/hp-hr	3	1.21E-05 lb/hp-hr	3	1.21E-05 lb/hp-hr
2	1.16 lb/hp-hr	2	1.16 lb/hp-hr	9	1.21E-05 lb/hp-hr	9	1.21E-05 lb/hp-hr	3	7.00E-04 lb/hp-hr
10	6.35E-05 lb/hp-hr	2	1.16 lb/hp-hr	7	1.16 lb/hp-hr	7	1.16 lb/hp-hr	9	1.21E-05 lb/hp-hr
5	9.26E-06 lb/hp-hr	5	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	10	6.35E-05 lb/hp-hr	2	1.16 lb/hp-hr
6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	6	1.16 lb/hp-hr	5	9.26E-06 lb/hp-hr	10	6.35E-05 lb/hp-hr
	0.58 tpy		0.12 tpy		0.39 tpy		0.39 tpy		0.39 tpy
	0.02 tpy		0.03 tpy		0.09 tpy		0.09 tpy		0.09 tpy
	0.02 tpy		0.00 tpy		0.01 tpy		0.01 tpy		0.01 tpy
	0.02 tpy		0.00 tpy		0.01 tpy		0.01 tpy		0.01 tpy
	0.02 tpy		0.00 tpy		0.01 tpy		0.01 tpy		0.01 tpy
	0.00 tpy		0.00 tpy		0.01 tpy		0.01 tpy		0.01 tpy
	27.98 tpy		0.00 tpy		0.00 tpy		0.00 tpy		0.01 tpy
	28.08 tpy		5.60 tpy		18.65 tpy		18.65 tpy		0.00 tpy
			5.62 tpy		18.72 tpy		18.72 tpy		18.65 tpy
									18.72 tpy

Table B-5. HAP Emissions for Engines > 600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu) ¹	Emissions (tpy)
Benzene	1	7.76E-04	5.43E-06
Toluene	1	2.81E-04	1.97E-06
Xylenes	1	1.93E-04	1.35E-06
Propylene	1	2.79E-03	1.95E-05
Formaldehyde	1	7.89E-05	5.52E-07
Acetaldehyde	1	2.52E-05	1.76E-07
Acrolein	1	7.88E-06	5.52E-08
Total PAH	1	2.12E-04	1.48E-06

Notes:
 1 - Per U.S. EPA's AP-42, Section 3.4, Large Stationary Diesel and All Stationary Dual-fuel Engines, Tables 3.4-3 and 3.4-4 (Oct. 1996) for diesel fuel combustion.
 2 - Converted from lb/MMBtu to lb/hp-hr using an average brake-specific fuel consumption (BSFC) value of 7,000 Btu/hp-hr, per AP-42 Table 3.4-1, footnote e.

Table B-6. HAP Emissions for Engines <600 hp

HAPs	Ref.	Emission Factor (lb/MMBtu)	Emission Factor (lb/hp-hr)	Emissions (tpy)
Benzene	1	9.33E-04	6.53E-06	4.02E-02
Toluene	1	4.09E-04	2.86E-06	1.76E-02
Xylenes	1	2.85E-04	2.00E-06	1.23E-02
Propylene	1	2.58E-03	1.81E-05	1.11E-01
1,3-Butadiene	1	3.91E-05	2.74E-07	1.69E-03
Formaldehyde	1	1.18E-03	8.26E-06	5.09E-02
Acetaldehyde	1	7.67E-04	5.37E-06	3.31E-02
Acrolein	1	9.25E-05	6.48E-07	3.99E-03
Naphthalene	1	8.48E-05	5.94E-07	3.66E-03
Acenaphthylene	1	5.06E-06	3.54E-08	2.18E-04
Acenaphthene	1	1.42E-06	9.94E-09	6.13E-05
Fluorene	1	2.92E-05	2.04E-07	1.26E-03
Phenanthrene	1	2.94E-05	2.06E-07	1.27E-03
Anthracene	1	1.87E-06	1.31E-08	8.07E-05
Fluoranthene	1	7.61E-06	5.33E-08	3.28E-04
Pyrene	1	4.78E-06	3.35E-08	2.06E-04
Benzo(a)anthracene	1	1.68E-06	1.18E-08	7.25E-05
Chrysene	1	3.53E-07	2.47E-09	1.52E-05
Benzo(b)fluoranthene	1	9.91E-08	6.94E-10	4.28E-06
Benzo(k)fluoranthene	1	1.55E-07	1.09E-09	6.69E-06
Benzo(e)pyrene	1	1.88E-07	1.32E-09	8.11E-06
Indeno(1,2,3-cd)pyrene	1	3.75E-07	2.63E-09	1.62E-05
Dibenz(a,h)anthracene	1	5.83E-07	4.08E-09	2.51E-05
Benzo(g,h,i)perylene	1	4.89E-07	3.42E-09	2.11E-05

Notes:
 1 - HAP emission factors based on AP-42 Table 3.3-2 for organic compound emissions from diesel-fired engines. Emission factors converted from lb/MMBtu to lb/hp-hr using a brake efficiency of 7,000 Btu/hp-hr.

This Page was Intentionally Left Blank

APPENDIX B. WCAQMD PERMIT APPLICATIONS FOR NEW EQUIPMENT

GENERAL APPLICATION FOR AN AIR QUALITY STATIONARY SOURCE PERMIT TO OPERATE

Return to: Washoe County Health District
Air Quality Management Division
1001 E. Ninth Street, Suite B171
Reno, Nevada 89512
(775) 784-7200

www.OurCleanAir.com

GENERAL INFORMATION FOR ALL AIR QUALITY PERMIT TO OPERATE APPLICATIONS

- Application must be filled out completely for all items that are applicable.
- Application must be signed by a responsible person.
- **For new facilities an additional Operating Permit Fee will be assessed after completion of the air quality emissions review which will be based on potential emissions calculated for the first year.**
- A Plan Review Fee must be submitted with this Application.

\$1,278 for Minor Stationary Sources;
\$3,796 for Synthetic Minor Stationary Sources

1. Legal Business Name (Name Permit will be issued under):

Renown Health

Street Address: Mill Street Campus, 1155 Mill Street
City: Reno State: NV Zip Code: 89502
Parcel: 012-150-24 Process Type: Fuel burning equipment (central utility plant, support facilities, etc.)
Onsite Contact: Chris Baker Title: Director of Facilities Engineering
Telephone: (775) 982-6188 E-Mail: cbaker2@renown.org

2. Mailing Address (if different than above):

Street Address: 245 Liberty Street
City: Reno State: NV Zip Code: 89501
Business Representative: Chris Baker Title: Director of Facilities Engineering
Telephone: (775) 982-6188 E-Mail: cbaker2@renown.org

3. Billing Address (if different than above):

Street Address: _____
City: _____ State: _____ Zip Code: _____
Representative: _____ Title: _____
Telephone: _____ E-Mail: _____

4. Attach a Description of Process (include: processing times, hours of operation, batches per year, size per batch, etc.):

Enclosed Not-Enclosed Not Applicable

5. Attach a Process Flow Diagram:

Enclosed Not-Enclosed Not Applicable

6. Attach an Equipment list (see sample excel spreadsheet):

Enclosed Not-Enclosed Not Applicable

7. Attach a List of Materials and Estimated Quantities to be used (see sample excel spreadsheet):

***** Attach ALL MSDS sheets for all materials *****

Enclosed Not-Enclosed Not Applicable

8. Attach a Description of Emissions Control Equipment (include: manufacturer, model, serial number, flow diagrams, emission units controlled, etc.):

Enclosed Not-Enclosed Not Applicable

Construction Start Date: 07/01/2022 Operations Start Date: 03/01/2025

NOTE: Applicant agrees to allow on-site inspection during and after construction by the Air Quality Management Division during working hours without prior notice. The operator must notify this office when the facility commences and completes construction. An official Permit to Operate will not be issued until a final inspection is made and all required test data has been forwarded to this office assuring that equipment will meet all district and state regulations.

This application is submitted in accordance with the provisions of Section 030.000, and under penalty of perjury, to the best of my knowledge the information supplied in this document is true and correct.



Responsible Party Signature

8/25/23

Date

Chris Baker

Director of Facilities Engineering

Print Name

Title

To be filled in by AQ Staff	
Permit No.:	BLD22-04198E
Date:	
Accepted By:	

**APPLICATION FOR AN INTERNAL COMBUSTION ENGINE AIR QUALITY
STATIONARY SOURCE PERMIT TO OPERATE**

Return to: Washoe County Health District
Air Quality Management Division
1001 E. Ninth Street B171
Reno, Nevada 89512
(775) 784-7200

www.OurCleanAir.com

GENERAL INFORMATION FOR ALL AIR QUALITY PERMIT TO OPERATE APPLICATIONS

- Application must be filled out completely for all items that are applicable.
- Application must be signed by a responsible person.
- **For new facilities an additional Operating Permit Fee will be assessed after completion of the air quality emissions review which will be based on potential emissions calculated for the first year.**
- A Plan Review Fee of **\$179** must be submitted with this Application

Legal Business Name (Name Permit will be issued under):

Renown Health

Street Address: 1155 Mill St

City: Reno State: Nevada Zip Code: 89502

Business Representative: Chris Baker Title:

Telephone: 775-400-8911 E-Mail: chris.baker@renown.org

1. Mailing Address (if different than above):

Street Address: 245 Liberty Street 4th Floor

City: Reno State: Nevada Zip Code: 89501

Business Representative: Chris Baker Title:

Telephone: 775-400-8911 E-Mail: chris.baker@renown.org

2. Billing Address (if different than above):

Street Address: _____

City: _____ State: _____ Zip Code: _____

Billing Representative: _____ Title: _____

Telephone: _____ E-Mail: _____

Construction Start Date: 07/01/2022 Operations Start Date: 03/01/2025

**WASHOE COUNTY
HEALTH DISTRICT**
ENHANCING QUALITY OF LIFE

Proposed Use of Engine: Emergency/Standby Continuous/Regular

Equipment Driven by Engine: Diesel Generator

Engine Make & Model & Size (kW or hp): Caterpillar 3516C 2000kW/2500kVA (Qty 3)

Date of Manufacture & Tier: EPA Stationary Emergency Tier 2

(Attach data sheet and EPA certificate)

Use of Air Pollution Control Apparatus: Yes No

Yes If Yes, please describe (manufacturer, model etc.): _____

Projected Maximum Operating Hours per Year: 50 ea

Typical Load to be operated (% of rated hp): 50

Type of Fuel used: Natural Gas Diesel #2 Gasoline

Sulfur Content of Fuel Oil (if applicable): 0.5997 g/BkW-hr

Amount of Fuel Consumed per year (gallons): 2,500 ea

Is this a mobile unit? Yes No

Has equipment been modified/reconstructed? If yes, when? No

Attach a list of All Internal Combustion Engines at Facility (see sample spreadsheet at www.OurCleanAir.com)

NOTE: Applicant agrees to allow on-site inspection during and after construction by the Air Quality Management Division during working hours without prior notice. The operator must notify this office when the facility commences and completes construction. An official Permit to Operate will not be issued until a final inspection is made and all required test data has been forwarded to this office assuring that equipment will meet all district and state regulations.

This application is submitted in accordance with the provisions of Section 030.000, and under penalty of perjury, to the best of my knowledge the information supplied in this document is true and correct.

Chris Baker

Digitally signed by Chris Baker
DN: C=US, E=cbaker@renown.org, CN=Chris Baker
Date: 2023.06.21 10:14:01-07'00'

Responsible Party Signature

Date

Chris Baker

Director of Facilities Engineering

Print Name

Title

Revised 04/2022 - KP

AIR QUALITY MANAGEMENT
1001 East Ninth Street | Reno, Nevada 89520
AQM Office: 775-784-7200 | Fax: 775-784-7225 | OurCleanAir.com
Serving Reno, Sparks and all of Washoe County, Nevada. Washoe County is an Equal Opportunity Employer.

APPLICATION FOR AN AIR QUALITY STATIONARY SOURCE PERMIT TO OPERATE – FUEL BURNING

Return to: Washoe County Health District
Air Quality Management Division
1001 East Ninth Street B171
Reno, Nevada 89512
(775) 784-7200

www.OurCleanAir.com

GENERAL INFORMATION FOR ALL AIR QUALITY PERMIT TO OPERATE APPLICATIONS

- Application must be filled out completely for all items that are applicable.
- Application must be signed by a responsible person.
- For new facilities an additional Operating Permit Fee will be assessed after completion of the air quality emissions review which will be based on potential emissions calculated for the first year.
- A Plan Review Fee of **\$179** must be submitted with this Application

Legal Business Name (Name Permit will be issued under):

Renown Health

Street Address: 1155 Mill St

City: Reno State: Nevada Zip Code: 89502

Onsite Contact: Chris Baker Title: _____

Telephone: 775-400-8911 E-Mail: chris.baker@renown.org

1. Mailing Address (if different than above):

Street Address: 245 Liberty Street 4th Floor

City: Reno State: Nevada Zip Code: 89501

Business Representative: Chris Baker Title: _____

Telephone: 775-400-8911 E-Mail: chris.baker@renown.org

2. Billing Address (if different than above):

Street Address: _____

City: _____ State: _____ Zip Code: _____

Representative: _____ Title: _____

Telephone: _____ E-Mail: _____

Construction Start Date: 7/1/2022 Operations Start Date: 3/1/2025

Type of Equipment (please attach list if more than one item): See attached

**WASHOE COUNTY
HEALTH DISTRICT**
ENHANCING QUALITY OF LIFE

Hours per Day 24 Days per Year 365

Max. Aggregate input BTU/hr: 148,013,600

Type of Fuel used: Natural Gas Fuel Oil Coal Wood

Type of Back-up Fuel used: Natural Gas Fuel Oil Coal Wood

Amount of Fuel Consumed per Year: 4,723 gals.

Sulfur Content if Oil or Coal is used: _____

Use of Air Pollution Control Apparatus: Yes No

If Yes, please describe (manufacturer, model etc.): _____

Attach List of All Fuel Burning Equipment at Facility (see sample excel spreadsheet at www.OurCleanAir.com):

Any Additional Information – please include attachments if necessary:

NOTE: Applicant agrees to allow on-site inspection during and after construction by the Air Quality Management Division during working hours without prior notice. The operator must notify this office when the facility commences and completes construction. An official Permit to Operate will not be issued until a final inspection is made and all required test data has been forwarded to this office assuring that equipment will meet all district and state regulations.

This application is submitted in accordance with the provisions of Section 030.000, and under penalty of perjury, to the best of my knowledge the information supplied in this document is true and correct.

<u>Chris Baker</u>	<small>Digitally signed by Chris Baker DN: C=US, E=cbaker@renown.org, CN=Chris Baker Date: 2023.06.22 13:08:34-0700'</small>
Responsible Party Signature	Date
<u>Chris Baker</u>	Director of Facilities Engineering
Print Name	Title

Revised 04/2022– KP

APPENDIX C. SUBMITTALS FOR NEW EQUIPMENT



**CLARK/SULLIVAN
construction**

Submittal Transmittal

Detailed, Grouped by Each Number

2115 - Renown Central Utility Plant (CUP)
1155 Mill Street
Reno, NV 89502

Project # 2115
Tel: 775-772-8820 Fax: Manny@clarksullivan.com

Date: 5/6/2022 **Reference Number:** 102

Transmitted To: Cory Griffin Perkins and Will Architect 2218 Bryan Street Suite 200 Dallas, TX 75201 Tel: 214-283-8743	Transmitted By: Alicia Lyttle Clark/Sullivan Construction 905 Industrial Way Sparks, NV 89431 Tel: 775.355.8500 Fax: 775.355.8063
--	---

Qty	Submittal Package No	Description	Due Date	Package Action
1	017 - 235239 - 01	RESUBMITTAL Firetube Boilers	5/20/2022	For Approval

Transmitted For	Delivered Via	Tracking Number
Approval	Email	

Items	Qty	Description	Notes	Item Action
001	1	235239 - Firetube Boilers - Product Data		
002	1	235239 - Firetube Boilers - Shop Drawings		

Cc: Company Name	Contact Name	Copies	Notes
------------------	--------------	--------	-------

Remarks

PW Response:
 - Revise and Resubmit - structural calculations per Datum comments.
 - Exceptions noted for other submittals included
 E Vaughn 5-19-2022

A		NO EXCEPTIONS
B	<input checked="" type="checkbox"/>	EXCEPTIONS AS NOTED
C	<input checked="" type="checkbox"/>	REVISE AND RESUBMIT
D	<input type="checkbox"/>	REJECTED
E	<input type="checkbox"/>	FOR INFORMATION ONLY
F	<input type="checkbox"/>	NOT REVIEWED
SUBMITTAL REVIEW		
SUBMITTALS are reviewed for conformance with the approved contract documents and specifications. The contractor is responsible for providing all necessary information and data to the architect. The architect is not responsible for the accuracy of the contractor's submittals. The contractor shall submit all submittals to the architect for review and approval. The architect's review is limited to a general check for conformance with the contract documents and specifications. The architect does not warrant the accuracy of the submittals or the contractor's interpretation of the contract documents. The contractor shall be responsible for the accuracy of the submittals and the contractor's interpretation of the contract documents.		
Project No		147439 000
By		vaughne
Date		05-19-2022

Signature
Prolog Manager Printed on: 5/6/2022 RENO

Signed Date

Savage and Son

Renown Health Regional Central Utility Plant

Job# 7464

23 52 39

Firetube Boilers

Owner: Renown Health
1155 Mill Street
Reno, NV 89502

Architect: Perkins & Will
2218 Bryan St, Suite 200
Dallas, TX 75201

Engineer: WSP Building Systems
425 Market Street, 17th Floor
San Francisco, CA 94105

General Contractor: Clark/Sullivan Construction
905 Industrial Way
Sparks, NV 89431

Plumbing/Mechanical Contractor: Savage and Son, Inc.
3101 Yori Avenue
Reno, Nevada 89502

Plumbing • HVAC • Piping Since 1893
COMMERCIAL • RESIDENTIAL • INDUSTRIAL

3101 YORI AVENUE, RENO, NV 89502 • (775) 828-4193 • NV LIC. 10 • CA LIC. 37844

23 52 39 Firetube Boilers

Cleaver Brooks CBEX-2W-200-900-150ST Steam Boilers

Seismic Calculations

Cleaver Brooks CRE-36J6DS Feedwater Economizer

Cleaver Brooks A34B Blowdown Separator

Clark/Sullivan's
Oldest
Contractor

Clark/Sullivan Construction

This submittal has been reviewed by Clark/Sullivan for conformance with project documents. This review does not relieve the subcontractor or material supplier from responsibility from errors or deviations from the drawings and specifications.

Reviewed by: AML

Date: 5.6.2022

Subcontractor: Savage

Savage and Son

23 52 39 Firetube Boilers

Cleaver Brooks CBEX-2W-200-900-150ST Steam Boilers

Seismic Calculations

Resubmittal Notes:

- Correct gas pressure noted.
- Additional seismic anchorage/details to be provided by contractor. Submittal to follow under Section 230548.
- Combustion air intakes as shown with louvers on Mechanical drawings.

WSP:

1. Structural engineer to review seismic calculations (pg 26-31)

PJD/SV, 05/12/2022

- No Exceptions Noted
- Exceptions Noted No Resubmission Required
- Exceptions Noted Resubmit For Record
- Revise And Resubmit
- Reviewed For Information
- Not Reviewed



SUBMITTAL REVIEW

REVIEW IS SOLELY FOR GENERAL CONFORMANCE WITH THE DESIGN CONCEPT. THIS REVIEW DOES NOT RELIEVE THE CONTRACTOR FROM TOTAL RESPONSIBILITY FOR QUANTITIES, ERRORS, OMISSIONS OR COMPLIANCE WITH THE INTENT OF THE CONTRACT DOCUMENTS. REVIEW AND APPROVAL BY CONTRACTOR IS REQUIRED BEFORE FABRICATION, SHIPMENT OR INSTALLATION.

ANY ACTION SHOWN IS SUBJECT TO THE REQUIREMENTS OF THE PLANS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR: DIMENSIONS WHICH SHALL BE CONFIRMED AND CORRELATED AT THE JOB SITE. ALL REVISED SUBMITTALS MUST BE RETURNED BY CONTRACTOR WITHIN 15 DAYS FROM RECEIPT OF THE ORIGINAL SUBMITTAL REVIEW.

BY: Peter-Jake Daniels DATE: 5/12/2022

REVIEW OF SHOP DRAWINGS BY ENGINEER SERVES ONLY TO CHECK GENERAL CONFORMANCE WITH CONTRACT DOCUMENTS RELATED ONLY TO THOSE STRUCTURAL ELEMENTS NOTED ON THE CONTRACT STRUCTURAL DRAWINGS AND SPECIFICATIONS. RESPONSIBILITY FOR STRICT COMPLIANCE WITH DRAWINGS AND SPECIFICATIONS AND CORRECTNESS OF CONTRACTOR'S WORK RESTS SOLELY WITH CONTRACTOR REGARDLESS OF THE ACTION TAKEN OR NOTATIONS MADE OR NOT MADE BY THE ENGINEER ON THE SHOP DRAWINGS. ENGINEER DOES NOT ASSUME ANY RESPONSIBILITY FOR VERIFICATION OF DIMENSIONS, DETAILS, MATERIALS, OR CONSTRUCTION OR FABRICATION MEANS AND METHODS.

DATUM SUBMITTAL NO. 010 DATUM
RECEIVED 05-13-2022 ENGINEERS, INC.

NO EXCEPTIONS TAKEN By: DT
MAKE CORRECTIONS NOTED
AMEND & RESUBMIT Date 05-18-2022
REJECTED - SEE REMARKS

Datum Comments:

1. Datum's review is only in relation to structural calculations on pages 26-31 of the pdf. Datum takes no exceptions to re-submitting separate from remainder of submittal if acceptable to P&W.
2. Structural calculations shall be signed by a licensed professional engineer as per specification section 23 52 39 article 1.4.B.3.
3. Structural anchorage details signed by a licensed professional engineer as per specification section 23 52 39 article 1.4.B.3.
4. Seismic accelerations may be reduced to value shown on sheet S00C-02 of construction documents. Additionally, revise roof height to match height of roof in the project.
5. Provide calculations for required anchor embedment depth.
6. Calculations indicate design is per IBC 2012, project is per IBC 2018, confirm compliance.

STATEMENT OF COMPLIANCE

R.F. MacDonald Co. will furnish the following:

Designation: 1061-B-1, B2, and B3

Three (3) Cleaver-Brooks CBEX Elite-200-900-150ST firetube boiler shall be offered as a self-contained packaged forced draft horizontal firetube steam boiler rated for 900 boiler horsepower with fuel input capacities of 36,741 CFH based on gas of 1000 BTU/CFH. Burner packages will be fully automatic for firing natural gas and #2 Oil. Boiler will be designed for maximum steam pressure of 150 PSIG and have a maximum capacity of 31,050 lbs/hr.

The boiler shall be a multi-pass horizontal firetube updraft boiler with using extended heating surface per rated optimized to reduce boiler foot print. It shall be mounted on a heavy steel frame with an integrated forced draft burner and burner controls. The boilers shall be completely preassembled and fire tested at the factory. The unit shall be ready for immediate mounting on floor or simple foundation and ready for attachment of water, steam, fuel, electrical, vent and blow-down connections.

Boiler Design

The boiler shell will be constructed in accordance with ASME Boiler Code and will receive authorized boiler inspection prior to shipment. A copy of the inspection report shall be furnished to the purchaser. The boiler shall be furnished with a manhole and handholes to facilitate boiler inspection and cleaning. Two lifting eyes shall be located on top of the boiler. Front doors on the boiler shall be davited and sealed with superwool insulation and fastened tightly using locking lugs on steel studs. The rear door shall be fitted with an access plug for rear fireside inspection. The boiler tubes shall not include turbulators, swirlers or other add-on appurtenances. The exhaust gas vent shall be located at the front of the boiler and shall be capable of supporting 2,000 lbs. The boiler vent shall contain a stack thermometer. Observation ports for the inspection of flame conditions shall be provided at each end of the boiler. The boiler insulation shall consist of 2" blanket under a sectional pre-formed sheet metal lagging. The insulation must be readily removable and capable of being reinstalled if required. The entire boiler based frame and other components shall be factory painted before shipment, using a hard-finish enamel coating. The boiler shall contain a chemical feed connection.

Boiler Trim (Mounted)

- Feedwater globe and check valve
- Steam non-return valve and stop valve with ASME spool piece
- Feedwater control valve and bypass piping
- Quick and slow blowdown valves
- Surface blowoff manual stop valve and metering valve
- Surface blowdown conductivity controller
- Sample cooler mounted and piped
- Vacuum breaker

- Main and auxiliary low water cutoffs
- High water alarm
- Primary gas train
- Variable speed driver w/ bypass for blower motor
- Pilot gas train
- Main fused disconnect
- Uninterruptible power supply
- Oil train and oil pump

Boiler Trim (Shipped Loose For Field Installation)

- ASME rated pressure relief valve
- Steam stop and non-return valves
- O2 Trim
- BACnet MSTP ProtoNode
- Ladder and platforms

Note: Seismic design with calculation included. Stamp non-CA PE License.

Burner

Forced draft burner of the gun design with hinged access for inspection and service. Reversed curve fabricated aluminum blower fan. Burner shall be of the high radiant multi-port type for natural gas. Gas burner piping on all units shall include primary and secondary gas shutoff valves, motor operated with proof of closure switches and plugged leakage test connections. The main gas valves shall be wired to close automatically in the event of power failure, flame failure, low water or any safety shutdown condition.

HAWK 4000 – Advanced Burner Control System

The Hawk 4000 Advanced System integrates a programmable logic controller, touch screen graphical human-machine interface (HMI), and burner management control, used to control and monitor the complete boiler system. The system offers advanced technology and advanced features for Burner Management and monitoring, firing rate control, thermal shock protection, variable speed drive on combustion air fan, remote monitoring, building automation system monitoring interface, integrated O₂ Monitoring and Air trim. The HMI provides several user interactive screens to display and indicate the status of the boilers operation, operating parameters and integrated control such as the burner management controller.

Control Trim

- Parallel Positioning Combustion Control
- Combustion air control
- Automatic Sequencing – standby, re-purge, pilot flame, main flame, run and post purge.
- Flame proving and lockout on flame failure during pilot flame proving, main flame proving, or run.
- Low fire damper/valve position for flame ignition trials.
- Touch Screen Interface
 - 10” Panel View Plus Color HMI
- High Stack Flue Gas Temperature Monitoring
- Hot Stand By
- Dual Fuel Manual Selector Switch
- BAS System – ProtoNode – BACnet
- UL Label Panel

Emissions Guarantee

The boiler will include an emission control package designed and supplied by Cleaver-Brooks to meet a NO_x emission limit of 30 ppm and CO limit of 100 ppm each corrected to 3% O₂ while firing **natural gas only**.

Requirements

Blower motor: 460V/3Ph/60Hz

Gas pressure: 5 PSIG

A control circuit transformer will be provided to supply 120V/1Ph/60Hz to the control circuit

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT



ATTN: William Austin
4750 Longley Lane #105
Reno, NV 89052
(775) 850-3600

DIESEL STANDBY GENERATOR SET SUBMITTAL



*Images may not reflect actual packages

THREE (3) CAT 3516C Standby Diesel Generator Sets, Rated at 2000kW

Revision 2, Submitted: May 31, 2022

Submittal Prepared By:

Hisham Mannaa, Project Engineer
Cashman Power Solutions
3300 Saint Rose Pkwy.
Henderson, NV 89052

hmanna@cashmanequipment.com

(725) 202-5982

Scott Rhoden, Engine Business Manager · Troy Lowe, Sales Engineer · Geoffrey Torres, Sales Engineer · Kerry Barrick, Project Coordinator ·
Hisham Mannaa, Project Engineer

CASHMAN
Power Solutions



DIESEL STANDBY GENERATOR SET SUBMITTAL

THREE (3) CAT 3516C Standby Diesel Generator Sets, Rated at 2000kW

Renown Health Regional Central Utility Plant

Approval of Submittal

Client Signature

Date

By signing above, the client confirms approval of the submitted package and all specifications therein. This includes but is not limited to dimensions, the design and all specified components.

The client understands that any changes to the order requested after this acceptance will require a formal change order. Any changes made to the approved submitted package may add time and/or cost to the production.

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
DIESEL STANDBY GENERATOR SET SUBMITTAL

TAB 1: GENERAL INFORMATION

- 1.1 CASHMAN CAT – BILL OF MATERIALS
- 1.2 PROJECT CLARIFICATIONS, DEVIATIONS & EXCEPTIONS
- 1.3 INSTALLATION NOTES AND CONSIDERATIONS
- 1.4 INTERCONNECT REQUIREMENTS

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT CASHMAN CAT - BILL OF MATERIALS

THREE (3) Caterpillar 3516C Diesel Standby Generator Sets

Model: CAT 3516C
Rating: 2000kW @ 0.8 PF (Standby Rated)
Voltage: 4160V, 3-phase, 4-wire, 60 Hz
Control Panel: EMCP 4.2B Generator Set Controller

Generator standard equipment and options including (Qty. 1 each unless otherwise specified):

MOUNTING SYSTEM

Spring-type vibration isolators with integral seismic restraint and external adjustment.

ENGINE

Caterpillar Diesel Engine (both on- and off-road #2 ULSD acceptable)
1800 RPM rated engine speed
Electronic Isochronous Governor

ENGINE COOLING SYSTEM

Rated for 104°F
Unit Mounted Radiator
Jacket Water Heater (maintains coolant temperature at 130°F for quick engine starting)
50/50 Antifreeze/Water Mixture

ELECTRIC STARTING SYSTEM

Qty. 4 – 12V CAT Engine Starting Battery Set (Qty. 4 – 153-5720)
Heavy-Duty Dual 24VDC Electric Starting Motors (Left Hand Mounted)
24V, 45A Battery Charging Alternator (charges engine starting battery set only)

AIR STARTING SYSTEM

Qty. 3 – 400 Gallon Vertical Mount Air Storage Tanks
Qty. 2 – 40 HP Rotary Screw Air Compressors, 125 PSIG Max. Pressure, MK5 Graphic Touch Controller
Qty. 2 – Non cycling Refrigerated Air Dryers
Engine Mounted Pneumatic Starting Motor (Right Hand Mounted)

CERTIFICATIONS:

Engine Meets Current EPA Tier II Emissions Requirements for Diesel Standby Generator Sets

EXHAUST SYSTEM

Critical grade exhaust silencer system. This item ships loose for contractor installation, and includes critical silencer, flex connectors, wall thimble, and rain cap. Intermediary piping and insulation not included and is by others.

GENERATOR AND GENERATOR ATTACHMENTS

Brushless, Revolving Field Type Generator, Permanent Magnet Excitation
EM15 Integrated Voltage Regulator
Dual bearing, 105°C temperature rise rating
1000A Buss Bar

EMCP 4.2B CONTROL PANEL

LCD Display with adjustable contrast and backlight with auto power off AC metering: Volts, Amps, Frequency, Battery Volts, Engine Hours, Engine Jacket Water Temperature, Lube Oil Pressure, Engine Speed, and more.

Communication: MODBUS TCP

Local NFPA 99-110 Annunciator (factory installed on generator set control cabinet)

Options:

(Qty. 1) – Remote Annunciator Module (shipped loose for onsite contractor installation)

(Qty. 1) – DIO Module (factory installed in generator control panel)

STARTUP, TESTING, & COMMISSIONING

Startup Services with Technician (Includes Lube Oil and Coolant)

Onsite Load Bank Test: 2-Hour Resistive (1.0 PF)

Customer Training on Operation and Maintenance

WARRANTY

Standard CAT Warranty

MAINTENANCE

2 Year Customer Service Agreement

PROJECT CLARIFICATIONS, DEVIATIONS & EXCEPTIONS

Cashman Power takes general exception to specified products, services, and attachments which are proprietary to any other manufacturer.

1. Submittal must be reviewed and approved prior to ordering of equipment.
2. All installation provided by others.
3. All nameplates, infrared scanning and coordination study provided by others.
4. CAT standard startup/commissioning services included.
5. Section 26 32 13, 2.2.D(3): CAT 3516C, 2000kW, 3-Phase, 4-Wire, in lieu of 3-Phase, 3-Wire Generator.
6. Section 26 32 13, 2.3N(7): Battery Heater is not needed for indoor system and will not be provided.

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
CAT GENERATOR SET
INSTALLATION SUMMARY

SYSTEM DATA

Engine Model	3516C
Engine Displacement	69 L
Generator Rating	2500kVA/2000kW
Voltage (V)	4160V
Phase	Three
Hertz	60
Fuel System	Diesel
Full Load Fuel Consumption	133.6 gal/hr.
Battery Voltage	24VDC

GENERATOR SET PACKAGE DIMENSIONS
(Approximate, not for construction use)

Height	138 in.
Width	103 in.
Length	269 in.

SYSTEM WEIGHTS

Package Weight	~43,850 lbs.
Total Package Weight	~45,390 lbs.

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
CAT GENERATOR SET
INSTALLATION SUMMARY

GENERATOR INSTALLATION CONSIDERATIONS

ACCESS

Cashman service department must be allowed adequate access to the job site for start-up and testing of equipment during normal business hours.

CONNECTIONS

Due to vibrations, all connections to the generator set should be flexible (fuel piping, exhaust piping, electrical conduit, etc.)

CONTROL WIRING

All control wiring must be run in separate conduits from any power wiring to prevent induced voltages. Stranded copper wire is required.

Pull 25% additional wire for spares

Refer to previous sheet for specific information

ELECTRICAL AND FUEL STUB UP

All stub up information can be found in the drawing information that is included in the submittal.

FOUNDATION RECOMMENDATIONS

Foundation depth should be calculated using the wet weight provided in the submittal

Foundation should extend a minimum of 12 inches beyond the generator set base rails

VIBRATION ISOLATOR PADS

Vibration isolators are installed under the generator set rails. Generator set needs to be bolted to the floor.

POWER REQUIREMENTS

Coolant heater, battery charger, day tank controls or any other ac loads required for engine to run, require emergency source normal power input. Refer to previous sheet for details on voltages and load requirements.

VENTILATION

The generator set should be located so that clean, cool air is available to the air intake. Radiator exhaust air should be free of flow restrictions. *We recommend* a minimum of 5 ft clearance on all sides. If walls are present, additional space may be required along with intake and discharge louvers added. Failure to

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
CAT GENERATOR SET
INSTALLATION SUMMARY

prevent hot air recirculation from the engine radiator and exhaust discharge could cause the genset to overheat.

UNLOADING CONSIDERATION

When off-loading equipment with cranes, spreader bars should be used to avoid damaging the equipment. Refer to the dry weight provided for offloading.

DIVISION OF RESPONSIBILITIES

CONTRACTOR'S RESPONSIBILITIES

The following work must be completed by the Contractor prior to startup of the unit per drawings and instructions included in the Contractors Submittal:

FOUNDATION

Off-load and set equipment on a foundation designed and constructed according to load requirements and soil conditions. Provide anchor calculations per local code and requirements. Vibration isolators should be adjusted prior to piping/wiring interconnection.

WIRING

Supply and terminate all interconnecting 12 or 24 VDC control wiring. Wire AC power to jacket water heater, battery charger and all auxiliary equipment including ATS and Switchgear. Wire all power cabling between generator, switchgear, ATS and auxiliary equipment.

FUEL

Provide an adequate supply of good quality fuel. Caterpillar guidelines shall be provided upon request.

CASHMAN EQUIPMENT COMPANY'S RESPONSIBILITIES

In addition to supply of equipment and delivery to the jobsite, Cashman Equipment Company will provide the following:

PROJECT ASSISTANCE

Project assistance of all equipment provided in Cashman's Scope of Supply including design information and submittal drawings. Project support and coordination, as required. Provide Operation and Maintenance Manuals, spare parts list and test reports, if required.

START-UP

Provide the services of a technician to startup and test the generator set, as required. Startup activities include check and install engine coolant and lubricating oil as necessary, install battery electrolyte, check control functions, check automatic operation and load test, if required.

Should you have any questions regarding this submittal or installation procedures, please contact:

GEOFF TORRES

Project Manager

Cashman Equipment Co.

3300 St. Rose Parkway

Henderson, NV 89052

Phone (800) 937-2326

Cell: (702) 343-0448

Email: GeoffreyTorres@cashmanequipment.com

Interconnect Requirements - Renew Health Regional Central Utility Plant

Conduit Number	From	To	Required Wiring	Purpose	Voltage
#1	Generator Control Panel	New/Existing Switchgear	Switchgear supplier to specify requirements	Generator Load Sharing and Voltage Regulation Controls	24VDC or less
#2		Generator Remote Annunciator	Qty. (4) 14 AWG or larger THHN	24VDC Annunciator Power, Spare	24VDC or less
#3		SCADA/BMS System	Qty. (1) Beiden 9841 Cable Contractor/End-User to Specify Monitoring Protocol and Coordinate with Cashman	RS-485 Communications Link for Remote Annunciator Communications link for SCADA/BMS Generator Monitoring	5VDC or less 5VDC or less
#4	Panel 1061-0-LSL2	Generator Control Panel	20A, 120VAC Wiring	Auxiliary Power Distribution for Battery Charger	120V Single Phase
	Panel 1061-0-LSL2	Generator Control Panel	10A, 208VAC Wiring	Auxiliary Power Distribution for Alternator Space Heater	208V Single Phase
	Panel 1061-0-LSL2	Generator Control Panel	44A, 208VAC Wiring	Auxiliary Power Distribution for Jacket Water Heater	208V Single Phase

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
DIESEL STANDBY GENERATOR SET SUBMITTAL

TAB 2: SHOP DRAWINGS


- 2.1 CAT 3516C DIESEL STANDBY GENERATOR SET
 - 2.1.1 LAYOUT/INSTALLATION DRAWINGS
 - 2.1.2 WIRING DIAGRAMS/SCHEMATICS

SHOP DRAWINGS
CAT 3516C DIESEL STANDBY GENERATOR SET


LAYOUT/INSTALLATION DRAWINGS

REVISIONS


REV.	DESCRIPTION	NAME	DATE



SIDE VIEW




OUTLET VIEW



BOTTOM (INLET) VIEW

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: FRACTIONAL: ± 1/8" TWO PLACE DECIMAL: ± .125 THREE PLACE DECIMAL: ± .005 ANGULAR: ± 2° (DIM) = CRITICAL DIMENSION (DIM) = REFERENCE DIMENSION PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF NELSON GLOBAL PRODUCTS (NGP). ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF NGP IS PROHIBITED.	DRAWING TYPE: SALES OUTLINE	DRAWN: CAF CHECKED: - FILE NAME:	DATE: 10/18/21
	GT EXHAUST / NELSON 1560 WILKINS DRIVE WILKINSVILLE, KY 40391-1800 WWW.GTEXHAUST.COM WWW.NELSONGP.COM	SMART / DRAWING#: GS303279 CATALOG: A416-C1-10-5116-2-TOP	TITLE: CRITICAL GRADE 1.6IN SERENITY Silencer STYLE 2 DUGI 10IN BISO 1IN THERMAL PACKING TOP BRACKETS CATERPILLAR 3516
SCALE: NONE WEIGHT: LBS SHEET 1 OF 1			MATERIAL: ALUMINIZED STEEL



GA300079

UNLESS OTHERWISE SPECIFIED:	DRAWN	DWZ	11/13/08
DIMENSIONS ARE IN INCHES	CHECKED		
FRACTIONAL: ± 1/8"	ENG APPR.		
ANGULAR: MACH ± BEND ±			
TWO PLACE DECIMAL ± .13			
THREE PLACE DECIMAL ± .125			
INTERPRET GEOMETRIC TOLERANCING PER:			
MATERIAL			
SEE BOM			
FINISH			
NONE			
DO NOT SCALE DRAWING			



PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS
 THE SOLE PROPERTY OF GT EXHAUST, INC. ANY
 REPRODUCTION IN PART OR AS A WHOLE WITHOUT
 THE WRITTEN PERMISSION OF GT EXHAUST, INC IS
 PROHIBITED.

PART # 10-1F1-1018-CAT


TITLE: 10" FLEX WITH A ANSI PATTERN FLANGE
 AND A FLOATING CAT. ENGINE FLANGE

SIZE DWG. NO. REV
A 10-1F1-1018-CAT C

SCALE: 1:8 WEIGHT: 45.8873 SHEET 1 OF 1

REVISIONS

REV.	DESCRIPTION	NAME	DATE



UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: FRACTIONAL: ± 1/8" TWO PLACE DECIMAL: ± .13 THREE PLACE DECIMAL: ± .125 ANGULAR: ± 1° (DIM) = CRITICAL DIMENSION (DIM) = REFERENCE DIMENSION		DRAWING TYPE: SALES OUTLINE		GT EXHAUST / NELSON 650 WILLIAMS DRIVE STOUTSDOWN, WI 53589 PH. 608-719-1800 WWW.GTUNHAUL.COM WWW.NELSONEXHAUST.COM	
DRAWN CAF	CHECKED -	DATE 08/02/18	FILE NAME: -	PART NUMBER GA300346	TITLE THIMBLE KIT 1 1/2IN NON-Combustible STYLE Standard 8IN ROOF/WALL 26IN OAL
THIRD ANGLE PROJECTION		FINISH: HIGH HEAT BLACK		SCALE: NONE	
MATERIAL: ALUMINIZED STEEL		WEIGHT: LBS		SHEET 1 OF 1	

WIRING DIAGRAMS/SCHEMATICS

ENGINE TYPE	GENERATOR	VOLTAGE	CONTROLLER	SUGGESTED PRINT LIST
C27 / C32	1200/1400 FRAME	LV(<1000V)	EMCP 4.3/4.4	1-7 9 18 20 21 24 26 27 31 46-49 61-64 69 71-74 82 83 98-101
C32	1400 FRAME	MV(1000-5000V)	EMCP 4.3/4.4	1-7 9 18 20 26 27 32 33 46-48 61-64 69 71-74 82 83 98-101
C32	2700 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 9 18 20 22 26 27 37 46-48 50 61-63 65 69 71-74 83 98-101
3512MUJ/3516MUJ	1400/1600/1800 FRAME	LV(<1000V)	EMCP 4.3/4.4	1-7 9 18 20 21 24 26 27 32 33 46-48 54-56 61-64 69 71-74 84 85 104 105
3512MUJ/3516MUJ	1400/1600/1800 FRAME	MV(1000-5000V)	EMCP 4.3/4.4	1-7 9 18 20 26 27 32 33 46-48 54-56 61-64 69 71-74 84 85 104 105
3512EUJ/3516EUJ	2700 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 9 18 20 22 26 27 37 46-48 50 54-56 61-63 65 69 71-74 85 104 105
3512EUJ/3516EUJ	1400/1600/1800	LV(<1000V)	EMCP 4.3/4.4	1-7 9 18 20 21 24 26 27 31 46-49 61-64 69 71-74 80 81 102 103
3512EUJ/3516EUJ	1400/1600/1800	MV(1000-5000V)	EMCP 4.3/4.4	1-7 9 18 20 26 27 32 33 46-48 61-64 69 71-74 80 81 102 103
3516EUJ	Y5000 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 9 18 20 22 26 27 37 46-48 50 61-63 65 69 71-74 81 102 103
3516EUJ	B5600H4 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 13 18 20 23 26 27 40 46-48 53 61-63 68 69 71-74 81 102 103
3516EUJ	3000 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 12 18 20 23 26 27 39 46-48 52 61-63 67 69 71-74 81 102 103
C175-16	1800 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 9 18 20 21 24 26 27 31 46-49 61-64 69 71-74 80 81 102 103
C175-16	1800 FRAME	LV(<1000V)	EMCP 4.3/4.4	1-7 9 18 20 26 27 32 33 46-48 61-64 69 71-74 80 81 102 103
C175-16/C175-20	3000 FRAME	MV(1000-5000V)	EMCP 4.3/4.4	1-7 9 18 20 22 26 27 32 33 46-48 61-64 69 71-74 87 89 111 112 113
C175-16/C175-20	3000 FRAME	MV-HV(>1000V)	EMCP 4.3/4.4	1-7 9 11 18 20 22 26 27 38 46-48 61-64 69 71-74 87 89 111 112 113
G3500A	1400 FRAME	LV(<1000V)/MV-HV(>1000V)	EMCP 4.3/4.4	1-7 16-18 20-22 26-35 41 49 57-64 69-74 92 116 119
G3500C/E	1600/1800 FRAME	LV(<1000V)/MV-HV(>1000V)	EMCP 4.3/4.4	1-7 16-18 20-22 26-35 41 49 57-64 69-74 90 114 119
G3500C/E	2600/2700 FRAME	LV(<1000V)/MV-HV(>1000V)	EMCP 4.3/4.4	1-7 10 16-18 20 22 26-30 37 42 50 57-63 65 69 71-74 90 114 119
G3500H	1600/1800 FRAME	LV(<1000V)/MV-HV(>1000V)	EMCP 4.3/4.4	1-7 16-18 20-22 26-35 41 49 57-64 69-74 94-96 118 119
G3500H	2700 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 10 16-18 20 22 26-30 37 38 42 50 57-63 65 69 71-74 94-96 118 119
G3500H	3000 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 11 16-18 20 22 26-30 37 38 42 50 57-63 65 69 71-74 94-96 118 119
G3500B	1600 FRAME	HV(>5KV)	EMCP 4.3/4.4	1-7 16-18 20-22 26-35 41 49 57-64 69 71-74 93 117 119
G3500 STANDBY	1400/1600/1800 FRAME	LV(<1000V)/MV-HV(>1000V)	EMCP 4.3/4.4	1-7 16-18 20-22 26-35 41 49 57-64 69 71-74 93 117 119
C27	1200/1400 FRAME	LV(<1000V)	EMCP 4.2B	1-8 18-21 24 31 43-45 61-64 69 82 83 98-101
C32	1200/1400 FRAME	LV(<1000V)	EMCP 4.2B	1-8 18-21 24 31 43-45 61-64 69 82 83 98-101
C32	1400 FRAME	MV(1000-5000V)	EMCP 4.2B	1-8 18-21 24 31 43-45 61-64 69 82 83 98-101
C32	2700 FRAME	HV(>5KV)	EMCP 4.2B	1-8 18-21 24 31 43-45 61-64 69 82 83 98-101
3512MUJ/3516MUJ	1400/1600/1800 FRAME	LV(<1000V)	EMCP 4.2B	1-8 10 18-20 22 37 43-45 50 61-63 65 69 83 98-101
3512MUJ/3516MUJ	1400/1600/1800 FRAME	MV(1000-5000V)	EMCP 4.2B	1-8 18-20 33 36 43-45 54-56 61-64 69 84 85 104 105
3512MUJ/3516MUJ	2700 FRAME	HV(>5KV)	EMCP 4.2B	1-8 18-21 24 31 43-45 49 54-56 61-64 69 84 85 104 105
3512EUJ/3516EUJ	1400/1600/1800 FRAME	LV(<1000V)	EMCP 4.2B	1-8 10 18-20 22 37 43-45 50 54-56 61-63 65 69 85 104 105
3512EUJ/3516EUJ	1400/1600/1800 FRAME	MV(1000-5000V)	EMCP 4.2B	1-8 31 43-45 49 61-64 69 80 81 102 103 104 105
3516EUJ	2700 FRAME	HV(>5KV)	EMCP 4.2B	1-8 18-20 33 36 43-45 61-64 69 80 81 102 103
3516EUJ	Y5000 FRAME	HV(>5KV)	EMCP 4.2B	1-8 10 18-20 22 37 43-45 50 61-63 65 69 81 102 103
3516EUJ	B5600H4 FRAME	HV(>5KV)	EMCP 4.2B	1-8 13 18-20 23 40 43-45 53 61-63 68 69 81 102 103
3516EUJ	3000 FRAME	HV(>5KV)	EMCP 4.2B	1-8 12 18-20 23 39 43-45 52 61-63 67 69 81 102 103
C175-16	1800 FRAME	HV(>5KV)	EMCP 4.2B	1-8 11 18-20 22 38 43-45 52 61-63 66 69 81 102 103
C175-16	1800 FRAME	LV(<1000V)	EMCP 4.2B	1-8 18-21 24 31 43-45 49 61-64 69 87 89 111 112 113
C175-16/C175-20	3000 FRAME	MV(1000-5000V)	EMCP 4.2B	1-8 18-20 33 36 43-45 61-64 69 87 89 111 112 113
C175-16/C175-20	3000 FRAME	MV-HV(>1000V)	EMCP 4.2B	1-8 11 18-20 22 38 43-45 52 61-63 66 69 89 111 112 113

15167A INT-PROP
 15167A DRAWING - AUTOCAD
 15167A GRAND MARKINGS
 15167A IDENTIFICATION
 15167A INTERPRETATION
 15167A INTERP & TOL

ARUN GOPAL
 LYLE SEWELL
 J.D. ELDER
 J. J. HARRIS
 RECORDS

01 2 AUG 19
 00 1 JUL 18

CATERPILLAR INC.
 1600 N. WILSON AVENUE
 PEORIA, IL 61654-9001
 U.S.A.

DIAGRAM - WIRING
 MODULAR CONTROLS

521-9364

EMCP 4.3/4.4 I/O DEFAULT CONFIGURATION

DESCRIPTION	RELAY	3500-EUI	C175-16/C175-20	C27 & C32	G3500
E-STOP (DEDICATED)		E-STOP (DEDICATED)	E-STOP (DEDICATED)	E-STOP (DEDICATED)	E-STOP (DEDICATED)
REMOTE INITIATE (DEDICATED)		REMOTE INITIATE (DEDICATED)	REMOTE INITIATE (DEDICATED)	REMOTE INITIATE (DEDICATED)	REMOTE INITIATE (DEDICATED)
START (DEDICATED DI-2)		SPARE	FUEL LEAK (ENCLOSURE)	SPARE	SPARE
PROC. DI-01		SPARE	AC BATTERY CHARGER FAILURE (ENCLOSURE)	SPARE	SPARE
PROC. DI-02		526F1 OPEN (OPTIONAL)	526F1 OPEN (OPTIONAL)	526F1 OPEN (OPTIONAL)	526F1 OPEN (OPTIONAL)
PROC. DI-03		526F2 OPEN (OPTIONAL)	526F2 OPEN (OPTIONAL)	526F2 OPEN (OPTIONAL)	526F2 OPEN (OPTIONAL)
PROC. DI-04		JACKET WATER COOLANT LEVEL ALARM	SPARE	SPARE	SPARE
PROC. DI-05		SCAC COOLANT LEVEL ALARM	SPARE	SPARE	SPARE
PROC. DI-06		SPARE	SPARE	SPARE	SPARE
PROC. DI-07		SPARE	SPARE	SPARE	SPARE
PROC. DI-08		SPARE	SPARE	SPARE	SPARE
ISOLATED DI-01		SPARE	SPARE	SPARE	SPARE
ISOLATED DI-02		SPARE	SPARE	SPARE	SPARE
ISOLATED DI-03		SPARE	SPARE	SPARE	SPARE
ISOLATED DI-04		SPARE	SPARE	SPARE	SPARE
ANALOG INPUT-1		GEAR OIL TEMPERATURE (GEARBOX)	SPARE	SPARE	SPARE
ANALOG INPUT-2		SPARE	SPARE	SPARE	SPARE
ANALOG INPUT-3		SPARE	SPARE	SPARE	SPARE
ANALOG INPUT-4		SPARE	SPARE	SPARE	SPARE
DI-1	R1	STARTER MOTOR MAG RELAY	SPARE	SPARE	STARTER MOTOR MAG RELAY
DI-2	R2	SPARE	SPARE	SPARE	START/STOP (ENABLE)
DI-3	R3	SPARE	DISABLE AUX AC SUPPLY (ENCLOSURE)	SPARE	EQU FAULT RESET
DI-4		SPARE	SPARE	SPARE	SPARE
DI-5		COMMON SHUTDOWN	COMMON SHUTDOWN	COMMON SHUTDOWN	COMMON SHUTDOWN
DI-6		SPARE	SPARE	SPARE	SPARE
DI-7		SPARE	SPARE	SPARE	SPARE
DI-8		SPARE	SPARE	SPARE	SPARE
DI-9		SPARE	SPARE	SPARE	SPARE
DI-10		SPARE	SPARE	SPARE	COMMON SHUTDOWN
DI-11		SPARE	SPARE	SPARE	SPARE
DI-12	R12	SPARE	SPARE	SPARE	SPARE
DI-13	R13	SPARE	SPARE	SPARE	SPARE
DI-14	R14	REFUEL	SPARE	SPARE	SPARE
DI-15	R15	DISABLE AUX AC SUPPLY	DISABLE AUX AC SUPPLY	DISABLE AUX AC SUPPLY	DISABLE AUX AC SUPPLY
DI-16	R16	SPARE	SPARE	SPARE	GOVERNOR ZV00C*
DI-17		SPARE	SPARE	SPARE	SPARE
DI-18		GROUP START	GROUP START	GROUP START	GROUP START
DI-19		CIRCUIT BREAKER OVERCURRENT ALARM	CIRCUIT BREAKER OVERCURRENT ALARM	CIRCUIT BREAKER OVERCURRENT ALARM	CIRCUIT BREAKER OVERCURRENT ALARM
DI-20		MANUAL CIRCUIT BREAKER OPEN	MANUAL CIRCUIT BREAKER OPEN	MANUAL CIRCUIT BREAKER OPEN	MANUAL CIRCUIT BREAKER OPEN
DI-21		MANUAL CIRCUIT BREAKER CLOSE	MANUAL CIRCUIT BREAKER CLOSE	MANUAL CIRCUIT BREAKER CLOSE	MANUAL CIRCUIT BREAKER CLOSE
DI-22		DEAD BUS ARBITRATION RELAY	DEAD BUS ARBITRATION RELAY	DEAD BUS ARBITRATION RELAY	DEAD BUS ARBITRATION RELAY
DI-23		CIRCUIT BREAKER CLOSE	CIRCUIT BREAKER CLOSE	CIRCUIT BREAKER CLOSE	CIRCUIT BREAKER CLOSE
DI-24		CIRCUIT BREAKER OPEN	CIRCUIT BREAKER OPEN	CIRCUIT BREAKER OPEN	CIRCUIT BREAKER OPEN

* EMCP 4.4 ONLY
 * C3500A SERIES GAS PACKAGES ONLY
 * EMCP 4.3 ONLY

EMCP 4.2B I/O DEFAULT CONFIGURATION

DESCRIPTION	RELAY	3500-EUI	C175-16/C175-20	C27 & C32
RELAY 01	R01	SMVS	SPARE	SPARE
RELAY 02	R02	SPARE	SPARE	SPARE
RELAY 03	R03	SPARE	SPARE	SPARE
RELAY 04	R04	LEVEL ENABLE	SPARE	SPARE
RELAY 05	R05	REFUEL	COMMON SHUTDOWN	COMMON SHUTDOWN
RELAY 06	R06	COMMON SHUTDOWN	COMMON SHUTDOWN	COMMON SHUTDOWN
RELAY 07	R07	LOW IDLE SPEED	SPARE	SPARE
RELAY 08	R08	SPARE	SPARE	SPARE
RELAY 09	R09	DISABLE AUX AC SUPPLY	DISABLE AUX AC SUPPLY	DISABLE AUX AC SUPPLY
RELAY 10	R10	CONTROL SIGNAL TO M/T (DEDICATED)	CONTROL SIGNAL TO M/T (DEDICATED)	CONTROL SIGNAL TO M/T (DEDICATED)
RELAY 11	R11	E-STOP (DEDICATED)	E-STOP (DEDICATED)	E-STOP (DEDICATED)
RELAY 12	R12	REMOTE INITIATE (DEDICATED)	REMOTE INITIATE (DEDICATED)	REMOTE INITIATE (DEDICATED)
RELAY 13	R13	SPARE	SPARE	SPARE
RELAY 14	R14	526F1 OPEN (OPTIONAL)	526F1 OPEN (OPTIONAL)	526F1 OPEN (OPTIONAL)
RELAY 15	R15	526F2 OPEN (OPTIONAL)	526F2 OPEN (OPTIONAL)	526F2 OPEN (OPTIONAL)
RELAY 16	R16	GEAR OIL PRESSURE SWITCH(GEARBOX)	JACKET WATER COOLANT LEVEL ALARM	JACKET WATER COOLANT LEVEL ALARM
RELAY 17	R17	GEAR OIL PRESSURE SWITCH(GEARBOX)	SCAC COOLANT LEVEL ALARM	SCAC COOLANT LEVEL ALARM
RELAY 18	R18	SPARE	SPARE	SPARE
RELAY 19	R19	SPARE	SPARE	SPARE
RELAY 20	R20	ENGINE COOLANT TEMPERATURE	ENGINE COOLANT TEMPERATURE	ENGINE COOLANT TEMPERATURE
RELAY 21	R21	SPARE	SPARE	SPARE
RELAY 22	R22	SPARE	SPARE	SPARE

1E5176A INT-PROP
 1E2733 DRAWING - AUTOCAD
 1E0198W BRAND MARKINGS
 1E0015G CONFIDENTIALITY
 1E0012A INTERPRETATION
 1E0011 INT/PR & TOL

ARLAN COPAL
 LYLE SEWAL
 J.D. ELDER
 RECORDS

DATE: 01/11/18
 TIME: 10:00 AM
 PROJECT: 521-9364
 DRAWING: 1E5176A INT-PROP



81 23AUG18
 001 11JUL18
 COL. MAIL

CATERPILLAR INC.
 1000 W. WASHINGTON ST., SUITE 1000
 PEORIA, IL 61604-1000
 TEL: 312.781.2000
 FAX: 312.781.2001
 WWW.CATERPILLAR.COM

DIAGRAM - WIRING
 MODULAR CONTROLS

521-9364 - 361 W944 D

NOTES
 CATERPILLAR: CONFIDENTIAL GREEN



- ① EMCP 4
- ② EMCP 4 PANEL
- ③ RS-485 ANNUNCIATOR (OPTIONAL)
- ④ SPEED/Hz ADJUST (OPTIONAL)
- ⑤ SERVICE TOOL CONNECTOR #2 (CAN2: EXPANSION MODULES, RTD AND DIO)
- ⑥ SERVICE TOOL CONNECTOR #1 (GDL& CAN1: ADEM, EMCP, THERMOCOUPLE, CAT CONNECT)
- ⑦ CIRCUIT BREAKER CLOSE PUSH BUTTON (RED LIGHT) (EMCP 4.4 ONLY)
- ⑧ CIRCUIT BREAKER TRIP PUSH BUTTON (GREEN LIGHT) (EMCP 4.4 ONLY)
- ⑨ EMERGENCY STOP PUSH BUTTON
- ⑩ RTD MODULE (OPTIONAL)
- ⑪ CAN 2 TEE CONNECTOR
- ⑫ IVR MODULE (EM10/EM15)
- ⑬ PMG/IE FUSING
- ⑭ VOLTAGE SENSING FUSING
- ⑮ CURRENT SENSING
- ⑯ PWM (IVR MODULE CONTROL SIGNAL)
- ⑰ 24VDC TERMINAL STRIP
- ⑱ CUSTOMER SHORE POWER CONNECTION
- ⑲ SPACE HEATER CONTROLS (OPTIONAL)
- ⑳ JACKET WATER HEATER CONTROLS (OPTIONAL)
- ㉑ GEARBOX COMPONENTS (3516 ONLY) OR 12V COMMON ENCLOSURE BATTERY CHARGER COMPONENTS (C27/C32 ONLY)


REV	DATE	BY	CHKD	DESCRIPTION
1	01.2.AUG.19	ARJUN GOPAL	TYLE SEWALL	ISSUED FOR CONSTRUCTION
2	00.11.JUL.18	J.D. EIDER		ISSUED FOR CONSTRUCTION
3				ISSUED FOR CONSTRUCTION
4				ISSUED FOR CONSTRUCTION
5				ISSUED FOR CONSTRUCTION
6				ISSUED FOR CONSTRUCTION
7				ISSUED FOR CONSTRUCTION
8				ISSUED FOR CONSTRUCTION
9				ISSUED FOR CONSTRUCTION
10				ISSUED FOR CONSTRUCTION
11				ISSUED FOR CONSTRUCTION
12				ISSUED FOR CONSTRUCTION
13				ISSUED FOR CONSTRUCTION
14				ISSUED FOR CONSTRUCTION
15				ISSUED FOR CONSTRUCTION
16				ISSUED FOR CONSTRUCTION
17				ISSUED FOR CONSTRUCTION
18				ISSUED FOR CONSTRUCTION
19				ISSUED FOR CONSTRUCTION
20				ISSUED FOR CONSTRUCTION

COMPONENT LAYOUT - SHEET 1 OF 11
 MODULAR CONTROL PANEL/VR SUBPANEL
 FOR NOTES, SEE SHEET 11
 CATERPILLAR: CONFIDENTIAL GREEN


CATERPILLAR INC.
 THE MANUFACTURER OF THE PRODUCT IS CATERPILLAR INC. 11
 100 NORTH WASHINGTON AVENUE, PEORIA, ILLINOIS 61654-0001
 DIAGRAM - WIRING
 MODULAR CONTROLS

OPTIONAL DISCRETE I/O MODULE TERMINALS
(INSTALLED IN AC/DC BOX)

RESISTIVE LOADS RATED FOR JAWBOWC,
K&M CONTACTS RATED FOR S&B/SMAC,
INDUCTIVE LOADS RATED FOR JAWBOWC CS&B-4
(USER DC RETURN)
(USER DC SUPPLY)




NOTE F



FOR MULTIPHONE NETWORK TERMINATE WITH 120 OHM RESISTOR AT THE ENDS OF THE NETWORK

MODULAR CONTROL PANEL
TERMINAL BLOCK ASSEMBLY



NOTE J

CUSTOMER INTERCONNECTS SHEET 3 OF 11
CUSTOMER INTERCONNECTS SHEET 4 OF 11
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN


1	1E5187A	INT-PROP	AUTOCAD
2	1E0012A	INT-PROP	MARKINGS
3	1E0013S	CONFIDENTIALITY	
4	1E0012A	INTERPRETATION	
5	1E0011	INTPR & TOL	
6	1E0011	INTPR & TOL	
7	1E0011	INTPR & TOL	
8	1E0011	INTPR & TOL	
9	1E0011	INTPR & TOL	
10	1E0011	INTPR & TOL	
11	1E0011	INTPR & TOL	
12	1E0011	INTPR & TOL	
13	1E0011	INTPR & TOL	
14	1E0011	INTPR & TOL	
15	1E0011	INTPR & TOL	
16	1E0011	INTPR & TOL	
17	1E0011	INTPR & TOL	
18	1E0011	INTPR & TOL	
19	1E0011	INTPR & TOL	
20	1E0011	INTPR & TOL	
21	1E0011	INTPR & TOL	
22	1E0011	INTPR & TOL	
23	1E0011	INTPR & TOL	
24	1E0011	INTPR & TOL	
25	1E0011	INTPR & TOL	
26	1E0011	INTPR & TOL	
27	1E0011	INTPR & TOL	
28	1E0011	INTPR & TOL	
29	1E0011	INTPR & TOL	
30	1E0011	INTPR & TOL	
31	1E0011	INTPR & TOL	
32	1E0011	INTPR & TOL	
33	1E0011	INTPR & TOL	
34	1E0011	INTPR & TOL	
35	1E0011	INTPR & TOL	
36	1E0011	INTPR & TOL	
37	1E0011	INTPR & TOL	
38	1E0011	INTPR & TOL	
39	1E0011	INTPR & TOL	
40	1E0011	INTPR & TOL	
41	1E0011	INTPR & TOL	
42	1E0011	INTPR & TOL	
43	1E0011	INTPR & TOL	
44	1E0011	INTPR & TOL	
45	1E0011	INTPR & TOL	
46	1E0011	INTPR & TOL	
47	1E0011	INTPR & TOL	
48	1E0011	INTPR & TOL	
49	1E0011	INTPR & TOL	
50	1E0011	INTPR & TOL	
51	1E0011	INTPR & TOL	
52	1E0011	INTPR & TOL	
53	1E0011	INTPR & TOL	
54	1E0011	INTPR & TOL	
55	1E0011	INTPR & TOL	
56	1E0011	INTPR & TOL	
57	1E0011	INTPR & TOL	
58	1E0011	INTPR & TOL	
59	1E0011	INTPR & TOL	
60	1E0011	INTPR & TOL	
61	1E0011	INTPR & TOL	
62	1E0011	INTPR & TOL	
63	1E0011	INTPR & TOL	
64	1E0011	INTPR & TOL	
65	1E0011	INTPR & TOL	
66	1E0011	INTPR & TOL	
67	1E0011	INTPR & TOL	
68	1E0011	INTPR & TOL	
69	1E0011	INTPR & TOL	
70	1E0011	INTPR & TOL	
71	1E0011	INTPR & TOL	
72	1E0011	INTPR & TOL	
73	1E0011	INTPR & TOL	
74	1E0011	INTPR & TOL	
75	1E0011	INTPR & TOL	
76	1E0011	INTPR & TOL	
77	1E0011	INTPR & TOL	
78	1E0011	INTPR & TOL	
79	1E0011	INTPR & TOL	
80	1E0011	INTPR & TOL	
81	1E0011	INTPR & TOL	
82	1E0011	INTPR & TOL	
83	1E0011	INTPR & TOL	
84	1E0011	INTPR & TOL	
85	1E0011	INTPR & TOL	
86	1E0011	INTPR & TOL	
87	1E0011	INTPR & TOL	
88	1E0011	INTPR & TOL	
89	1E0011	INTPR & TOL	
90	1E0011	INTPR & TOL	
91	1E0011	INTPR & TOL	
92	1E0011	INTPR & TOL	
93	1E0011	INTPR & TOL	
94	1E0011	INTPR & TOL	
95	1E0011	INTPR & TOL	
96	1E0011	INTPR & TOL	
97	1E0011	INTPR & TOL	
98	1E0011	INTPR & TOL	
99	1E0011	INTPR & TOL	
100	1E0011	INTPR & TOL	

CATERPILLAR INC.

DATE: 01 23 AUG 19
TIME: 00 11 JUL 18
DRAWN: JJA ELDER
CHECKED: JJA ELDER
APPROVED: ARJUN GOPAL
SCALE: 1:1
SHEET: 20 OF 118
PROJECT: 521-9364

DIAGRAM - WIRING
521-9364

REFER SHEET 35 FOR OPTIONAL SWITCHGEAR TYPE CONNECTION, PT. AND DCT CONNECTION DETAILS




1	118 AC 200V	118 AC 200V
2	118 AC 200V	118 AC 200V
3	118 AC 200V	118 AC 200V
4	118 AC 200V	118 AC 200V
5	118 AC 200V	118 AC 200V
6	118 AC 200V	118 AC 200V
7	118 AC 200V	118 AC 200V
8	118 AC 200V	118 AC 200V
9	118 AC 200V	118 AC 200V
10	118 AC 200V	118 AC 200V
11	118 AC 200V	118 AC 200V
12	118 AC 200V	118 AC 200V
13	118 AC 200V	118 AC 200V
14	118 AC 200V	118 AC 200V
15	118 AC 200V	118 AC 200V
16	118 AC 200V	118 AC 200V
17	118 AC 200V	118 AC 200V
18	118 AC 200V	118 AC 200V
19	118 AC 200V	118 AC 200V
20	118 AC 200V	118 AC 200V
21	118 AC 200V	118 AC 200V
22	118 AC 200V	118 AC 200V
23	118 AC 200V	118 AC 200V
24	118 AC 200V	118 AC 200V
25	118 AC 200V	118 AC 200V
26	118 AC 200V	118 AC 200V
27	118 AC 200V	118 AC 200V
28	118 AC 200V	118 AC 200V
29	118 AC 200V	118 AC 200V
30	118 AC 200V	118 AC 200V
31	118 AC 200V	118 AC 200V
32	118 AC 200V	118 AC 200V
33	118 AC 200V	118 AC 200V
34	118 AC 200V	118 AC 200V
35	118 AC 200V	118 AC 200V
36	118 AC 200V	118 AC 200V
37	118 AC 200V	118 AC 200V
38	118 AC 200V	118 AC 200V
39	118 AC 200V	118 AC 200V
40	118 AC 200V	118 AC 200V
41	118 AC 200V	118 AC 200V
42	118 AC 200V	118 AC 200V
43	118 AC 200V	118 AC 200V
44	118 AC 200V	118 AC 200V
45	118 AC 200V	118 AC 200V
46	118 AC 200V	118 AC 200V
47	118 AC 200V	118 AC 200V
48	118 AC 200V	118 AC 200V
49	118 AC 200V	118 AC 200V
50	118 AC 200V	118 AC 200V
51	118 AC 200V	118 AC 200V
52	118 AC 200V	118 AC 200V
53	118 AC 200V	118 AC 200V
54	118 AC 200V	118 AC 200V
55	118 AC 200V	118 AC 200V
56	118 AC 200V	118 AC 200V
57	118 AC 200V	118 AC 200V
58	118 AC 200V	118 AC 200V
59	118 AC 200V	118 AC 200V
60	118 AC 200V	118 AC 200V
61	118 AC 200V	118 AC 200V
62	118 AC 200V	118 AC 200V
63	118 AC 200V	118 AC 200V
64	118 AC 200V	118 AC 200V
65	118 AC 200V	118 AC 200V
66	118 AC 200V	118 AC 200V
67	118 AC 200V	118 AC 200V
68	118 AC 200V	118 AC 200V
69	118 AC 200V	118 AC 200V
70	118 AC 200V	118 AC 200V
71	118 AC 200V	118 AC 200V
72	118 AC 200V	118 AC 200V
73	118 AC 200V	118 AC 200V
74	118 AC 200V	118 AC 200V
75	118 AC 200V	118 AC 200V
76	118 AC 200V	118 AC 200V
77	118 AC 200V	118 AC 200V
78	118 AC 200V	118 AC 200V
79	118 AC 200V	118 AC 200V
80	118 AC 200V	118 AC 200V
81	118 AC 200V	118 AC 200V
82	118 AC 200V	118 AC 200V
83	118 AC 200V	118 AC 200V
84	118 AC 200V	118 AC 200V
85	118 AC 200V	118 AC 200V
86	118 AC 200V	118 AC 200V
87	118 AC 200V	118 AC 200V
88	118 AC 200V	118 AC 200V
89	118 AC 200V	118 AC 200V
90	118 AC 200V	118 AC 200V
91	118 AC 200V	118 AC 200V
92	118 AC 200V	118 AC 200V
93	118 AC 200V	118 AC 200V
94	118 AC 200V	118 AC 200V
95	118 AC 200V	118 AC 200V
96	118 AC 200V	118 AC 200V
97	118 AC 200V	118 AC 200V
98	118 AC 200V	118 AC 200V
99	118 AC 200V	118 AC 200V
100	118 AC 200V	118 AC 200V

AC SCHEMATIC - SHEET 3 OF 12
 MED VOLT (3300-4160V) - IVR OPTION
 FOR MODULAR CONTROL
 FOR MODULAR SHEET 4
 CATERPILLAR - CONFIDENTIAL GREEN

CATERPILLAR INC.
 1100 EAST CALIFORNIA STREET
 PEORIA, ILLINOIS 61654-0001
 PHONE 312/375-3000
 FAX 312/375-3001
 TELETYPE 312/375-3002
 CATERPILLAR INC. 1100 EAST CALIFORNIA STREET PEORIA, ILLINOIS 61654-0001 PHONE 312/375-3000 FAX 312/375-3001 TELETYPE 312/375-3002


REVISIONS
 NO. DATE BY
 01 2 AUG 19 01 11 JUL 18
 02 11 JUL 18 01 11 JUL 18
 03 11 JUL 18 01 11 JUL 18
 04 11 JUL 18 01 11 JUL 18
 05 11 JUL 18 01 11 JUL 18
 06 11 JUL 18 01 11 JUL 18
 07 11 JUL 18 01 11 JUL 18
 08 11 JUL 18 01 11 JUL 18
 09 11 JUL 18 01 11 JUL 18
 10 11 JUL 18 01 11 JUL 18
 11 11 JUL 18 01 11 JUL 18
 12 11 JUL 18 01 11 JUL 18
 13 11 JUL 18 01 11 JUL 18
 14 11 JUL 18 01 11 JUL 18
 15 11 JUL 18 01 11 JUL 18
 16 11 JUL 18 01 11 JUL 18
 17 11 JUL 18 01 11 JUL 18
 18 11 JUL 18 01 11 JUL 18
 19 11 JUL 18 01 11 JUL 18
 20 11 JUL 18 01 11 JUL 18
 21 11 JUL 18 01 11 JUL 18
 22 11 JUL 18 01 11 JUL 18
 23 11 JUL 18 01 11 JUL 18
 24 11 JUL 18 01 11 JUL 18
 25 11 JUL 18 01 11 JUL 18
 26 11 JUL 18 01 11 JUL 18
 27 11 JUL 18 01 11 JUL 18
 28 11 JUL 18 01 11 JUL 18
 29 11 JUL 18 01 11 JUL 18
 30 11 JUL 18 01 11 JUL 18
 31 11 JUL 18 01 11 JUL 18
 32 11 JUL 18 01 11 JUL 18
 33 11 JUL 18 01 11 JUL 18
 34 11 JUL 18 01 11 JUL 18
 35 11 JUL 18 01 11 JUL 18
 36 11 JUL 18 01 11 JUL 18
 37 11 JUL 18 01 11 JUL 18
 38 11 JUL 18 01 11 JUL 18
 39 11 JUL 18 01 11 JUL 18
 40 11 JUL 18 01 11 JUL 18
 41 11 JUL 18 01 11 JUL 18
 42 11 JUL 18 01 11 JUL 18
 43 11 JUL 18 01 11 JUL 18
 44 11 JUL 18 01 11 JUL 18
 45 11 JUL 18 01 11 JUL 18
 46 11 JUL 18 01 11 JUL 18
 47 11 JUL 18 01 11 JUL 18
 48 11 JUL 18 01 11 JUL 18
 49 11 JUL 18 01 11 JUL 18
 50 11 JUL 18 01 11 JUL 18
 51 11 JUL 18 01 11 JUL 18
 52 11 JUL 18 01 11 JUL 18
 53 11 JUL 18 01 11 JUL 18
 54 11 JUL 18 01 11 JUL 18
 55 11 JUL 18 01 11 JUL 18
 56 11 JUL 18 01 11 JUL 18
 57 11 JUL 18 01 11 JUL 18
 58 11 JUL 18 01 11 JUL 18
 59 11 JUL 18 01 11 JUL 18
 60 11 JUL 18 01 11 JUL 18
 61 11 JUL 18 01 11 JUL 18
 62 11 JUL 18 01 11 JUL 18
 63 11 JUL 18 01 11 JUL 18
 64 11 JUL 18 01 11 JUL 18
 65 11 JUL 18 01 11 JUL 18
 66 11 JUL 18 01 11 JUL 18
 67 11 JUL 18 01 11 JUL 18
 68 11 JUL 18 01 11 JUL 18
 69 11 JUL 18 01 11 JUL 18
 70 11 JUL 18 01 11 JUL 18
 71 11 JUL 18 01 11 JUL 18
 72 11 JUL 18 01 11 JUL 18
 73 11 JUL 18 01 11 JUL 18
 74 11 JUL 18 01 11 JUL 18
 75 11 JUL 18 01 11 JUL 18
 76 11 JUL 18 01 11 JUL 18
 77 11 JUL 18 01 11 JUL 18
 78 11 JUL 18 01 11 JUL 18
 79 11 JUL 18 01 11 JUL 18
 80 11 JUL 18 01 11 JUL 18
 81 11 JUL 18 01 11 JUL 18
 82 11 JUL 18 01 11 JUL 18
 83 11 JUL 18 01 11 JUL 18
 84 11 JUL 18 01 11 JUL 18
 85 11 JUL 18 01 11 JUL 18
 86 11 JUL 18 01 11 JUL 18
 87 11 JUL 18 01 11 JUL 18
 88 11 JUL 18 01 11 JUL 18
 89 11 JUL 18 01 11 JUL 18
 90 11 JUL 18 01 11 JUL 18
 91 11 JUL 18 01 11 JUL 18
 92 11 JUL 18 01 11 JUL 18
 93 11 JUL 18 01 11 JUL 18
 94 11 JUL 18 01 11 JUL 18
 95 11 JUL 18 01 11 JUL 18
 96 11 JUL 18 01 11 JUL 18
 97 11 JUL 18 01 11 JUL 18
 98 11 JUL 18 01 11 JUL 18
 99 11 JUL 18 01 11 JUL 18
 100 11 JUL 18 01 11 JUL 18



DC SCHEMATIC - SHEET 1 OF 18
 EMCP 4.2B-DIESEL
 FOR NOTES SEE SHEET 4
 CATERPILLAR: CONFIDENTIAL GREEN


1	TEST/VA INT - PROP
2	TEST/VA DRAWING - AUTOCAD
3	TEST/VA BRAND MARKINGS
4	TEST/VA CONFIDENTIALITY
5	TEST/VA INTERPRETATION
6	TEST/VA INTRP & TOL
7	TEST/VA
8	TEST/VA
9	TEST/VA
10	TEST/VA
11	TEST/VA
12	TEST/VA
13	TEST/VA
14	TEST/VA
15	TEST/VA
16	TEST/VA
17	TEST/VA
18	TEST/VA
19	TEST/VA
20	TEST/VA
21	TEST/VA
22	TEST/VA
23	TEST/VA
24	TEST/VA
25	TEST/VA
26	TEST/VA
27	TEST/VA
28	TEST/VA
29	TEST/VA
30	TEST/VA
31	TEST/VA
32	TEST/VA
33	TEST/VA
34	TEST/VA
35	TEST/VA
36	TEST/VA
37	TEST/VA
38	TEST/VA
39	TEST/VA
40	TEST/VA
41	TEST/VA
42	TEST/VA
43	TEST/VA
44	TEST/VA
45	TEST/VA
46	TEST/VA
47	TEST/VA
48	TEST/VA
49	TEST/VA
50	TEST/VA
51	TEST/VA
52	TEST/VA
53	TEST/VA
54	TEST/VA
55	TEST/VA
56	TEST/VA
57	TEST/VA
58	TEST/VA
59	TEST/VA
60	TEST/VA
61	TEST/VA
62	TEST/VA
63	TEST/VA
64	TEST/VA
65	TEST/VA
66	TEST/VA
67	TEST/VA
68	TEST/VA
69	TEST/VA
70	TEST/VA
71	TEST/VA
72	TEST/VA
73	TEST/VA
74	TEST/VA
75	TEST/VA
76	TEST/VA
77	TEST/VA
78	TEST/VA
79	TEST/VA
80	TEST/VA
81	TEST/VA
82	TEST/VA
83	TEST/VA
84	TEST/VA
85	TEST/VA
86	TEST/VA
87	TEST/VA
88	TEST/VA
89	TEST/VA
90	TEST/VA
91	TEST/VA
92	TEST/VA
93	TEST/VA
94	TEST/VA
95	TEST/VA
96	TEST/VA
97	TEST/VA
98	TEST/VA
99	TEST/VA
100	TEST/VA

521-9364 1-18 W944 D



RESISTIVE LOADS RATED FOR 380VAC
INDUCTIVE LOADS RATED FOR 0.5/0.8/250VAC COS-φ= .4

OPTIONAL DID MODULE




OPTIONAL RTD MODULE

DC SCHEMATIC - SHEET 3 OF 18
EMCP 4.2B-DIESEL
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

TEST DATA - PROP	1
TEST DATA - AUTOCAD	2
TEST DATA - BRAND MARKINGS	3
TEST DATA - CONFIDENTIALITY	4
TEST DATA - INTERPRETATION	5
TEST DATA - INTRP & TOI	6
TEST DATA - MISC	7
TEST DATA - ARJIN GOPAL	8
TEST DATA - LYLE SEWELL	9
TEST DATA - J.D. ELDER	10
TEST DATA - RECORDS	11
TEST DATA - UNLESS OTHERWISE SPECIFIED	12
TEST DATA - DIMENSIONS ARE IN MILLIMETERS	13
TEST DATA - TOLERANCES ARE AS SHOWN	14
TEST DATA - UNLESS OTHERWISE SPECIFIED	15
TEST DATA - SHEET 45 OF 118	16
TEST DATA - DATE	17
TEST DATA - 01.2.AUG.19	18
TEST DATA - 001.1.JUL.18	19
TEST DATA - 001.1.JUL.18	20
TEST DATA - 001.1.JUL.18	21
TEST DATA - 001.1.JUL.18	22
TEST DATA - 001.1.JUL.18	23
TEST DATA - 001.1.JUL.18	24
TEST DATA - 001.1.JUL.18	25
TEST DATA - 001.1.JUL.18	26
TEST DATA - 001.1.JUL.18	27
TEST DATA - 001.1.JUL.18	28
TEST DATA - 001.1.JUL.18	29
TEST DATA - 001.1.JUL.18	30
TEST DATA - 001.1.JUL.18	31
TEST DATA - 001.1.JUL.18	32
TEST DATA - 001.1.JUL.18	33
TEST DATA - 001.1.JUL.18	34
TEST DATA - 001.1.JUL.18	35
TEST DATA - 001.1.JUL.18	36
TEST DATA - 001.1.JUL.18	37
TEST DATA - 001.1.JUL.18	38
TEST DATA - 001.1.JUL.18	39
TEST DATA - 001.1.JUL.18	40
TEST DATA - 001.1.JUL.18	41
TEST DATA - 001.1.JUL.18	42
TEST DATA - 001.1.JUL.18	43
TEST DATA - 001.1.JUL.18	44
TEST DATA - 001.1.JUL.18	45
TEST DATA - 001.1.JUL.18	46
TEST DATA - 001.1.JUL.18	47
TEST DATA - 001.1.JUL.18	48
TEST DATA - 001.1.JUL.18	49
TEST DATA - 001.1.JUL.18	50
TEST DATA - 001.1.JUL.18	51
TEST DATA - 001.1.JUL.18	52
TEST DATA - 001.1.JUL.18	53
TEST DATA - 001.1.JUL.18	54
TEST DATA - 001.1.JUL.18	55
TEST DATA - 001.1.JUL.18	56
TEST DATA - 001.1.JUL.18	57
TEST DATA - 001.1.JUL.18	58
TEST DATA - 001.1.JUL.18	59
TEST DATA - 001.1.JUL.18	60
TEST DATA - 001.1.JUL.18	61
TEST DATA - 001.1.JUL.18	62
TEST DATA - 001.1.JUL.18	63
TEST DATA - 001.1.JUL.18	64
TEST DATA - 001.1.JUL.18	65
TEST DATA - 001.1.JUL.18	66
TEST DATA - 001.1.JUL.18	67
TEST DATA - 001.1.JUL.18	68
TEST DATA - 001.1.JUL.18	69
TEST DATA - 001.1.JUL.18	70
TEST DATA - 001.1.JUL.18	71
TEST DATA - 001.1.JUL.18	72
TEST DATA - 001.1.JUL.18	73
TEST DATA - 001.1.JUL.18	74
TEST DATA - 001.1.JUL.18	75
TEST DATA - 001.1.JUL.18	76
TEST DATA - 001.1.JUL.18	77
TEST DATA - 001.1.JUL.18	78
TEST DATA - 001.1.JUL.18	79
TEST DATA - 001.1.JUL.18	80
TEST DATA - 001.1.JUL.18	81
TEST DATA - 001.1.JUL.18	82
TEST DATA - 001.1.JUL.18	83
TEST DATA - 001.1.JUL.18	84
TEST DATA - 001.1.JUL.18	85
TEST DATA - 001.1.JUL.18	86
TEST DATA - 001.1.JUL.18	87
TEST DATA - 001.1.JUL.18	88
TEST DATA - 001.1.JUL.18	89
TEST DATA - 001.1.JUL.18	90
TEST DATA - 001.1.JUL.18	91
TEST DATA - 001.1.JUL.18	92
TEST DATA - 001.1.JUL.18	93
TEST DATA - 001.1.JUL.18	94
TEST DATA - 001.1.JUL.18	95
TEST DATA - 001.1.JUL.18	96
TEST DATA - 001.1.JUL.18	97
TEST DATA - 001.1.JUL.18	98
TEST DATA - 001.1.JUL.18	99
TEST DATA - 001.1.JUL.18	100

CATERPILLAR INC.

521-9364 - 18 - W944.0



ANALOG INPUTS

The EMCP 4.1 and 4.2 support three 2-wire (plus shield) Analog inputs. None of these inputs are dedicated to specific functions. These are individually selectable as either Voltage or Resistive Sender inputs for interface to senders, customer signals, etc. The modes of operation are described below:

- Voltage mode: 0-5 Volts with software-selectable sub-ranges
- The input impedance is a minimum of 10k Ohms and a maximum of 1M Ohms. The Analog Input return signals must be tied to battery negative external to the controller.

Voltage Sender Ranges

- 0 to 5V
- 1 to 5V
- 0.5 to 4.5V

Any Analog Input can be configured for any one of the Data Identification parameters shown below:

- Engine Oil Press
- Eng Coolant Temp
- Data Link 3 SCADA (EMCP 4.2 only)
- Air/Fuel Ratio
- Engine Speed Control
- Engine Fuel Level
- Generator Voltage Control
- Ext Tank Fuel Level
- Custom Parameters

DIGITAL INPUTS

The EMCP 4.1 and 4.2 have six user-programmable Digital Inputs. The user programmable digital inputs are referred to as Data Inputs. A change in state of a Digital Input is shown on the display that are labeled 'A' and 'B' are reserved for E-Stop and Remote Start.

The Usage Type of COMMAND/STATUS is used to make certain system conditions known by the EMCP 4; an example of a Command/Status parameter is:

- Relay Speed
- Relay Voltage
- Lower Voltage

Remote voltage adjustment toggle switches may be used to fine tune the generator output voltage by programming an EMCP Digital Input for Relay Voltage and Lower Voltage. Each activation of the digital input raises or lowers the voltage by 0.2% of rated voltage. The voltage change is temporary; the voltage bias is raised or lowered by 0.2% of rated approximately every 400ms.

Using an available analog input, configure in ET, (A1H, A2, or A3) or display (H3) an analog input for Desired Engine Speed Command. Program the Analog Input Signal Range for 0 to 5V. The physical range is then mapped to a change in speed using the Minimum Data Range and Maximum Data Range. Keep in mind this value is 2 bas, so if you desire to change the speed from 710 rpm to 1890 rpm, values of -90 for Minimum Data Range and +90 for Maximum Data Range would be used. (based on 1800 RPM = Rated)

Voltage adjustments are categorized into 2 types: Manual biasing and Analog biasing. Manual voltage adjustment includes fine tuning the generator output voltage via digital input. EMCP display or SCADA (Webbus). Analog voltage adjustment is performed via programmable analog inputs to the EMCP and provide a voltage bias to an external control systems (such as switchgear). It is important to note that the Manual Bias Percentage must be correctly configured to be greater than the expected bias range, otherwise it may not be recognized by the generator. The generator Gen Maximum Voltage Bias Percentage is accessed within the CAT ET Service Tool configuration menu under Generator AC Monitor, or can be accessed from the EMCP display by navigating to the following sub-menu:

Note: All manual voltage biasing is removed and reset to zero when the engine is stopped. Manual voltage bias levels are not carried over to the next start up after an engine shutdown.

Analog voltage adjustment is done via a programmable analog input to the EMCP configured for Generator Voltage Control. Analog inputs provide a voltage control interface for external potentiometers or external control systems (such as switchgear). The Generator Voltage Control analog input signal is interpreted and converted by the EMCP into a voltage bias percentage of (nominal) rated voltage. For example, consider an analog input configured for a signal range of 0 to +5V, and a data range of -10% to 10%. When this analog input signal value equals +3V, a voltage bias percentage of +2.0 % of rated will be applied to the generator output voltage.

TEST ITEM	PROB	DATE
1	23 AUG 19	01
2	00	11 JUL 18
3	00	11 JUL 18
4	00	11 JUL 18
5	00	11 JUL 18
6	00	11 JUL 18
7	00	11 JUL 18
8	00	11 JUL 18
9	00	11 JUL 18
10	00	11 JUL 18
11	00	11 JUL 18
12	00	11 JUL 18
13	00	11 JUL 18
14	00	11 JUL 18
15	00	11 JUL 18
16	00	11 JUL 18
17	00	11 JUL 18
18	00	11 JUL 18
19	00	11 JUL 18
20	00	11 JUL 18
21	00	11 JUL 18
22	00	11 JUL 18
23	00	11 JUL 18
24	00	11 JUL 18
25	00	11 JUL 18
26	00	11 JUL 18
27	00	11 JUL 18
28	00	11 JUL 18
29	00	11 JUL 18
30	00	11 JUL 18
31	00	11 JUL 18
32	00	11 JUL 18
33	00	11 JUL 18
34	00	11 JUL 18
35	00	11 JUL 18
36	00	11 JUL 18
37	00	11 JUL 18
38	00	11 JUL 18
39	00	11 JUL 18
40	00	11 JUL 18
41	00	11 JUL 18
42	00	11 JUL 18
43	00	11 JUL 18
44	00	11 JUL 18
45	00	11 JUL 18
46	00	11 JUL 18
47	00	11 JUL 18
48	00	11 JUL 18
49	00	11 JUL 18
50	00	11 JUL 18
51	00	11 JUL 18
52	00	11 JUL 18
53	00	11 JUL 18
54	00	11 JUL 18
55	00	11 JUL 18
56	00	11 JUL 18
57	00	11 JUL 18
58	00	11 JUL 18
59	00	11 JUL 18
60	00	11 JUL 18
61	00	11 JUL 18
62	00	11 JUL 18
63	00	11 JUL 18
64	00	11 JUL 18
65	00	11 JUL 18
66	00	11 JUL 18
67	00	11 JUL 18
68	00	11 JUL 18
69	00	11 JUL 18
70	00	11 JUL 18
71	00	11 JUL 18
72	00	11 JUL 18
73	00	11 JUL 18
74	00	11 JUL 18
75	00	11 JUL 18
76	00	11 JUL 18
77	00	11 JUL 18
78	00	11 JUL 18
79	00	11 JUL 18
80	00	11 JUL 18
81	00	11 JUL 18
82	00	11 JUL 18
83	00	11 JUL 18
84	00	11 JUL 18
85	00	11 JUL 18
86	00	11 JUL 18
87	00	11 JUL 18
88	00	11 JUL 18
89	00	11 JUL 18
90	00	11 JUL 18
91	00	11 JUL 18
92	00	11 JUL 18
93	00	11 JUL 18
94	00	11 JUL 18
95	00	11 JUL 18
96	00	11 JUL 18
97	00	11 JUL 18
98	00	11 JUL 18
99	00	11 JUL 18
100	00	11 JUL 18

SPEED AND VOLTAGE CONTROL
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

40 PIN RECEPTACLE

DESCRIPTION	PIN	WIRE # COLOR AND
NOT USED	1	NOT USED
NOT USED	2	NOT USED
NOT USED	3	NOT USED
BATTERY +	4	115 C16 AWC-200
BATTERY -	5	116 C16 AWC-200
KEY SWITCH	6	117 C16 AWC-200
NOT USED	7	NOT USED
NOT USED	8	NOT USED
NOT USED	9	NOT USED
NOT USED	10	NOT USED
NOT USED	11	NOT USED
NOT USED	12	NOT USED
NOT USED	13	NOT USED
CAT DATA LINK +	14	893 C16 AWC-200
CAT DATA LINK -	15	892 C16 AWC-200
DIGITAL RETURN	16	779 C16 AWC-200
EMERGENCY STOP	17	775 C16 AWC-200
NOT USED	18	NOT USED
NOT USED	19	NOT USED
NOT USED	20	NOT USED
NOT USED	21	770 C16 AWC-200
NOT USED	22	NOT USED
NOT USED	23	NOT USED
NOT USED	24	771 C16 AWC-200
NOT USED	25	NOT USED
NOT USED	26	NOT USED
NOT USED	27	NOT USED
NOT USED	28	NOT USED
NOT USED	29	NOT USED
NOT USED	30	NOT USED
LOW FUEL SW - NOT USED	31	1472 C16 AWC-200
EMERGENCY STOP	32	254 C16 AWC-200
DIGITAL RETURN	33	257 C16 AWC-200
DIGITAL SWITCH 5	34	258 C16 AWC-200
DIGITAL SWITCH 6	35	259 C16 AWC-200
CALL SH	36	1708 C24 375-2200
BATTERY +	37	2294 C16 AWC-200
BATTERY -	38	2295 C16 AWC-200
BATTERY +	39	2296 C16 AWC-200
BATTERY -	40	2297 C16 AWC-200

40 PIN PLUG



DESCRIPTION	PIN	WIRE # COLOR AND
NOT USED	1	NOT USED
NOT USED	2	NOT USED
NOT USED	3	NOT USED
115 C16 AWC-200	4	115 C16 AWC-200
116 C16 AWC-200	5	116 C16 AWC-200
117 C16 AWC-200	6	117 C16 AWC-200
NOT USED	7	NOT USED
NOT USED	8	NOT USED
NOT USED	9	NOT USED
NOT USED	10	NOT USED
NOT USED	11	NOT USED
NOT USED	12	NOT USED
NOT USED	13	NOT USED
893 C16 AWC-200	14	893 C16 AWC-200
892 C16 AWC-200	15	892 C16 AWC-200
779 C16 AWC-200	16	779 C16 AWC-200
775 C16 AWC-200	17	775 C16 AWC-200
NOT USED	18	NOT USED
NOT USED	19	NOT USED
NOT USED	20	NOT USED
770 C16 AWC-200	21	770 C16 AWC-200
NOT USED	22	NOT USED
NOT USED	23	NOT USED
771 C16 AWC-200	24	771 C16 AWC-200
NOT USED	25	NOT USED
NOT USED	26	NOT USED
NOT USED	27	NOT USED
NOT USED	28	NOT USED
NOT USED	29	NOT USED
NOT USED	30	NOT USED
LOW FUEL SW - NOT USED	31	1472 C16 AWC-200
EMERGENCY STOP	32	254 C16 AWC-200
DIGITAL RETURN	33	257 C16 AWC-200
DIGITAL SWITCH 5	34	258 C16 AWC-200
DIGITAL SWITCH 6	35	259 C16 AWC-200
CALL SH	36	1708 C24 375-2200
BATTERY +	37	2294 C16 AWC-200
BATTERY -	38	2295 C16 AWC-200
BATTERY +	39	2296 C16 AWC-200
BATTERY -	40	2297 C16 AWC-200

CONNECT TO ENGINE FOR 3500 EUI

OR ENGINE INTERFACE EXTENSION FOR 3516T41,3516E

CONNECT TO MODULAR CONTROL PANEL

CONNECT TO MODULAR CONTROL PANEL



1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

1	15167A INT-PROP
2	15735 DRAWING - AUTOCAD
3	150198W BRAND MARKINGS
4	1500130 CONFIDENTIALITY
5	150012A INTERPRETATION
6	150011 INTPR & TOL
7	DATE
8	BY
9	CHKD
10	APP'D
11	DATE
12	BY
13	CHKD
14	APP'D
15	DATE
16	BY
17	CHKD
18	APP'D
19	DATE
20	BY
21	CHKD
22	APP'D
23	DATE
24	BY
25	CHKD
26	APP'D
27	DATE
28	BY
29	CHKD
30	APP'D
31	DATE
32	BY
33	CHKD
34	APP'D
35	DATE
36	BY
37	CHKD
38	APP'D
39	DATE
40	BY

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

ENGINE INTERFACE HARNESS SHEET 1 OF 17
ON PACKAGE CONTROLS-3500 EUI
FOR NOTES SEE SHEET 4
CATERPILLAR: CONFIDENTIAL GREEN

RENOWN HEALTH REGIONAL CENTRAL UTILITY PLANT
DIESEL STANDBY GENERATOR SET SUBMITTAL

TAB 3: CAT 3516C DIESEL STANDBY GENERATOR SET PRODUCT DATASHEETS/CUTSHEETS

- 3.1 CAT 3516C DIESEL STANDBY GENERATOR SET
 - 3.1.1 1822 FRAME GENERATOR TECHNICAL DATA
- 3.2 AUXILIARY EQUIPMENT
 - 3.2.1 EMCP 4.2B GENERATOR SET CONTROLLER
 - 3.2.2 LOCAL ANNUNCIATOR MODULE
 - 3.2.3 REMOTE ANNUNCIATOR MODULE
 - 3.2.4 DIO MODULE
 - 3.2.5 CAT ENGINE STARTING BATTERIES
 - 3.2.6 BATTERY CHARGER
 - 3.2.7 JACKET WATER HEATER
- 3.3 IBC SEISMIC CERTIFICATE

PRODUCT DATASHEETS AND CUTSHEETS
CAT 3516C DIESEL STANDBY GENERATOR SET

Cat® 3516C

Diesel Generator Sets



Image shown may not reflect actual configuration

Bore – mm (in)	170 (6.69)
Stroke – mm (in)	190 (7.48)
Displacement – L (in ³)	69 (4210.64)
Compression Ratio	14.7:1
Aspiration	TA
Fuel System	EUI
Governor Type	ADEM™ A3

Standby 60 Hz ekW (kVA)	Mission Critical 60 Hz ekW (kVA)	Prime 60 Hz ekW (kVA)	Continuous 60 Hz ekW (kVA)	Emissions Performance
2000 (2500)	2000 (2500)	1825 (2281)	1650 (2063)	U.S. EPA Stationary Emergency Use Only (Tier 2)

Features

Cat® Diesel Engine

- Meets U.S. EPA Stationary Emergency Use Only (Tier 2) emission standards
- Reliable performance proven in thousands of applications worldwide

Generator Set Package

- Accepts 100% block load in one step and meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

Alternators

- Superior motor starting capability minimizes need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

Cooling System

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- Tested to ensure proper generator set cooling

EMCP 4 Control Panels

- User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements

Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

Worldwide Product Support

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region

Standard and Optional Equipment

Engine

Air Cleaner

- Single element
- Dual element

Muffler

- Critical Grade Silencer (ships loose)

Starting

- Standard batteries
- Oversized batteries
- Standard electric starter(s)
- Heavy duty electric starter(s)
- Dual electric starter(s)
- Air starter(s)
- Jacket water heater

Alternator

Output voltage

- 380V 6300V
- 440V 6600V
- 480V 6900V
- 600V 12470V
- 2400V 13200V
- 4160V 13800V

Temperature Rise (over 40°C ambient)

- 150°C
- 125°C/130°C
- 105°C
- 80°C

Winding type

- Random wound
- Form wound

Excitation

- Internal excitation (IE)
- Permanent magnet (PM)

Attachments

- Anti-condensation heater
- Stator and bearing temperature monitoring and protection

Power Termination

Type

- Bus bar
- Circuit breaker

Differential CTs provided. Switchgear supplier to coordinate differential CTs on the switchgear side of the generator feeders to coordinate stator differential (87G) protections.

- LSIG-P

Control System

Controller

- EMCP 4.2B
- EMCP 4.3
- EMCP 4.4

Attachments

- Local annunciator module
- Remote annunciator module
- Expansion I/O module
- Remote monitoring software

Charging

- Battery charger – 10A
- Battery charger – 20A
- Battery charger – 35A

Vibration Isolators

- Rubber
- Spring
- Seismic rated

Cat Connect

Connectivity

- Ethernet
- Cellular

Extended Service Options

Terms

- 2 year (prime)
- 3 year
- 5 year
- 10 year

Coverage

- Silver
- Gold
- Platinum
- Platinum Plus

Ancillary Equipment

- Automatic transfer switch (ATS)
- Paralleling switchgear
- Paralleling controls

Certifications

- UL 2200 Listed
- CSA
- IBC seismic certification
- OSHPD pre-approval


Note: Some options may not be available on all models. Certifications may not be available with all model configurations. Consult factory for availability.

Package Performance

Performance	Standby	Mission Critical	Prime	Continuous
Frequency	60 Hz	60 Hz	60 Hz	60 Hz
Gen set power rating with fan	2000 ekW	2000 ekW	1825 ekW	1650 ekW
Gen set power rating with fan @ 0.8 power factor	2500 kVA	2500 kVA	2281 kVA	2063 kVA
Emissions	EPA ESE (TIER 2)			
Performance number	EM1896-03	EM1897-03	DM8264-06	DM8265-05
Fuel Consumption				
100% load with fan – L/hr (gal/hr)	505.8 (133.6)	505.8 (133.6)	465.6 (123.0)	427.9 (113.0)
75% load with fan – L/hr (gal/hr)	393.9 (104.1)	393.9 (104.1)	366.7 (96.9)	338.3 (89.4)
50% load with fan – L/hr (gal/hr)	284.2 (75.1)	284.2 (75.1)	261.3 (69.0)	238.3 (63.0)
25% load with fan – L/hr (gal/hr)	164.3 (43.4)	164.3 (43.4)	154.2 (40.7)	144.1 (38.1)
Cooling System				
Radiator air flow restriction (system) – kPa (in. water)	0.12 (0.48)	0.12 (0.48)	0.12 (0.48)	0.12 (0.48)
Radiator air flow – m ³ /min (cfm)	2204 (77834)	2204 (77834)	2204 (77834)	2204 (77834)
Engine coolant capacity – L (gal)	233.2 (61.6)	233.2 (61.6)	233.2 (61.6)	233.2 (61.6)
Radiator coolant capacity – L (gal)	180.0 (47.6)	180.0 (47.6)	180.0 (47.6)	180.0 (47.6)
Total coolant capacity – L (gal)	413.2 (109.2)	413.2 (109.2)	413.2 (109.2)	413.2 (109.2)
Inlet Air				
Combustion air inlet flow rate – m ³ /min (cfm)	185.5 (6548.9)	185.5 (6548.9)	180.0 (6357.6)	174.3 (6155.8)
Exhaust System				
Exhaust stack gas temperature – °C (°F)	400.1 (752.1)	400.1 (752.1)	382.8 (721.1)	370.7 (699.3)
Exhaust gas flow rate – m ³ /min (cfm)	433.1 (15292.8)	433.1 (15292.8)	408.1 (14410.4)	385.3 (13605.7)
Exhaust system backpressure (maximum allowable) – kPa (in. water)	6.7 (27.0)	6.7 (27.0)	6.7 (27.0)	6.7 (27.0)
Heat Rejection				
Heat rejection to jacket water – kW (Btu/min)	759 (43150)	759 (43150)	715 (40666)	673 (38277)
Heat rejection to exhaust (total) – kW (Btu/min)	1788 (101696)	1788 (101696)	1645 (93554)	1522 (86577)
Heat rejection to aftercooler – kW (Btu/min)	672 (38240)	672 (38240)	612 (34784)	553 (31421)
Heat rejection to atmosphere from engine – kW (Btu/min)	133 (7564)	133 (7564)	127 (7230)	123 (6983)
Heat rejection from alternator – kW (Btu/min)	96 (5464)	96 (5464)	86 (4895)	76 (4326)
Emissions* (Nominal)				
NOx mg/Nm ³ (g/hp-h)	2754.3 (5.46)	2754.3 (5.46)	2488.9 (5.05)	2202.3 (4.37)
CO mg/Nm ³ (g/hp-h)	143.3 (0.30)	143.3 (0.30)	129.7 (0.27)	112.3 (0.24)
HC mg/Nm ³ (g/hp-h)	44.7 (0.11)	44.7 (0.11)	55.6 (0.13)	67.4 (0.16)
PM mg/Nm ³ (g/hp-h)	10.4 (0.03)	10.4 (0.03)	10.9 (0.03)	12.0 (0.03)
Emissions* (Potential Site Variation)				
NOx mg/Nm ³ (g/hp-h)	3305.2 (6.56)	3305.2 (6.56)	2986.6 (6.06)	2642.7 (5.24)
CO mg/Nm ³ (g/hp-h)	258.0 (0.54)	258.0 (0.54)	233.4 (0.49)	202.1 (0.43)
HC mg/Nm ³ (g/hp-h)	59.5 (0.14)	59.5 (0.14)	73.9 (0.18)	89.6 (0.22)
PM mg/Nm ³ (g/hp-h)	14.6 (0.04)	14.6 (0.04)	15.3 (0.04)	16.8 (0.04)

*mg/Nm³ levels are corrected to 5% O₂. Contact your local Cat dealer for further information.

Weights and Dimensions



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)
6542 (257.6)	2339 (92.1)	2997 (118.0)	16 275 (35,880)

Note: For reference only. Do not use for installation design. Contact your local Cat dealer for precise weights and dimensions.

Ratings Definitions

Standby

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby rated ekW. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Mission Critical

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 85% of the mission critical rated ekW. Typical peak demand up to 100% of rated ekW for up to 5% of the operating time. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Prime

Output available with varying load for an unlimited time. Average power output is 70% of the prime rated ekW. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year.

Continuous

Output available with non-varying load for an unlimited time. Average power output is 70-100% of the continuous rated ekW. Typical peak demand is 100% of continuous rated ekW for 100% of the operating hours.

Applicable Codes and Standards

AS 1359, CSA C22.2 No. 100-04, UL 142, UL 489, UL 869, UL 2200, IBC, IEC 60034-1, ISO 3046, ISO 8528, NEMA MG1-22, NEMA MG1-33, 2014/35/EU, 2006/42/EC, 2014/30/EU and facilitates compliance to NFPA 37, NFPA 70, NFPA 99, NFPA 110.

Note: Codes may not be available in all model configurations. Please consult your local Cat dealer for availability.

Data Center Applications

- All ratings Tier III/Tier IV compliant per Uptime Institute requirements.
- All ratings ANSI/TIA-942 compliant for Rated-1 through Rated-4 data centers.

Fuel Rates

Fuel consumption reported in accordance with ISO 3046-1, based on fuel oil of 35° API [16°C (60°F)] gravity having an LHV of 42,780 kJ/kg (18,390 Btu/lb) when used at 15°C (59°F) and weighing 850 g/liter (7.0936 lbs/U.S. gal.) All fuel consumption values refer to rated engine power.

www.cat.com/electricpower

©2021 Caterpillar

All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

CAT, CATERPILLAR, LET'S DO THE WORK, their respective logos, "Caterpillar Corporate Yellow", the "Power Edge" and Cat "Modern Hex" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

PRODUCT DATASHEETS AND CUTSHEETS
1822 GENERATOR FRAME TECHNICAL DATA

GENERATOR DATA

(AT400240)-ENGINE (BAA126422A)-CEM

NOVEMBER 03, 2021

For Help Desk Phone Numbers [Click here](#)

Selected Model

Engine: 3516 Generator Frame: 1822 Genset Rating (kW): 2000.0 Line Voltage: 4160
 Fuel: Diesel Generator Arrangement: 3723048 Genset Rating (kVA): 2500.0 Phase Voltage: 2402
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 347.0
 Duty: STANDBY Connection: SERIES STAR Application: EPG Status: Current

Version:
41205 /40749 /40680 /9270

Spec Information

Generator Specification				Generator Efficiency		
Frame: 1822	Type: SR5	No. of Bearings: 2		Per Unit Load	kW	Efficiency %
Winding Type: FORM WOUND	Flywheel: 21.0			0.25	500.0	92.0
Connection: SERIES STAR	Housing: 00			0.5	1000.0	94.9
Phases: 3	No. of Leads: 6			0.75	1500.0	95.8
Poles: 4	Wires per Lead: 1			1.0	2000.0	95.9
Sync Speed: 1800	Generator Pitch: 0.6667					

Reactances	Per Unit	Ohms
SUBTRANSIENT - DIRECT AXIS X _d	0.1264	0.8753
SUBTRANSIENT - QUADRATURE AXIS X _q	0.1186	0.8213
TRANSIENT - SATURATED X _d	0.1914	1.3248
SYNCHRONOUS - DIRECT AXIS X _d	3.0222	20.9204
SYNCHRONOUS - QUADRATURE AXIS X _q	1.3374	9.2580
NEGATIVE SEQUENCE X ₂	0.1225	0.8480
ZERO SEQUENCE X ₀	0.0100	0.0691

Time Constants	Seconds
OPEN CIRCUIT TRANSIENT - DIRECT AXIS T' _{do}	5.0860
SHORT CIRCUIT TRANSIENT - DIRECT AXIS T' _d	0.3221
OPEN CIRCUIT SUBTRANSIENT - DIRECT AXIS T'' _{do}	0.0075
SHORT CIRCUIT SUBTRANSIENT - DIRECT AXIS T'' _d	0.0065
OPEN CIRCUIT SUBTRANSIENT - QUADRATURE AXIS T'' _{q0}	0.0066
SHORT CIRCUIT SUBTRANSIENT - QUADRATURE AXIS T'' _q	0.0057
EXCITER TIME CONSTANT T _e	0.2580
ARMATURE SHORT CIRCUIT T _a	0.0454

Short Circuit Ratio: 0.43 Stator Resistance = 0.0787 Ohms Field Resistance = 0.8963 Ohms

Voltage Regulation		Generator Excitation		
Voltage level adjustment: +/-	5.0%	No Load	Full Load, (rated) pf	
Voltage regulation, steady state: +/-	0.5%		Series	Parallel
Voltage regulation with 3% speed change: +/-	0.5%	Excitation voltage:	9.82 Volts	47.0 Volts Volts
Waveform deviation line - line, no load: less than	3.0%	Excitation current	0.9 Amps	3.56 Amps Amps
Telephone influence factor: less than	50			

Selected Model

Engine: 3516 **Generator Frame:** 1822 **Genset Rating (kW):** 2000.0 **Line Voltage:** 4160
Fuel: Diesel **Generator Arrangement:** 3723048 **Genset Rating (kVA):** 2500.0 **Phase Voltage:** 2402
Frequency: 60 **Excitation Type:** Permanent Magnet **Pwr. Factor:** 0.8 **Rated Current:** 347.0
Duty: STANDBY **Connection:** SERIES STAR **Application:** EPG **Status:** Current

Version:
 41205 /40749 /40680 /9270

Generator Mechanical Information

Center of Gravity		
Dimension X	-1071.9 mm	-42.2 IN.
Dimension Y	0.0 mm	0.0 IN.
Dimension Z	0.0 mm	0.0 IN.

- "X" is measured from driven end of generator and parallel to rotor. Towards engine fan is positive. See General Information for details
- "Y" is measured vertically from rotor center line. Up is positive.
- "Z" is measured to left and right of rotor center line. To the right is positive.

Generator WT = 4905 kg	* Rotor WT = 1778 kg	* Stator WT = 2411 kg
10,814 LB	3,920 LB	5,315 LB

Rotor Balance = 0.0508 mm deflection PTP
 Overspeed Capacity = 125% of synchronous speed

Generator Torsional Data

J1 = Coupling and Fan **J2 = Rotor** **J3 = Exciter End**
TOTAL J = J1 + J2 + J3

K1 = Shaft Stiffness between J1 + J2 (Diameter 1)			K2 = Shaft Stiffness between J2 + J3 (Diameter 2)			
J1	K1	Min Shaft Dia 1	J2	K2	Min Shaft Dia 2	J3
30.1 LB IN. s ²	62.0 MLB IN./rad	5.0 IN.	547.2 LB IN. s ²	57.3 MLB IN./rad	3.8 IN.	3.8 LB IN. s ²
3.397 N m s ²	7.0 MN m/rad	127.0 mm	61.82 N m s ²	6.47 MN m/rad	96.5 mm	0.43 N m s ²
			Total J			
			581.0 LB IN. s ²			
			65.647 N m s ²			

Selected Model

Engine: 3516 **Generator Frame:** 1822 **Genset Rating (kW):** 2000.0 **Line Voltage:** 4160
Fuel: Diesel **Generator Arrangement:** 3723048 **Genset Rating (kVA):** 2500.0 **Phase Voltage:** 2402
Frequency: 60 **Excitation Type:** Permanent Magnet **Pwr. Factor:** 0.8 **Rated Current:** 347.0
Duty: STANDBY **Connection:** SERIES STAR **Application:** EPG **Status:** Current

Version:
 41205 /40749 /40680 /9270

Generator Cooling Requirements - Temperature - Insulation Data			
Cooling Requirements:		Temperature Data: (Ambient 40 °C)	
Heat Dissipated: 85.5 kW		Stator Rise:	105.0 °C
Air Flow: 199.2 m ³ /min		Rotor Rise:	105.0 °C
Insulation Class: H			
Insulation Reg. as shipped: 100.0 MΩ minimum at 40 °C			
Thermal Limits of Generator			
Frequency:	60 Hz		
Line to Line Voltage:	4160 Volts		
B BR 80/40	2250.0 kVA		
F BR -105/40	2563.0 kVA		
H BR - 125/40	2813.0 kVA		
F PR - 130/40	2813.0 kVA		
H PR - 150/40	3125.0 kVA		


Selected Model

Engine: 3516 **Generator Frame:** 1822 **Genset Rating (kW):** 2000.0 **Line Voltage:** 4160
Fuel: Diesel **Generator Arrangement:** 3723048 **Genset Rating (kVA):** 2500.0 **Phase Voltage:** 2402
Frequency: 60 **Excitation Type:** Permanent Magnet **Pwr. Factor:** 0.8 **Rated Current:** 347.0
Duty: STANDBY **Connection:** SERIES STAR **Application:** EPG **Status:** Current

Version:
 41205 /40749 /40680 /9270

**Starting Capability & Current Decrement
Motor Starting Capability (0.4 pf)**


SKVA	Percent Volt Dip
349	2.5
716	5.0
1,104	7.5
1,512	10.0
1,944	12.5
2,402	15.0
2,887	17.5
3,403	20.0
3,952	22.5
4,537	25.0
5,163	27.5
5,833	30.0
6,553	32.5
7,329	35.0
8,167	37.5
9,074	40.0



Current Decrement Data

E Time Cycle	AMP
0.0	2,720
1.0	1,801
2.0	1,655
3.0	1,574
4.0	1,502
5.0	1,434
7.5	1,278
10.0	1,141
12.5	1,021
15.0	915
20.0	754
25.0	804
30.0	885
35.0	960
40.0	1,026
45.0	1,084

Current Decrement



Instantaneous 3 Phase Fault Current: 2720 Amps Instantaneous Line - Line Fault Current: 2393 Amps
Instantaneous Line - Neutral Fault Current: 3985 Amps

Selected Model


Engine: 3516 Generator Frame: 1822 Genset Rating (kW): 2000.0 Line Voltage: 4160
Fuel: Diesel Generator Arrangement: 3723048 Genset Rating (kVA): 2500.0 Phase Voltage: 2402
Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 347.0
Duty: STANDBY Connection: SERIES STAR Application: EPG Status: Current

Version:
41205 /40749 /40680 /9270

Generator Output Characteristic Curves
Open Circuit Curve

Open Circuit


Field Current	Line - Line Volt
0.0	0
12.7	2,496
15.0	2,912
17.6	3,328
21.1	3,744
26.5	4,160
36.6	4,576
58.3	4,992
108.1	5,408
226.1	5,824



Short Circuit Curve

Short Circuit

Field Current	Armature Current
0.0	0
36.4	208
42.5	243
48.5	278
54.6	312
60.7	347
66.7	382
72.8	416
78.9	451
85.0	486



Selected Model


Engine: 3516 **Generator Frame:** 1822 **Genset Rating (kW):** 2000.0 **Line Voltage:** 4160
Fuel: Diesel **Generator Arrangement:** 3723048 **Genset Rating (kVA):** 2500.0 **Phase Voltage:** 2402
Frequency: 60 **Excitation Type:** Permanent Magnet **Pwr. Factor:** 0.8 **Rated Current:** 347.0
Duty: STANDBY **Connection:** SERIES STAR **Application:** EPG **Status:** Current

Version:
41205 /40749 /40680 /9270

**Generator Output Characteristic Curves
Zero Power Factor Curve**

Zero Power


Field Current	Line - Line Volt
60.7	0
75.6	2,080
78.4	2,496
82.1	2,912
88.1	3,328
99.6	3,744
124.5	4,160
182.2	4,576
319.7	4,992
651.2	5,408



Air Gap Curve

Air Gap

Field Current	Line - Line Volt
0.0	0
12.5	2,496
14.6	2,912
16.7	3,328
18.8	3,744
20.9	4,160
23.0	4,576
25.0	4,992
27.1	5,408
29.2	5,824




Selected Model

Engine: 3516 **Generator Frame:** 1822 **Genset Rating (kW):** 2000.0 **Line Voltage:** 4160
Fuel: Diesel **Generator Arrangement:** 3723048 **Genset Rating (kVA):** 2500.0 **Phase Voltage:** 2402
Frequency: 60 **Excitation Type:** Permanent Magnet **Pwr. Factor:** 0.8 **Rated Current:** 347.0
Duty: STANDBY **Connection:** SERIES STAR **Application:** EPG **Status:** Current

Version:
 41205 /40749 /40680 /9270

Reactive Capability Curve

Operating Chart



Selected Model

Engine: 3516	Generator Frame: 1822	Genset Rating (kW): 2000.0	Line Voltage: 4160
Fuel: Diesel	Generator Arrangement: 3723048	Genset Rating (kVA): 2500.0	Phase Voltage: 2402
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 347.0
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version: 41205 /40749 /40680 /9270

General Information

DM7825 Caterpillar SR5 Generators (50 Hz, 60 Hz)
Data for 1400, 1600, 1700, 1800 and 1900 frames Caterpillar SR5
generators built by Leroy Somer - USA and Leroy Somer France.

Refer to DM7821 for explanation of all generator data in Technical
Marketing Information (TMI) except generator efficiency for which the
explanation is given below.

GENERATOR EFFICIENCY

Generator efficiency is the percentage of engine flywheel (or other
prime mover) power that is converted into electrical output. The
generator efficiency shown is calculated by the summation of all
losses method, and is determined in accordance with the IEC Standard
60034. The efficiency considers only the generator. There is no
consideration of engine or parasitic losses here.

Refer to DM7829 for low and medium voltage protective setting values and
limits.

Caterpillar Confidential: **Green**

Content Owner: Commercial Processes Division


Web Master(s): [PSG Web Based Systems Support](#)

Current Date: 11/3/2021 2:29:22 PM

© Caterpillar Inc. 2021 All Rights Reserved.

[Data Privacy Statement](#).

PRODUCT DATASHEETS AND CUTSHEETS
AUXILIARY EQUIPMENT



Picture shown may not reflect actual configuration

Full range of attachments

- Wide range of system expansion attachments, designed specifically to work with the EMCP 4
- Flexible packaging options for easy and cost effective installation

World wide product support

- Cat dealers provide extensive pre and post sale support
- Cat dealers have over 1,600 dealer branch stores operating in 200 countries

Features

- A 33 x 132 pixel, 3.8 inch, white backlit graphical display denotes text alarm/event descriptions, set points, engine and generator monitoring, and is visible in all lighting conditions.
- Textual display with support for 26 languages
- Advanced engine monitoring is available on systems with an ADEM™ controller.
- Integration with the CDVR and IVR provides enhanced system performance
- Fully featured power metering, protective relaying, engine and generator parameter viewing, and expanded AC metering are all integrated into this controller.
- Real-time clock allows for date and time stamping of diagnostics and events in the control's logs as well as service maintenance reminders based on engine operating hours or calendar days. Up to 40 diagnostic events are stored in the non-volatile memory

EMCP 4.2B GENERATOR SET CONTROLLER

The Cat® EMCP 4.2B offers fully featured power metering, protective relaying and engine and generator control and monitoring. Engine and generator controls, diagnostics, and operating information are accessible via the control panel keypads; diagnostics from the EMCP 4 optional modules can be viewed and reset through the EMCP 4.2B.

Features

- Ability to view and reset diagnostics on EMCP 4 optional modules via the control panel removes the need for a separate service tool for troubleshooting
- Set points and software stored in non-volatile memory, preventing loss during a power outage
- Five levels of security allow for configurable operator privileges
- Programmable security levels for groups of setpoints.
- Programmable kW Relays (3)
- Programmable weekly exerciser timer
- Dealer configurable resistive maps
- Default overview screen
- Real (kW) Load histogram
- Auto mains failure
- Programmable logic functionality
- Selectable units
 - Temperature: °C or °F
 - Pressure: psi, kPa, bar
 - Fuel Consumption: Liter/hr or Gal/hr (U.S. or U.K.)

Standard Features

- Voltage (L-L, L-N)
- Current (Phase)
- Average Volt, Amp, Frequency
- kW, kVAr, kVA (Average, Phase, %)
- Power Factor (Average, Phase)
- kW-hr, kVAr-hr (total)
- Excitation voltage and current (with CDVR)
- Desired Voltage, Excitation Command, Operating Mode (with IVR)
- Generator stator and bearing temp (with optional module)
- kW load histogram

Generator Protection

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under frequency (81 O/U)
- Reverse Power (kW) (32)
- Reverse Reactive Power (kVAr) (32RV)
- Overcurrent (50/51)
- Thermal Damage Curve

Engine Monitoring

- Coolant temperature
- Oil pressure
- Engine speed (RPM)
- Battery voltage
- Run hours
- Crank attempt and successful start counter
- Enhanced engine monitoring (with electronic engines)

Engine Protection

- Control switch not in auto (alarm)
- High coolant temp (alarm and shutdown)
- Low coolant temp (alarm)
- Low coolant level (alarm)
- High engine oil temp (alarm and shutdown)
- Low, high, and weak battery voltage
- Overspeed
- Overcrank
- Low Oil Pressure

Control

- Run / Auto / Stop control
- Speed and voltage adjust
- Local and remote emergency stop
- Remote start/stop
- Cycle crank

Inputs & Outputs

- Two dedicated digital inputs
- Three analog inputs
- Six programmable digital inputs
- Eight relay out
- Two programmable digital outputs

Communications

- Primary and accessory CAN data links
- RS-485 annunciator data link
- Modbus RTU (RS-485 Half duplex)

Language Support

Arabic, Bulgarian, Czech, Chinese, Danish, Dutch, English, Estonian, Finnish, French, German, Greek, Hungarian, Italian, Icelandic, Japanese, Latvian, Lithuanian, Norwegian, Polish, Portuguese, Romanian, Russian, Spanish, Swedish, Turkish

Environmental

- Control module operating temperature: -40°C to 70°C
- Display operating temperature: -20°C to 70°C
- Humidity: 100% condensing 30°C to 60°C
- Storage temperature: -40°C to 85°C
- Vibration: Random profile, 24-1000 Hz, 4.3G rms

Standards

- UL Recognized
- CSA C22.2 No.100,14, 94
- Complies with all necessary standards for CE Certification
 - 98/37/EC Machinery Directive
 - BS EN 60204-1 Safety of Machinery
 - 89/336/EEC EMC Directive
 - BS EN 50081-1 Emissions Standard
 - BS EN 50082-2 Immunity Standard
 - 73/23/EEC Low Voltage Directive
 - EN 50178 LVD Standard
- IEC529, IEC60034-5, IEC61131-3
- MIL STND 461

Optional Modules

CAN annunciator



The EMCP 4 CAN Annunciator serves to display generator set system alarm conditions and status indications. The annunciator has been designed for use on the accessory communication network and may be used in either local (package mounted) or remote (up to 800 feet) application. A maximum of four annunciators may be used with a single EMCP.

RS-485 annunciator



The EMCP 4 RS-485 Annunciator serves to display generator set system alarm conditions and status indications. The annunciator has been designed for use on the long distance annunciator datalink and is used for remote (up to 4000 feet) application.

The remote monitoring software allows the user to configure data monitoring and data acquisition processes for monitoring, graphing, and logging of generator set data.

Qty. (1) Local Annunciator factory installed on generator set.


Qty. (1) Remote Annunciator ships loose for on-site contractor installation

Remote monitoring software



The EMCP remote monitoring software package is a PC based program which allows the user to monitor and control a generator set, and is capable of running on a Windows based operating system. The remote monitoring software allows the user to configure data monitoring and data acquisition processes for monitoring, graphing, and logging of generator set data.

Programmable logic software



The EMCP programmable logic software package is a PC based program which allows the configuration of the programmable logic blocks, and is capable of running on a Windows based operating system. The programmable logic software allows the user to configure logic to change the operation of the EMCP control and interfaces within a limited scope.

Optional Modules (Continued)

Digital input/output module



The Digital Input/Output (DI/O) module serves to provide expandable Input and Output event capability of the EMCP 4 and is capable of reading 12 digital inputs and setting 8 relay outputs.

The DI/O module has been designed for use on the accessory Communication Network and may be used in either local (package mounted) or remote (up to 800 feet) application.

RTD module

The RTD module serves to provide expandable generator temperature monitoring capability of the EMCP 4 and is capable of reading up to eight type 2-wire, 3-wire and 4-wire RTD inputs.

The RTD Module has been designed for use on the Accessory Communication Network and may be used in either local (package mounted) or remote (up to 800 feet) application. A maximum of one RTD Module may be used with a single EMCP 4.

Qty. (1) DI/O Module comes factory installed in generator set control panel

Qty. (1) RTD module factory installed as part of generator set

Thermocouple module

The thermocouple module serves to provide expandable engine and generator temperature monitoring capability of the EMCP 4 and is capable of reading up to twenty Type J or K thermocouple inputs.

The thermocouple module has been designed for use on the primary communication network for engine information and the accessory communication network for generator information. It may be used in either local (package mounted) or remote (up to 800 feet) application. A maximum of one thermocouple modules may be used with a single EMCP 4 on each datalink.

Materials and specifications are subject to change without notice.

CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

Cat® Batteries



Cat Batteries — Greater Starting Power — Lower Maintenance — Longer Life

Cat Premium High Output (PHO) batteries are used in all Caterpillar Machines and Engine Gen-Sets. They are designed to meet stringent Caterpillar design specifications, which provide industry leading cold cranking amp (CCA) capability and maximum vibration resistance.

Maintenance Free or low maintenance designs are available in wet and dry configurations.

General Service Line batteries are available in Maintenance Free or low maintenance designs and in wet or dry configurations. Wide selections of BCI group sizes are available for automotive, light truck, bus, industrial, agricultural, marine, recreational and valve regulated (VRLA-AGM & Gel) applications.

Caterpillar. The difference counts.™

Cat Dealers define world – class product support. We offer you the right parts and service solutions, when and where you need them.

The Cat Dealer network of highly trained experts keeps your entire fleet up and running to maximize your equipment investments.

CATERPILLAR®

World's Toughest Batteries



Premium High Output – Maximum Vibration Resistance

- Vibration Resistance...five times the Industry Standard
- Exclusive “flat top” BCI group 4D & 8D batteries are Maintenance Free and have the industries highest cold cranking amps (CCA)
- Popular BCI group 31 Maintenance Free batteries with industry leading cold cranking amps...up to 1000 (CCA), for electric power, machine or on-highway truck and bus applications. Deep cycle models available for truck, marine or recreational usage

Specifications for Cat Premium High Output Batteries – Available Worldwide

BCI Group Size	Part No.	Cold Cranking Amps**	Reserve Capacity Minutes	Volts	Amp Hr. Capacity @ 20 Hrs.	Construction	Add Water Maintenance Check Hours	BCI Overall Dimensions				Nominal Weight	
								Length In (mm)	Width In (mm)	Height In (mm)	Wet Lb (kg)	Dry Lb (kg)	Nominal Acid to Fill Qt (liter)
8D	153-5720	1500	465	12	210	C	MF	20.47 (520)	10.8 (275)	9.76 (248)	132 (60)	-	-
4D	101-4000	1400	400	12	150	LAC+	MFA	20.7 (526.5)	10.56 (270)	9.76 (248)	122 (60)	86 (39)	18.0 (11.0)
4D	153-5710	1200	325	12	200	C	MFA	20.47 (520)	8.58 (218)	9.76 (248)	119 (54)	-	-
4D	153-5700	1200	305	12	145	C	MFA	20.47 (520)	8.58 (218)	9.76 (248)	101 (46)	-	-
4D	9X-9720	1000	305	12	145	LAC+	MFA	20.47 (520)	8.58 (218)	9.76 (248)	119 (54)	81 (37)	14.0 (11.0)
4D	9X-9720	1000	305	12	145	LAC+	MFA	20.47 (520)	8.58 (218)	9.76 (248)	101 (46)	59 (27)	15.9 (12.0)
31	125-4330	1000	180	12	100	C-S*	MFA	12.9 (328.4)	6.74 (171.2)	9.25 (236)	60 (27)	-	-
31	125-4370	825	180	12	100	C-S**	MFA	12.9 (328.4)	6.74 (171.2)	9.25 (236)	60 (27)	-	-
31	125-4380	700	185	12	100	C-S***	MFA	12.9 (328.4)	6.74 (171.2)	9.25 (236)	60 (27)	-	-
31	250-0480	700	185	12	100	C-SDT***	MFA	12.9 (328.4)	6.74 (171.2)	9.25 (236)	60 (27)	-	-
31	125-2522	1000	170	12	90	C-SAE	MFA	12.9 (328.4)	6.74 (171.2)	9.76 (248.3)	60 (27)	-	-
31	115-2421	950	170	12	90	C-SAE	MFA	12.9 (328.4)	6.74 (171.2)	9.46 (240.3)	60 (27)	44 (20)	6.6 (6.2)
31	9X-3404	950	165	12	100	C-SAE	MFA	13 (330.2)	6.77 (172)	9.76 (248.3)	58 (26)	-	-
31	21-5760	750	165	12	100	C-SAE	MFA	13 (330.2)	6.77 (172)	9.46 (240.3)	55 (25)	-	-
74	153-5658	650	110	12	92	SC	MFA	10.99 (278.9)	6.85 (174)	9.0 (229.1)	38 (18)	-	-
65	231-6368	800	110	12	80	SC	MFA	11.9 (301.4)	7.6 (193.8)	7.5 (191.4)	45.5 (21)	-	-
74	153-5450	600	110	12	92	SC*	MFA	10.99 (278.9)	7.0 (178.2)	8.15 (205.9)	38 (18)	-	-
58	175-1280	500	70	12	35	SC	MFA	8.96 (228.1)	7.2 (182.5)	6.9 (174)	31 (14)	-	-
2	153-5690	800	210	8	80	LAC+	1000	10.21 (259)	6.8 (173)	8.72 (221.6)	37 (17)	22 (10)	4.8 (4.5)

Qty. (4) wired in series-parallel arrangement

Construction Notes:

- LAC = Low Maintenance, Hybrid Construction
- C = Calcium Lead Alloy Grid Design
- MF = Maintenance Free
- MFA = Maintenance Free with Accessible Vent Caps
- S = Stud Terminals
- + = Shipped Dry Only
- * = Side Terminals
- ** = Starting and Deep Cycle Battery
- *** = Deep Cycle and Starting Battery
- " = For 30 seconds at 0° F (-18° C)
- ' = Minimum of 25 amp output at 80° F (27° C)
- SAE = Uses SAE Posts
- SDT = Dual, Top mounted Terminals, Stud and SAE Post, Marine Deep Cycle/Starting Battery
- SC = Silver (Ag) Calcium Alloy Grids for resistance to high underhood temperatures

Rugged Design – Built Tough – Reliable Starting

- Positive and Negative plates are anchored to container bottom and locked at the top of cell element for maximum vibration resistance.
- Heavy-duty forged terminal post bushings provide maximum strength and resistance to acid seepage.
- Hefty full-frame grids, no sharp edges, optimum acid/paste combination provides better charge acceptance after deep discharge.
- Manifold vented cover with built-in Flame Arrestor...a safety feature that directs corrosive gases away from the battery and hold-downs.
- Thick, robust container resists rugged treatment typical of heavy-duty commercial use. Embossed part number & descriptors for easy serviceability.



2022 EPA Tier 2 Exhaust Emission Compliance Statement 500DFEK Stationary Emergency 60 Hz Diesel Generator Set

Compliance Information:

The engine used in this generator set complies with Tier 2 emissions limit of U.S. EPA New Source Performance Standards for stationary emergency engines under the provisions of 40 CFR 60 Subpart IIII.

Engine Manufacturer: Cummins Inc.
 EPA Certificate Number: NCEXL015.AAJ-051
 Effective Date: 09/03/2021
 Date Issued: 09/03/2021
 EPA Engine Family (Cummins Emissions Family): NCEXL015.AAJ

Engine Information:

Model: QSX/QSX15/QSX15-G/QSX15-G9 Bore: 5.39 in. (137 mm)
 Engine Nameplate HP: 755 Stroke: 6.65 in. (169 mm)
 Type: 4 Cycle, In-line, 6 Cylinder Diesel Displacement: 912 cu. in. (15 liters)
 Aspiration: Turbocharged and CAC Compression ratio: 17.0:1
 Emission Control Device: Electronic Control Exhaust stack diameter: 8 in. (203 mm)

Diesel Fuel Emission Limits

D2 Cycle Exhaust Emissions

	Grams per BHP-hr			Grams per kWm-hr		
	<u>NO_x + NMHC</u>	<u>CO</u>	<u>PM</u>	<u>NO_x + NMHC</u>	<u>CO</u>	<u>PM</u>
Test Results	4.3	0.4	0.10	5.7	0.6	0.13
EPA Emissions Limit	4.8	2.6	0.15	6.4	3.5	0.20

Test methods: EPA emissions recorded per 40 CFR Part 60, 89, 1039, 1065 and weighted at load points prescribed in the regulations for constant speed engines.

Diesel fuel specifications: Cetane number: 40-50, Reference: ASTM D975 No. 2-D, 300-500 ppm Sulfur

Reference conditions: Air Inlet Temperature: 25 °C (77 °F), Fuel Inlet Temperature: 40 °C (104 °F). Barometric Pressure: 100 kPa (29.53 in Hg), Humidity: 10.7 g/kg (75 grains H₂O/lb) of dry air; required for NO_x correction, Restrictions: Intake Restriction set to a maximum allowable limit for clean filter; Exhaust Back Pressure set to a maximum allowable limit..

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.



Exhaust Emission Data Sheet

500DFEK

60 Hz Diesel Generator Set

EPA NSPS Stationary Emergency

Engine Information:

Model:	Cummins Inc. QSX15-G9 NR 2	Bore:	5.39 in. (137 mm)
Nameplate BHP @ 1800 RPM:	755	Stroke:	6.65 in. (169 mm)
Type:	4 cycle, in-line, 6 cylinder diesel	Displacement:	912 cu. in. (14.9 liters)
Aspiration:	Turbocharged with air-to-air charge air cooling		
Compression Ratio:	17:1		
Emission Control Device:	Turbocharged with charge air-cooled		

	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>Full</u>	<u>Full</u>
<u>Performance Data</u>	<u>Standby</u>	<u>Standby</u>	<u>Standby</u>	<u>Standby</u>	<u>Prime</u>
Engine HP @ Stated Load (1800 RPM)	202	379	555	732	668
Fuel Consumption (gal/Hr)	11.3	18.7	25.8	34.7	30.6
Exhaust Gas Flow (CFM)	1400	2150	2730	3625	3160
Exhaust Gas Temperature (°F)	745	830	820	900	880
 <u>Exhaust Emission Data</u>					
HC (Total Unburned Hydrocarbons)	0.24	0.09	0.07	0.14	0.12
NOx (Oxides of Nitrogen as NO ₂)	3.24	3.65	4.64	4.43	4.04
CO (Carbon Monoxide)	0.57	0.34	0.40	0.39	0.36
PM (Particulate Matter)	0.09	0.05	0.05	0.02	0.02
Smoke (Pierburg)	0.52	0.44	0.42	0.21	0.20

All values (except smoke) are cited: g/BHP-hr

Test Methods and Conditions

Steady-state emissions recorded per ISO8178-1 during operation at rated engine speed (+/- 2%) and stated constant load (+/- 2%) with engine temperatures, pressures and emission rated stabilized.

Fuel specification:	40-48 Cetane Number, 0.05 Wt.% max. Sulfur; Reference ISO8178-5, 40CFR86.1313-98 Type 2-D and ASTM D975 No. 2-D.
Air Inlet Temperature:	25 °C (77 °F)
Fuel Inlet Temperature:	40 °C (104 °F)
Barometric Pressure:	100 kPa (29.53 in Hg)
Humidity:	10.7 g/kg (75 grains H ₂ O/lb) of dry air (required for NOx correction)
Intake Restriction:	Set to maximum allowable limit for clean filter
Exhaust Back Pressure:	Set to maximum allowable limit

Data was taken from a single engine test according to the test methods, fuel specification and reference conditions stated above and is subjected to instrumentation and engine-to-engine variability. Tests conducted with alternate test methods, instrumentation, fuel or reference conditions can yield different results.

Gas Fired Equipment

Unit ID	Unit Type	Manuf	Qty	Model # (if available)	BTU in	BTU Tot
	Kitchen	Baker Flat Top Grill	2		160000	320,000
		Rational	6		106500	639,000
		Blodget	2		50000	100,000
		Groen	1		144000	144,000
		Rational	1		303000	303,000
		Rational	2		170000	340,000

Gas Fired Equipment

Unit ID	Unit Type	Manuf	Qty	Model # (if available)	BTU in	BTU Tot
	Kitchen	Vulcan Grill	1		66000	66,000
		Vulcan Stove Top	1		12000	12,000
						-
						-
						-
						-

Gas Fired Equipment

Unit ID	Unit Type	Manuf	Qty	Model # (if available)	BTU in	BTU Tot
						-
						-
						-
						-
						-
						-

